

King Water Company
P.O. Box 2243
Oak Harbor, Washington 98277
(888) 241 2503 Toll free
(360) 678 5336 Local

January 5, 2019

Routine Work for Sky Meadows Community

On Mondays and Fridays we drive through the system checking for leaks and anything unusual. In addition, we:

1. Read the master meter and record the usage. We calculate the average daily usage, which can be indicative of a leak if there is an abnormal jump in usage.
2. Take a monthly water sample and have it tested for coliform bacteria.
3. Maintain the filtration, supply chemicals and check levels of manganese weekly.
4. Flush the blow offs to clean out the water lines, as needed.
5. Respond to all complaints concerning water problems in the community.
6. Take all required testing for the state or county health department. Act as the primary interface with the respective departments.
7. Maintain all paperwork required by the state or county.
8. Check well pumping rates.
9. Order materials and repair leaks and equipment as needed.
10. Write the consumer confidence report.
11. Schedule and perform the annual reservoir cleaning.

In addition to the above, the following may be of interest:

December 2017

Took TTHM and HAA tests

March 2018

Full system flush.

April 2018

Took conductivity and chloride test on each well.

June 2018

Prepare water use efficiency
Service mazzie injectors

August 2018

Took conductivity and chloride on each well.
Took nitrate test.

September 2018

Full system flush.

October 2018

Air scrubbed filters, acid washed air and check valves.

December 2018

Took Herbicide Test

Sincerely,
King Water Company

Sky Meadows - Monthly Water Usage

