

**West Virginia Department of Health &
Human Resources
Berkeley County Health Department**

No image found with name:
Berkeley.png. Image files
needed to be generated.

FOOD ESTABLISHMENT INSPECTION REPORT

Establishment Information		
Facility Name Rosemont Elementary	Facility Type Food Service Establishment	
Licensee Name Berkeley Co. Board of Education	Facility Telephone # 304	
Facility Address 301 S Alabama Ave Martinsburg , WV	Licensee Address ,	
Inspection Information		
Inspection Type Routine	Inspection Date 11/26/2018	Total Time Spent 1.50

Equipment Temperatures	
Description	Temperature (Fahrenheit)
Hoshizaki left	37
Hoshizaki-right	37
Metro Hot Hold	151
True Refrigerator	40
Milk Left	38
Milk Right	38

Food Temperatures	
Description	Temperature (Fahrenheit)
Broccoli	147

Warewashing Info					
Machine Name	Sanitization Method	Thermo Label	PPM	Sanitizer Name	Sanitizer Type
BucketDishwasher	Chemical	160	100	ChlorineHeat	

OPERATOR - Violations cited in this report shall be corrected within the time frames specified below, but within a period not to exceed 10 calendar days for critical items (§ 8-405.11) or 90 days for non-critical items (§ 8-406.11).

Observed Critical Violations
<p>Total # 1 Repeated # 0</p> <p>4-602.11 - EQUIPMENT FOOD-CONTACT SURFACE This is a critical violation OBSERVATION: (CORRECTED DURING INSPECTION): Inside of ice machine needs cleaned (mold)</p>

Observed Non-Critical Violations

Total # 3

Repeated # 0

6-501.11 - PHYSICAL FACILITIES - GOOD REPAIR

OBSERVATION: Drain line on ice machine needs repaired (leaking)

6-501.11 - PHYSICAL FACILITIES - GOOD REPAIR

OBSERVATION: Water pipe holes under 3-Bay/Prep sinks need sealed.

6-501.12 - CLEANING, FREQUENCY AND RESTRICTIONS

OBSERVATION: Ceiling vent cover in bathroom needs cleaned (dust/debris)

Inspection Outcome

Comments

Disclaimer

Person in Charge

Sanitarian



Carolyn Linton



Keith Allison