



SMOKE DETECTOR LEGISLATION



(425 ILCS 60/3) (from Ch. 127 1/2, par. 803) Sec. 3.

(a) Every dwelling unit shall be equipped with at least one approved smoke detector in an operating condition **within 15 feet of every room used for sleeping purposes.** The detector shall be installed on the ceiling and at least 6 inches from any wall, or on a wall located between 4 and 6 inches from the ceiling.

(b) Every single family residence shall have at least **one (1) approved smoke detector installed on every story of the dwelling unit, including basements** but not including unoccupied attics. In dwelling units with split levels, a smoke detector installed on the upper level shall suffice for the adjacent lower level if the lower level is less than one full story below the upper level; however, if there is an intervening door between the adjacent levels, a smoke detector shall be installed on each level.



Need help in the placement of smoke detectors or changing batteries ?

Contact;

Palos Fire Protection District
8815 W. 123rd Street
Palos Park, IL 60464

(708) 448-0369