

**Aspen Acres Association**  
**Cross Connection Control and Backflow Prevention**

1. It shall be against the policy of Aspen Acres Association, at any connection supplied with water from the Association distribution system, to do any of the following:
  - a. To install or use any physical connection or arrangement of piping or fixtures, which may allow any fluid or substances unsuitable for human consumption to enter the potable water distribution system, as required by Section 608.1 through 608.5 of the International Plumbing Code.
  - b. To install any connection, arrangement, or fixtures without a backflow prevention device or assembly unless approved otherwise by the Board of Aspen Acres Association.
  - c. To incorrectly instal any backflow prevention device or assembly required by Section 608.1 and 608.6 of the International Plumbing Code.
2. Any person found in violation of this policy shall be required to immediately make all necessary corrections and may be subject to other appropriate action as determined by the Board of Aspen Acres Association.
3. This policy shall take effect April 18, 2007. A copy of the policy shall be provided at the 2007 Annual Meeting and will be available on the Association web site at [www.aspenacres.org](http://www.aspenacres.org).