

**West Virginia Department of Health &
Human Resources
Berkeley County Health Department**

No image found with name:
Berkeley.png. Image files
needed to be generated.

CHILD CARE CENTER INSPECTION REPORT

Establishment Information	
Facility Name RESA 8 Hack Wilson Way	Facility Type Child Care Center
Licensee Name RESA VIII Head Start	Facility Telephone # 304 263-6222
Facility Address 750 Hack Wilson Way Martinsburg , WV	Licensee Address ,

Establishment Details	
Adult to Child Ratio	Rm 1 13:2; Rm 2 17:2; Rm 3 16:2; Rm 4 8:2; Rm 5 16:2; Rm 6 17:2=87/12

Inspection Information		
Inspection Type Routine	Inspection Date 02/06/2018	Total Time Spent 1.75

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
<p>Total # 16 Repeated # 3</p> <p>14.1 - All areas and equipment of the child care center shall be kept clean and in good repair and in a neat and orderly condition at all times. Indoor environmental surfaces associated with children's activities, such as table tops, shall be cleaned and disinf OBSERVATION: Rm 1 restroom-coving stained and walls need painted-caulk needed at base of toilet</p> <p>14.1 - All areas and equipment of the child care center shall be kept clean and in good repair and in a neat and orderly condition at all times. Indoor environmental surfaces associated with children's activities, such as table tops, shall be cleaned and disinf OBSERVATION: Rm 1-blue couch needs cleaned; Rm 3 red couches need cleaned(down in corners); Rm 4 red couches need cleaned</p> <p>16.5 - A first aid kit shall be provided on the premises and shall be readily available at all times. The minimum contents of the kit shall include, but not be limited to, band aids; thermometer; gauze; tape; scissors; tweezers; disposable, nonporous gloves; a OBSERVATION: Rm 4-first aid kit needs a water bottle</p> <p>18.2 - Poisons and other potentially hazardous items shall be inaccessible to children and stored in their original containers. OBSERVATION: (CORRECTED DURING INSPECTION): Rm 1-spray bottle of Dawn soapy water needs to be labeled and Rm 5-spray bottle in restroom needs to be labeled(staff not aware of product)</p> <p>5.1.B. - Child care center buildings or structures shall be of sound structure and maintained in good repair. OBSERVATION: Rm 5-restroom floor tiles stained</p>

5.1.B. - Child care center buildings or structures shall be of sound structure and maintained in good repair.

OBSERVATION: Rm 4-wall coving taped to wall/needs secured

5.1.B. - Child care center buildings or structures shall be of sound structure and maintained in good repair.

OBSERVATION: Rm 2-outlet cover broken and cable cover box taped to wall

5.1.B. - Child care center buildings or structures shall be of sound structure and maintained in good repair.

OBSERVATION: Rm 2-light bulbs not working over sink

5.1.B. - Child care center buildings or structures shall be of sound structure and maintained in good repair.

OBSERVATION: Rm 3-shelf has fallen off wall-brackets taped(work order placed)

5.1.B. - Child care center buildings or structures shall be of sound structure and maintained in good repair.

OBSERVATION: Rm 2 restroom-holes in wall need patched

5.1.B. - Child care center buildings or structures shall be of sound structure and maintained in good repair.

REPEAT OBSERVATION Rm 4-restroom faucet dripping and new caulk needed behind sink

5.1.B. - Child care center buildings or structures shall be of sound structure and maintained in good repair.

OBSERVATION: Rm 6-back toilet not flushing properly

5.2.A - Floors, walls and ceilings shall be of easily cleanable construction.

OBSERVATION: Rm 3-wall vent needs cleaned

5.2.A - Floors, walls and ceilings shall be of easily cleanable construction.

REPEAT OBSERVATION Rm 5-ceiling vents need dusted and also in Rm 6

5.2.E - Carpeting shall be securely attached or of a non-skid nature.

REPEAT OBSERVATION Rm 1-black rug edges frayed; Rm 2-tan rug; Rm 6-edges pulled up(trip hazard)

5.4.E - Only those insecticides and rodenticides approved by the U. S. Environmental Protection Agency shall be used in child care centers.

OBSERVATION: Rm 5-snap trap observed in closet not approved

Inspection Outcome

Comments


Playground snow/ice covered

Disclaimer

Person in Charge



Sanitarian



Amy ARE Edwards