

# Karnataka Material Testing & Research Centre

(ASSISTED BY GOVT. OF KARNATAKA &amp; GOVT. OF INDIA)

G-4 &amp; 5, Industrial Estate, Gokul Road, HUBLI-580 030 (Karnataka)

Tel. : 0836 - 2330423 Cell: 09448124486 • Email : kmtrc\_hubli96@yahoo.co.in

Website : www.materialtestinghubli.com

**NABL ACCREDITED, BIS RECOGNISED, ISO 9001 CERTIFIED LABORATORY**

## WATER TEST REPORT

Sheet No.1 of 1

Customer : <b>J.K. Education Society's</b> Smt. Drakshayani Kalyanshettar Public School (CBSE), R.S. No. 179/1A/2, Shakti Colony, Near Adhyapak Nagar, HUBLI - 580 032		Report No. : <b>KMTRC / 23-24 / 05 / Aa</b> Date of Issue : <b>05.04.2023</b> Date of Test : <b>04.04.2023</b> Tested at : <b>KMTRC</b> Y/R No. & Date : <b>DK/02/2023-24 / 03.04.2023</b> Date of Receipt : <b>03.04.2023</b>	
Sample Details :	1		
Material / Speciman :	Water Sample		
Test Device Details :	Instruments & Volumetric		
Test Details :			
Sl. No.	PARAMETER	STANDARD REQUIREMENT IS : 10500 : 1991	ACTUAL
1.	Hydrogen Ion Concentration (pH)	6.50 TO 8.50	7.30 at 25.0°C
2.	Electric Conductivity (EC)	-- --	183.6 mS at 25.0°C
3.	Total Dissolved Solids mg / l, max (TDS)	-- 500.00	121.8 ppm at 25.0°C
4.	Calcium mg / l, max (Ca)	-- 075.00	13.60 mg/ltr
5.	Magnesium mg / l, max (Mg)	-- 030.00	7.776 mg/ltr
6.	Total Hardness mg / l, max (TH)	-- 300.00	66.00 mg/ltr
Other Details :			
1. Procedure Used : IS:3025			
REMARK :			
STATEMENT : 1) This report should not be reproduced except in full without written approval of the laboratory. 2) The test results relate only to the items/samples tested. 3) Feed back complaints if any, to be intimated within 10 days from date of receipt of the Test Report / Calibration Certificate			
for KARNATAKA MATERIAL TESTING & RESEARCH CENTRE,			
Tested by / Checked by: <i>Sell</i> 5/4/23		Approved by : <i>N.H. Kulkarni</i>	
Name : Shivaraj C Kammar		N.H. Kulkarni	
Designation : Chemical Asst.		Quality Manager	

Format : KMT/CHEM/F/01.Rev.01





SANITARY CONDITION CERTIFICATE.

No. HDMC/GWM/24/05/2023-24

Date : 14/09/2023

It is certified that an inspection team headed by NAYANA K.S

ENVIRONMENTAL ENGINEER (Name of Officers

with designation) from SOLID WASTE MANAGEMENT Dept., HDMC (Name of

Department/Office) inspected the J K Education Society's( R ) - Smt Drakshayani Kalyanshettar Public School, Shakti Colony , Near Adhyapak Nagar Hubli. (Name & Address

of the School) on 11/09/2023 and found that the Smt Drakshayani Kalyanshettar Public School (Name of school) has facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of two years.

Signature with Seal : [Signature]

Name : NAYANA K-S

Designation : Environmental Engineer

To

J K Education Society's ( R )

Smt Drakshayani Kalyanshettar Public School,

Shakti Colony , Near Adhyapak Nagar Hubli.

(Name & Address of the Institution)

ಪರಿಸರ ಅಭಿಯಂತರರು  
ಹುಬ್ಬಳ್ಳಿ-ಧಾರವಾಡ ಮಹಾನಗರ ಪಾಲಿಕೆ  
ಹುಬ್ಬಳ್ಳಿ