

**OIL MARKETERS
INDOOR STORAGE TANK EVALUATION
(Fuel Oil Tanks Located in Buildings)**

Name: _____

Address: _____

City/State: _____

Phone: (____) _____

These are minimum requirements. The tank manufacturer may specify additional safeguards. Answering "NO" to any of the following indicates a change may be needed.

TANK SYSTEM:

Size of indoor tank(s) _____

Product in tank(s) _____

Condition of tank(s) _____

Location of tanks(s) Basement 1st floor Other (describe) _____

Tanks larger than 10 gal. at least 5 ft. from a fire or flame?..... Yes No

Satisfactory condition of tank legs and foundation Yes No

No observable indication of corrosion..... Yes No

PIPING SYSTEM:

Condition of supply piping _____

All piping and tubing is wrought-iron, steel, copper or brass?..... Yes No

Operable shut-off valve at tank? Yes No

Unused tank openings plugged or capped?..... Yes No

Fill and vent openings piped outside?..... Yes No

(If "No" then explain) _____

Fill pipes identified by tag or color? Yes No

VENTS:

Condition of vents _____

Size of vent pipe 1¼" 1½" 2" (Other _____)

Fill and vent pipes terminate at least two feet from building openings?..... Yes No

Vent pipes free of obstructions? Yes No

Vents at least as large as the pump discharge when filled through

tight connections?..... Yes No

Liquid level vent alarm installed..... Yes No

* Consult the National Fire Protection Association standard #31 "Standard for the Safe Installation of Oil Burning Equipment" for additional requirements.

Dear Customer,

Your fuel tank, lines, piping and appliances ("system") are designed and installed for the storage and use of fuel. All consumers should carefully and periodically inspect the system or hire a competent independent person to do so for them. If any defects are discovered or if the system is withdrawn from use *you must immediately notify your fuel supplier.*

Today your fuel supplier evaluated your fuel system according to minimum reasonable requirements for a safe installation.

The inspection is not an undertaking to you or anyone else that the system is in a safe condition or in compliance with any applicable law. We do not warrant or certify that the system is safe, free of defect or leaks or that its use may not result in malfunction, personal injury or property damage.

Service Person's Name _____ Date _____
