

**West Virginia Department of Health &
Human Resources
Berkeley County Health Department**

No image found with name:
Berkeley.png. Image files
needed to be generated.

GENERAL SANITATION INSPECTION REPORT

<i>Establishment Information</i>		
Facility Name Hedgesville Middle School	Facility Type School	
Licensee Name Berkeley Co. Board of Education	Facility Telephone # 304 754-3313	
Facility Address 334 School House Drive Hedgesville, WV	Licensee Address ,	
<i>Inspection Information</i>		
Inspection Type Routine	Inspection Date 07/16/2018	Total Time Spent 2.50

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

<i>Observed Violations</i>
<p>Total # 5 Repeated # 0</p> <p>64-18-14.2 - Any plumbing or drainage system under the jurisdiction of this rule shall be maintained in good repair and in a sanitary and serviceable condition by the owner or his agent. OBSERVATION: Water leaks observed in faucets in copy room, science lab area in between rooms and in old shower room used for storage.</p> <p>64-18-19.2 - Floors, interior walls and ceilings shall be sound and in good repair. OBSERVATION: Several areas of the school have stained ceiling tiles, possible water leaks.</p> <p>64-18-19.2 - Floors, interior walls and ceilings shall be sound and in good repair. OBSERVATION: Walls in new resource room and rm 25 need repaired</p> <p>64-18-19.2 - Floors, interior walls and ceilings shall be sound and in good repair. OBSERVATION: Tile floor in the Session room/ Shepherd room needs repaired, missing and starting to come up in several areas.</p> <p>64-18-22.3 - Doors, windows & exterior openings shall be effectively protected against rodents, insects, & other vermin. Areas include, not limited to, food service, toilet, & housing areas. Not applicable primitive & outpost camping or similar recreational activities OBSERVATION: Ants observed in the sydent teaching kitchen by the windows and in the upper staircases</p>

<i>Inspection Outcome</i>

<i>Comments</i>

Disclaimer

Person in Charge
On file

Sanitarian
Glenn GCO Ondick