

2015 IECC Prescriptive Requirements (NTCOG amended)

Insulation (min.)

Attic: R-38

No attic: R-30

2x4 walls: R-13+3 (R-13 cavity + R-3 insulating sheathing)

2x6 walls: R-19

Underfloor over unconditioned space: R-19

Fenestrations (max.)

Windows & glass doors: U-factor 0.35, SHGC 0.25

Skylights: U-factor 0.55, 0.25 SHGC

Mechanical systems (min.)

14 SEER

supply ducts in unconditioned space: R-6

return ducts in unconditioned space: R-6

refrigerant piping: R-3

hot water piping: R-3

Lighting

75% of the permanently installed light fixtures to have high efficiency lamps (CFL or LED)