




**RADHA KRISHNA TEMPLE**  
 Owner  
 ALLEN TEXAS


PROJECT  
 JOB NUMBER  
 16DLS003  
 ISSUE DATE  
 04-22-2016  
 DRAWN BY  
 SDB  
 DESIGNED BY  
 NAV

REVISIONS





SHEET NUMBER  
**S0.2A**


MISCELLANEOUS SECTIONS




**1** TYPICAL OPENING IN MASONRY WALL  
 S0.2A 1/2" = 1'-0"




**6** TYPICAL PIPE SLEEVE SECTIONS  
 S0.2A 1" = 1'-0"



**7** TYPICAL FRAMING ABOUT ROOF HATCH / ROOF DRAIN  
 S0.2A 3/4" = 1'-0"



**5** CONTROL JOINTS IN CONCRETE SLAB ON GRADE  
 S0.2A 3/4" = 1'-0"




**9** TYPICAL SLAB JOINT DETAILS  
 S0.2A 3/4" = 1'-0"

**LOOSE LINTEL SCHEDULE**

WALL	OPENINGS	ANGLE OPTION 1	ANGLE OPTION 2
6"	TO 4'-0"	2-L3x3x1/4	
	TO 4'-0"	2-L3x3x1/4	1-L8x8x3/8
8"	4'-1" TO 7'-0"	2-L6x4x5/16 LLV	
	TO 4'-0"	2-L5x5x1/4	
12"	TO 4'-0"	2-L5x5x1/4	
	4'-1" TO 7'-0"	2-L6x4x5/16 LLV	


FOR OPENINGS LARGER THAN 4'-0", ATTACH VERTICAL LEG OF ANGLES TO WALL WITH 1/2" THRU-BOLTS AT 16"




**4** TYPICAL MECHANICAL OPENING IN CMU WALL (LOAD BEARING OR NON-LOAD BEARING WALLS)  
 S0.2A 3/4" = 1'-0"

**BOND BEAM SCHEDULE**

WALL	OPENINGS	BOND BEAM	REINF BARS	REMARKS
8"	TO 4'-0"	8"	2-#5 BOTT.	
	4'-1" TO 6'-0"	16"	2-#5 TOP & BOTT.	



**8** TYPICAL REINFORCING AT CMU OPENINGS  
 S0.2A 3/4" = 1'-0"



**7** TYPICAL FRAMING ABOUT ROOF HATCH / ROOF DRAIN  
 S0.2A 3/4" = 1'-0"