



Village of Richwood 2019 Drinking Water Consumer Confidence Report PWS# OH8000412

The Village of Richwood has an unconditional license to operate a water plant

Introduction

The Village of Richwood has prepared the following report to provide information to you, the consumer, on the quality of our drinking water. Included within this report is general health information, water quality test results, how to participate in decisions concerning your drinking water and water system contacts. Public participation and comments are encouraged at regular Village Council meetings, which meet the second and fourth Mondays of each month at the Administration Building at 153 N. Franklin Street. For more information on your drinking water, contact Monte Asher, Village Administrator at (740) 943-3315 during business hours.

Source Water Information

The Village of Richwood receives its drinking water from two wells located west of the North Union High School on North Franklin Street. Both of these wells are considered ground water sources with required treatment prior to being used for drinking. The water treatment plant currently operates as an iron removal plant and has the capacity to treat 374,000 gallons per day.

What are sources of contamination to drinking water?

The sources of drinking water (both tap water and bottled water) includes rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include: (A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife; (B) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; (C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; (D) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; (E) Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline ([1-800-426-4791](tel:1-800-426-4791)).

Drinking Water Source Assessment

This assessment indicates that The Village of Richwood's source drinking water has high susceptibility to contamination due to:

- A Presence of a relatively thin protective layer of clay/shale/other overlaying the aquifer.
- Shallow depth (less than 30 feet below ground surface) of the aquifer.
- No evidence to suggest that ground water has impacted by any significant levels of chemical contaminants from human activities.
- A presence of significant, potential contaminant sources in the protection area.

This susceptibility means that under currently existing conditions, the likelihood of the aquifer becoming contaminated is relatively high. This likelihood can be minimized by implementing appropriate protective measures. More information about the source water assessment or what consumers can do to help protect the aquifer is available on-line at <http://www.wapp.epa.ohio.gov/gis.swpa/OH8000412.pdf>.

Who needs to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, people who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infection. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

About your drinking water

The EPA requires regular sampling to ensure drinking water safety. The Village of Richwood Water Department has conducted sampling for bacteria, nitrate, inorganic, radiological, volatile organic contaminants, Haloacetic Acids and Total Trihalomethanes. The Ohio EPA requires public water suppliers to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though accurate, are more than one year old.

License to operate status:

In 2019, we had an unconditioned license to operate our water system.

How do I participate in decisions concerning my drinking water?

Public participation and comment are encouraged at regular Village Council meetings. Meetings are held at 7PM on the second and fourth Monday of each month at the Village Administrative Offices. You may also contact the Village of Richwood with any questions at 740-943-3315.

Lead Educational Information

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Village of Richwood is responsible for providing high quality drinking water but cannot control the variety of material used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in drinking water, you may wish to have your water tested. A list of laboratories certified in the State of Ohio to test for lead may be found at <http://www.epa.ohio.gov/ddagw> or by calling (614) 644-2752. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the:

Safe Water Hotline at (800) 426-4791 or at <http://www.epa.gov/safewater/lead>

2019 Drinking Water Consumer Confidence Report PWS# OH8000412

The Village of Richwood has an unconditional license to operate a water plant

Listed below is information on those contaminants that were found in The Village of Richwood drinking water. The Village of Richwood samples for a number of contaminants, most are non-detects. *The table below only indicates the contaminants that were detected.*

Regulated Contaminants

Contaminants (Units)	MCLG	MCL	Level Found	Range of Detection	Violations	Sample Year	Typical Source of Contaminants	Health Effects Language
Residual Disinfectants								
Chlorine (ppm)	4	4	1.29	0.90-2.09	N	2019	Water Additives used to control Microbes	Some people who use water containing chlorine well in excess of the MRDL could experience irritation effects to their eyes and nose. Some People who drink water containing chlorine well in excess of the MRDL could experience stomach discomfort
Total Trihalomethane, TTHMs (ppb)	N/A	80	19.7-33.5	19.7-33.5	N	2019	By-product of drinking water chlorination	Some people who drink water containing trihalomethane in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer
Haloacetic Acids, HAA5 (ppb)	N/A	60	6.3-9.7	6.3-9.7	N	2019	By-product of drinking water chlorination	Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

Contaminants (Units)	MCLG	MCL	Level Found	Range of Detection	Violations	Sample Year	Typical Source of Contaminants	Health Effects Language
Inorganic Contaminants								
Barium (ppm)	2	2	0.0775	0.0775	N	2019	Discharge from drilling waste; Discharge of metal refineries; Erosion of natural deposits	Some people who drink water containing barium in excess of the MCL over many years could experience an increase in their blood pressure.
Fluoride (ppm)	4	4	1.29	1.29	N	2016	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories	Some people who drink water containing fluoride in excess of the MCL over many years could get bone disease, including pain and tenderness of the bones. Children may get mottled teeth.

Lead & Copper						
Contaminants (Units)	Action Level (AL)	Individual Results over the AL	90% of test levels were less than	Violations	Year Sampled	Typical Source of Contaminants
Lead (ppb)*	15 ppb	146	ND	N	2019	Corrosion of household plumbing; Erosion of natural deposits
Copper (ppm)**	1.3 ppm	N/A	0.154	N	2019	Erosion of natural deposits, leeching from wood and preservatives, corrosion of household plumbing systems

Regulated Contaminants *1 out of 11 samples were found to have lead levels in excess of the lead action level of 15 ppb.

** 0 out of 11 samples were found to have copper levels in excess of the copper action level of 1.3 ppm.

Synthetic Organic Chemicals (SOC)								
Contaminants (Units)	MCLG	MCL	Level Found	Range of Detection	Violations	Sample Year	Typical Source of Contaminants	Health Effects Language
Alachlor (ppb)	0	2	<0.00002 ppb	N/A	N	2018	Runoff from herbicide used on row crops	Some people who drink water containing Alachlor in excess of the MCL over many years could have problems with their eyes, liver, kidneys, or spleen, or experience anemia, and may have an increased risk of getting cancer.
Atrazine (ppb)	3	3	<0.00003 ppb	N/A	N	2018	Runoff from herbicide used on row crops	Some people who drink water containing atrazine well in excess of the MCL over many years could experience problems with their cardiovascular system or reproductive difficulties.
Simazine (ppb)	4	4	<0.000035 ppb	N/A	N	2018	Herbicide runoff	Some people who drink water containing simazine in excess of the MCL over many years could experience problems with their blood

Table Definitions- In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, we have provided the following definitions.

AL (Action Level)	The concentration of a contaminant which if exceeded, triggers treatment or other requirements which a water system must follow.
MCL (Maximum Contaminant Level)	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG (Maximum Contaminant Level Goal)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MRDL (Maximum Residual Disinfectant Level)	The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MRDLG (Maximum Residual Disinfectant Level Goal)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
N	None
N/A (Not Applicable)	
PPB (Parts per Billion)	One part substance per billion parts water (or micrograms per liter)
PPM (Parts per Million)	One part substance per million parts water (or milligrams per liter)

DRINKING WATER NOTICE

Monitoring requirements were not met for RICHWOOD VILLAGE PWS

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During May 2019, we did not complete all monitoring or testing for total coliform bacteria, and therefore, cannot be sure of the quality of your drinking water during that time.

What Should I Do?

There is nothing you need to do at this time. You do not need to boil your water or take other corrective actions.

This notice is to inform you that RICHWOOD VILLAGE PWS did not monitor and report results for the presence of total coliform bacteria in the public drinking water system during the May 2019 time period, as required by the Ohio Environmental Protection Agency.

What Is Being Done?

Upon being notified of this violation, the water supply was required to have the drinking water analyzed for the above mentioned parameters. The water supplier will take steps to ensure that adequate monitoring will be performed in the future.

For more information, please contact Eric Kincaid at 740-943-3315
or at 153 N. Franklin St., Richwood, OH 43344

PWSID: OH8000412 Violation ID: 5863830