

TOWN OF DIX

Account #:

Utility Application Form

Applicants Name: _____
Service Address: _____
Billing Address: _____

Connection of New Service Only (check all that apply):

Water: Sewer: Effective Date: _____

- Are you or a resident physically disabled or mentally incapacitated? (Including: blindness, infirmity, or limited mobility? Yes: No:
- Name of spouse and/or other adult(s) occupants: _____

Home Phone: _____ Email: _____

Cell Phone(s): _____

Emergency Contact: _____

Address: _____ Phone: _____

If there are any changes in the above customer information it is the applicant's responsibility to contact the Town of Dix Office as soon as possible.

The undersigned hereby applies to have the above utility services and hereby agrees to observe all regulations set forth by the Town of Dix Board relative to the use of said utilities and to pay the established rates thereof. It is understood that in cases where a security deposit is required, no service will be connected or transferred until the full deposit fee is paid. It is further understood that the applicant assumes responsibility for bills rendered for said services commencing with the effective date of this application and continuing in force until submission of a signed termination notice, at which time responsibility will cease upon the effective date of termination.

Applicant Signature: _____ **Date:** _____

For Office Use Only

Transfer Fee: _____ Amount: _____

Proof of Ownership or Tenancy: _____ Request completed on: _____

**REGULATIONS & SPECIFICATIONS FOR WATER SERVICE LINES FROM
MUNICIPAL MAINS TO CUSTOMER POINT OF USE.**

Water Supply

1. Construction of the customer's water supply lines is to be accomplished by personnel provided by the customer. The tapping into the main line or establishing connection to an already installed curb stop shall be **DONE UNDER THE DIRECT SUPERVISION OF THE TOWN OF DIX WATER OPERATOR**, who is contracted through the Village of Watkins Glen.
2. The inside diameter size of the customer supply line shall be sufficient to allow acceptable usable volume and pressure at point of use, in any case at least $\frac{3}{4}$ inch inside diameter and no smaller.
3. Use non-jointed HIGH DENSITY POLYETHYLENE in the same out-side diameter as copper tubing and rated at 160 PSI or greater working pressure. (If not using copper)
4. At connection use stainless stiffener insert sleeves and copper compression fittings rated for in-ground service.
5. Install #14 AWG or larger copper wire directly over piping to enable future system location.
6. Water lines to be installed at a depth of **NO LESS** than 4 feet and must be laid in and covered with sand. Water lines cannot in any case be laid in the same trench with sewer, gas, steam, electrical or other conduit. **(Per State Law sewer and water lines must be at least 10 feet apart)**

All work requires inspection by the Water Operator PRIOR to covering and ONLY the Water Operator has the authority to turn the water on or off at the curb-stop.