# West Virginia Department of Health & Human Resources Berkeley County Health Department



#### CHILD CARE CENTER INSPECTION REPORT

Establishment Information		
Facility Name	Facility Type	
Norborne Day Care Center	Child Care Center	
Licensee Name	Facility Telephone #	
Norborne Day Care Board	304 263-2298	
Facility Address	Licensee Address	
200 W King St		
Martinsburg , WV	,	

Establishment Details				
Adult to Child Ratio	3's: 2/6; Pre-K: 2/6; 4's:2/7; 2's:4/1; school age: 2/7=9/30			
Inspection Information				
Inspection Type	Inspection Date	Total Time Spent		
Routine	06/08/2017	1.20		

**OPERATOR** - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

#### **ObservedViolations**

## Total #7

#### Repeated # 0

5.1.B. - Child care center buildings or structures shall be of sound structure and maintained in good repair. OBSERVATION: 3's room-several surfaces need recovered/painted-storage box, cabinet tops, etc

- 5.1.B. Child care center buildings or structures shall be of sound structure and maintained in good repair. OBSERVATION: lower restrooms-walls/floor need painted/repaired; boy's restroom toilet out of order
- 5.2.A Floors, walls and ceilings shall be of easily cleanable construction. OBSERVATION: Lower restrooms-area behind faucets need cleaned
- 5.2.A Floors, walls and ceilings shall be of easily cleanable construction. OBSERVATION: Pre-k:box fan, radio area, window blinds need dusted
- 5.2.A Floors, walls and ceilings shall be of easily cleanable construction. OBSERVATION: 3's room-window blinds need dusted
- 5.2.A Floors, walls and ceilings shall be of easily cleanable construction. OBSERVATION: 2's-window blind needs cleaned
- 5.5.A Play and activity surfaces shall have a minimum of fifty (50) foot candles of illumination at floor level. All other areas shall have at least thirty (30) foot candles of illumination at floor level.

  OBSERVATION: main restroom needs several light bulbs

## Inspection Outcome

Comments	

Disclaimer

Person in Charge

Sanitarian

Amy ARE Edwards