

SUNNYSIDE

Fugitive Dust Control Plan
Comprehensive Site Compliance Evaluation

This is an Annual Comprehensive Compliance Evaluation of Sunnyside's Fugitive Dust Control Plan.

Facility Name: Sunnyside Cogen (SCA) Evaluation Date: 7/25/22

Rusty Netz
Evaluation Year: 2022

Facility Representative: Rusty Netz Evaluator Title: Plant Engineer

General Dust Control Plan Requirements	Evaluation Item	Evaluation Result	Corrective Action Required	Target Date	Completion Date	Responsibility
Sunnyside Fugitive Dust Control Plan						
	Does the facility have an approved fugitive dust control plan in place?	Yes	UDAQ reviewed SCA's plan and approved on July 2022			R Netz
	Has any source information changed?	No				
	Has the process information changed?	No				
	Does the dust control plan adequately address potential sources of fugitive dust?	Yes				
	Are/have the required visual observations been adequate to evaluate the effectiveness of the plan?	Yes				
	Are the description and control procedures for potential sources of fugitive dust adequate for the facility to maintain fugitive emissions below permitting levels?	Yes				
	Is the employee/contractor training being conducted on the dust control plan and Title V air permit?	Yes				
	Is the training adequate?	Yes				

SUNNYSIDE

Fugitive Dust Control Plan
Comprehensive Site Compliance Evaluation

General Dust Control Plan Requirements	Evaluation Item	Evaluation Result	Corrective Action Required	Target Date	Completion Date	Responsibility
	Is proper recorded keeping in place?	Yes				
	Are dust control logs being maintained and filed?	Yes				
	Are training logs being maintained and filed?	Yes				
	Is the facility properly following record retention requirements?	Yes				
	Are there any changes that need to be made to the plan, which resulted from this comprehensive evaluation?	No				
	Were there any citizen complaints relating to the fugitive (dust) emissions pertaining to the CCR landfill and CCR operations?	Yes, one compliant on June 27, 2022	Increased loads of water for dust control to the area.	Completed the same day	Completed the same day	R Netz

Comments:

SCA adequately controlled fugitive emissions during this annual period using water trucks for dust control, and controlling truck speeds on any roads. SCA also reclaims the ash pile site on a regular basis which helps control fugitive emissions.