

Transfer	FCITC (MW)	Limiting PA
F to B	850	WERE-SPP
	3736.9	OPPD-SPP
	4465.4	OPPD-SPP
	4740.8	WERE-SPP
F to E	967.6	WERE-SPP

**Appendix D: Summary of Incremental Transfer Capabi
Transfers from Subsystem F**

Limiting Facility	Rating (MVA)	TDF (%)	LODF (%)
532765 HOYT 7 345kV - 532766 JEC N 7 345kV 1	896	-0.04146	-0.33419
645456 S3456 3 345kV - 645458 S3458 3 345kV 1	956	-0.05638	0.46663
645455 S3455 3 345kV - 645740 S3740 3 345kV 1	1073	-0.051	0.41264
532765 HOYT 7 345kV - 532766 JEC N 7 345kV 1	896	-0.04327	N/A
532765 HOYT 7 345 - 532766 JEC N 7	896	-0.03662	-0.33419

ilities

Cont.PA	Contingency / Outaged Facility	Operating Guide
WERE-SPP	532766 JEC N 7 345kV - 532767 GEARY 7 345kV 1	
OPPD-SPP	645455 S3455 3 345kV - 645740 S3740 3 345kV 1	
OPPD-SPP	645456 S3456 3 345kV - 645458 S3458 3 345kV 1	
N/A	No Contingency	
WERE-SPP	532766 JEC N 7 345 - 532767 GEARY 7 345 1	