

Town of Parkton Performance Annual Report

I. General Information:

Facility / System Name: Parkton Wastewater Treatment Plant
Responsible Entity: Town of Parkton
Person in Charge /Contact: Timothy E. Little (910)-858-3360
Applicable Permit(s): NC0026921

Description of Collection System or Treatment Process:

Operation of a 0.2 MGD wastewater treatment facility consisting of a manual bar screen, two oxidation ditches operated in parallel treatment trains, two clarifiers with flow directed to a Partial flume and flow meter, step down post aeration, aerated sludge digester with sludge drying beds, and post chlorination. This facility is located at the Parkton WWTP, on NC SR 1724 southeast of Parkton in Robeson County. The wastewater collection system consists of 2 miles of gravity flow sewer mains and 1.5 miles of force mains. We have two lift stations one that pumps waste water to different location in the collection system. Lift station # 2 pumps sewer water to the wastewater treatment plant.

II. Performance:

Text summary of System for Calendar Year 2016:

3 - Permit Violations

3 - Notice of Violation

11 - Sanitary Sewer Overflow

0 - Notice of Deficiency


The 11 sanitary sewer overflows were caused by I&I due to excessive rainfall amounts. Five of the 11 sanitary sewer overflows were due to Hurricane Matthew. The 3 Permit Violations were due to excessive rainfall amounts, we exceeded our permitted flow limit at the WWTP in the months of January, February, and October. The 3 NOV's were as follows, sanitary sewer overflow, excessive flow at WWTP and WET test administered by the state Failure.

III. Notification:

A copy of this report can be obtained at the Parkton Town Hall.


IV. Certification

I certify under penalty of law that this report is complete and accurate to the best of my knowledge. I further certify that this report has been made available to the users or customers of the named system at Parkton Town Hall.



Timothy E. Little
ORC
Town of Parkton

2-28-17
Date



Al McMillan
Mayor
Town of Parkton

28 Feb 2017
Date

Public Notice

The North Carolina Clean Act of 1999 requires that each owner or operator of any wastewater treatment plant or wastewater collection system to provide an annual performance report to its users and customers.

The Town of Parkton owns its wastewater collections system and the wastewater treatment facility located at NCSR 1724 Southeast of Parkton in Robeson County. A copy of the Town's 2016 performance report can be obtained at the Parkton Town Office, located at 28 West David Parnell St.

The report will show that during 2016, the Town of Parkton had 0 monitoring or reporting violations, 4 permit violations, and 11 sanitary sewer over flow.

The public is invited to pick up a copy of this report, or if there are any questions surrounding this 2016 report, to contact the Parkton Town Hall at (910) 858-3360.