



9/4/2020

Work Order: 20H1554
Project: [none]


Dixie Deer S.S.D.
Attn: Wayne Gudgell
316 North Lodge Road
Central, UT 84722

Client Service Contact: 801.262.7299

The analyses presented on this report were performed in accordance with the National Environmental Laboratory Accreditation Program (NELAP) unless noted in the comments, flags, or case narrative. If the report is to be used for regulatory compliance, it should be presented in its entirety, and not be altered.



Approved By:



Dave Gayer, Laboratory Director



CHEMTECH-FORD
LABORATORIES

Certificate of Analysis

Lab Sample No.: 20H1554-01

Name: Dixie Deer S.S.D.

Sample Date: 8/25/2020 9:10 AM

Sample Site: 102 W Frontier

Receipt Date: 8/26/2020 1:00 PM

Comments:

Sampler: Wayne Gudgell

Sample Matrix: Drinking Water

Project:

PO Number:

System No.: UTAH27003

Source Code: DS001

Sample Point: MR001

Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Regulated Haloacetic Acids (HAAs)								
Dibromoacetic Acid	1.0		1.0	ug/L	EPA 552.2	08/27/2020	08/28/2020	
Dichloroacetic Acid	ND		1.0	ug/L	EPA 552.2	08/27/2020	08/28/2020	
Monobromoacetic Acid	ND		1.0	ug/L	EPA 552.2	08/27/2020	08/28/2020	
Monochloroacetic Acid	ND		2.0	ug/L	EPA 552.2	08/27/2020	08/28/2020	
Trichloroacetic Acid	ND		1.0	ug/L	EPA 552.2	08/27/2020	08/28/2020	
Total Haloacetic Acids	ND	60	2.0	ug/L	EPA 552.2	08/27/2020	08/28/2020	
Trihalomethanes (THMs)								
Bromodichloromethane	ND		0.5	ug/L	EPA 524.2	08/28/2020	08/28/2020	
Bromoform	1.2		0.5	ug/L	EPA 524.2	08/28/2020	08/28/2020	
Chloroform	ND		0.5	ug/L	EPA 524.2	08/28/2020	08/28/2020	
Dibromochloromethane	ND		0.5	ug/L	EPA 524.2	08/28/2020	08/28/2020	
Total Trihalomethanes	1.2	80	0.5	ug/L	EPA 524.2	08/28/2020	08/28/2020	



CHEMTECH-FORD
LABORATORIES

Certificate of Analysis

Report Footnotes

Abbreviations

ND = Not detected at the corresponding Minimum Reporting Limit.

1 mg/L = one milligram per liter or 1 mg/Kg = one milligram per kilogram = 1 part per million.

1 ug/L = one microgram per liter or 1 ug/Kg = one microgram per kilogram = 1 part per billion.

1 ng/L = one nanogram per liter or 1 ng/Kg = one nanogram per kilogram = 1 part per trillion.

Data Comparisons

Values reported in **RED** exceed Primary Drinking Water standards.

Values reported in **BLUE** exceed Secondary Drinking Water standards.

BLANK values in the MCL column indicate no standard.