

Annual Drinking Water Quality Report for City of Vienna #IL0870350

VIENNA

IL0870350

Annual Water Quality Report for the period of January 1 to December 31, 2016

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The source of drinking water used by VIENNA is Surface Water

For more information regarding this report contact:

Name Herb Hosfeldt Or Dale Leggett

Phone 618-658-3821

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

| Source of Drinking Water | |
|--|--|
| <p>The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.</p> | <p>Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.</p> <p>In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.</p> <p>Some people may be more vulnerable to contaminants in drinking water than the general population.</p> |
| <p>Contaminants that may be present in source water include:</p> <ul style="list-style-type: none"> - Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. - Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming. - Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses. - Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems. - Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities. | <p>Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).</p> <p>If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.</p> |

Source Water Information

| Source Water Name | Type of Water | Report Status | Location |
|--|---------------|---------------|--|
| CC10-MASTER METER FROM MILLSTONE WDFP IL1515050 TP04 | GW | <u>ACTIVE</u> | IN THE VIENNA CITY LIMITS ON THE EAST SIDE |
| IN70810 - BLOOMFIELD LAKE 3.5MI NE VIENNA | SW | <u>ACTIVE</u> | 3.5 MILES NE OF VIENNA |
| IN70811 - SIDE CHANNEL RESERVOIR | SW | <u>ACTIVE</u> | NE EDGE OF VIENNA |

Source Water Assessment

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. City council meeting are scheduled the first and third Wednesday's of the month at Vienna City Hall. City hall's address is 205 North 4th Street, in Vienna, Illinois. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by City Hall or call our water operator at 618-658-3821. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

The city of vienna has (2) RAW water sources. Drinking water for the City of Vienna, Illinois (Facility No. 0870350) is supplied by the Vienna community water supply (CWS). Bloomfield Lake and the Vienna Reservoir act as the source of this drinking water. Source of Water: VIENNA Illinois EPA considers all surface water sources of community water supply to be susceptible to potential pollution problems. Hence, the reason for mandatory treatment for all surface water supplies in Illinois. Mandatory treatment includes coagulation, sedimentation, filtration, and disinfection. Causes of pollution to the lake include nutrients, siltation, suspended solids, and organic enrichment. Primary sources of pollution include agricultural runoff, land disposal (septic systems), and shoreline erosion.

Water Quality Test Results

| | |
|--|--|
| Definitions: | The following tables contain scientific terms and measures, some of which may require explanation. |
| Avg: | Regulatory compliance with some MCLs are based on running annual average of monthly samples. |
| Level 1 Assessment: | A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system. |
| Level 2 Assessment: | A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions. |
| Maximum Contaminant Level or MCL: | The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. |
| Maximum Contaminant Level Goal or MCLG: | The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. |
| Maximum residual disinfectant level or MRDL: | The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants. |
| Maximum residual disinfectant level goal or MRDLG: | The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants. |
| na: | not applicable. |
| mrem: | millirems per year (a measure of radiation absorbed by the body) |
| ppb: | micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water. |
| ppm: | milligrams per liter or parts per million - or one ounce in 7,350 gallons of water. |
| Treatment Technique or TT: | A required process intended to reduce the level of a contaminant in drinking water. |

Regulated Contaminants

| Disinfectants and Disinfection By-Products | Collection Date | Highest Level Detected | Range of Levels Detected | MCLG | MCL | Units | Violation | Likely Source of Contamination |
|--|--------------------|---------------------------|-----------------------------|--------------------------|----------|-------|-----------|--|
| Chlorine | 12/31/2016 | 1.7 | 1 - 2 | MRDLG = 4 | MRDL = 4 | ppm | N | Water additive used to control microbes. |
| Chlorite | 2016 | 0.84 | 0.59 - 0.84 | 0.8 | 1 | ppm | N | By-product of drinking water disinfection. |
| Haloacetic Acids (HAA5) | 2016 | 9 | 6.4 - 11.6 | No goal for the total | 60 | ppb | N | By-product of drinking water disinfection. |
| Total Trihalomethanes (TTHM) | 2016 | 2 | 1.1 - 2.1 | No goal for the total | 80 | ppb | N | By-product of drinking water disinfection. |
| Inorganic Contaminants | Collection Date | Highest Level Detected | Range of Levels Detected | MCLG | MCL | Units | Violation | Likely Source of Contamination |
| Barium | 2016 | 0.0218 | 0.0218 - 0.0218 | 2 | 2 | ppm | N | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits. |
| Fluoride | 2016 | 0.9 | 0.914 - 0.914 | 4 | 4.0 | ppm | N | Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories. |
| Sodium | 2016 | 12 | 11900 - 11900 | | | ppm | N | Erosion from naturally occurring deposits; Used in water softener regeneration. |
| Radioactive Contaminants | Collection Date | Highest Level Detected | Range of Levels Detected | MCLG | MCL | Units | Violation | Likely Source of Contamination |
| Combined Radium 226/228 | 01/06/2015 | 0.915 | 0.915 - 0.915 | 0 | 5 | pCi/L | N | Erosion of natural deposits. |

Gross alpha excluding 01/06/2015 0.287 0.287 - 0.287 0 15 pCi/L N Erosion of natural deposits.
radon and uranium

Turbidity

| | Limit (Treatment Technique) | Level Detected | Violation | Likely Source of Contamination |
|--------------------------------|--------------------------------|----------------|-----------|--------------------------------|
| Highest single measurement | 1 NTU | 0.28 NTU | N | Soil runoff. |
| Lowest monthly % meeting limit | 0.3 NTU | 100% | N | Soil runoff. |

Information Statement: Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of Water quality and the effectiveness of our filtration system and disinfectants.

Total Organic Carbon

The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set, unless a TOC violation is noted in the violations section.

The City of Vienna also has an Emergency connection to Millstone Water District, Facility # IL1515050. This connection is kept active to insure the pressure reducer and master meter works when needed. The city of Vienna uses Millstone Water on a limited basis, but does occasionally feed some of Vienna customers Millstone water. Because of that use we have included Millstone Water District's regulated contaminants table at the end of this CCR report, so customers can be aware of Millstones water quality. This section is Label Millstone.

Annual Drinking Water Quality Report

MILLSTONE PWD

IL1515050

Annual Water Quality Report for the period of January 1 to December 31, 2016

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The source of drinking water used by

MILLSTONE PWD is Ground Water

For more information regarding this report contact:

Name Norman Cubley

Phone 618-285-6201

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

Source of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Source Water Information

| Source Water Name | Type of Water | Report Status | Location |
|-------------------|--------------------------------|---------------|----------|
| WELL 5 (00757) | GW | <u>active</u> | _____ |
| WELL 6 (01016) | 1MI N OF BIG BAY W OF RR GW | <u>active</u> | _____ |

Source Water Assessment

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by City Hall or call our water operator at 618-285-6201. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

Source of Water: MILLSTONE PWD To determine Millstone PWD's susceptibility to groundwater contamination, a Well Site Survey, published in 1994 by the Illinois EPA, was reviewed. Based on information obtained in this document, one potential source of groundwater contamination is present that could pose a hazard to the groundwater pumped by the Millstone PWD community water supply wells. This site is a lime sludge lagoon located 50 feet from Well #5. Based on information provided by Millstone PWD's water supply officials, this lime sludge lagoon has changed its status (sludge removed) and the four wells listed in the above site data table have been properly abandoned. The community's source water is susceptible to SOC contamination from non-point sources related to agricultural land use. Also, as a result of monitoring conducted at the wells and entry point to the distribution system, the land-use activities, and a source water protection initiatives by the facility, the Millstone PWD's source water is not susceptible to VOC and IOC contamination. Furthermore, in anticipation of the U.S. EPA's proposed Ground Water Rule, the Illinois EPA has determined that the Millstone PWD's wells are not vulnerable to viral contamination. This determination is based on the evaluation of the following criteria considered during the Vulnerability Waiver Process: the community's wells are properly constructed with sound integrity and proper site conditions; all potential routes and sanitary defects have been mitigated such that the source water is adequately protected; monitoring data did not indicate a history of disease outbreak; and the sanitary survey of the water supply did not indicate viral contamination threat. However, having stated this, the "[U.S.] EPA is proposing to require States to identify systems in karst, gravel, and fractured rock aquifer systems as sensitive and these systems must perform routine source water monitoring". Because the community's wells are open to an unconfined sand and gravel aquifer, the Illinois EPA evaluated the well hydraulics associated with the Millstone PWD's well field. The amount of overburden should provide an adequate degree of filtration to prevent the movement of pathogens into the wells.

Water Quality Test Results

| | |
|--|--|
| Definitions: | The following tables contain scientific terms and measures, some of which may require explanation. |
| Avg: | Regulatory compliance with some MCLs are based on running annual average of monthly samples. |
| Level 1 Assessment: | A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system. |
| Level 2 Assessment: | A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions. |
| Maximum Contaminant Level or MCL: | The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. |
| Maximum Contaminant Level Goal or MCLG: | The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. |
| Maximum residual disinfectant level or MRDL: | The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants. |
| Maximum residual disinfectant level goal or MRDLG: | The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants. |
| na: | not applicable. |
| mrem: | millirems per year (a measure of radiation absorbed by the body) |
| ppb: | micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water. |
| ppm: | milligrams per liter or parts per million - or one ounce in 7,350 gallons of water. |
| Treatment Technique or TT: | A required process intended to reduce the level of a contaminant in drinking water. |

Regulated Contaminants

| Disinfectants and Disinfection By-Products | Collection Date | Highest Level Detected | Range of Levels Detected | MCLG | MCL | Units | Violation | Likely Source of Contamination |
|--|-----------------|------------------------|--------------------------|-----------------------|----------|-------|-----------|--|
| Chlorine | 12/31/2016 | 1.5 | 1 - 2 | MRDLG = 4 | MRDL = 4 | ppm | N | Water additive used to control microbes. |
| Haloacetic Acids (HAA5) | 2016 | 22 | 11.3 - 39 | No goal for the total | 60 | ppb | N | By-product of drinking water disinfection. |
| Total Trihalomethanes (TTHM) | 2016 | 73 | 53.7 - 83.9 | No goal for the total | 80 | ppb | N | By-product of drinking water disinfection. |
| Inorganic Contaminants | Collection Date | Highest Level Detected | Range of Levels Detected | MCLG | MCL | Units | Violation | Likely Source of Contamination |
| Arsenic | 07/22/2015 | 3.46 | 3.46 - 3.46 | 0 | 10 | ppb | N | Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes. |
| Barium | 07/22/2015 | 0.0262 | 0.0262 - 0.0262 | 2 | 2 | ppm | N | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits. |
| Fluoride | 07/22/2015 | 0.825 | 0.825 - 0.825 | 4 | 4.0 | ppm | N | Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories. |
| Sodium | 07/22/2015 | 9.25 | 9.25 - 9.25 | | | ppm | N | Erosion from naturally occurring deposits; Used in water softener regeneration. |
| Radioactive Contaminants | Collection Date | Highest Level Detected | Range of Levels Detected | MCLG | MCL | Units | Violation | Likely Source of Contamination |
| Gross alpha excluding radon and uranium | 04/01/2015 | 3.8 | 3.8 - 3.8 | 0 | 15 | pCi/L | N | Erosion of natural deposits. |