

IPGSM-COM

IP Internet and Digital Cellular Fire•Communicator

General

The IPGSM-COM is a compact alarm communicator panel. It connects to the primary and secondary communication ports of the Fire Alarm Control Panel's DACT. In the event of an off-normal condition, the panel sends contact ID formatted information to the IPGSM-COM communicator panel. The IPGSM-COM then reformats the data into highly encrypted Ethernet packets for transmission to the AlarmNet receiver via customer-provided internet/intranet connection.

Alternative communication methods are critical in the marketplace due to VoIP (Voice over IP), migration from POTS ("plain old telephone service") and growth of digital radio networks. The IPGSM-COM delivers secure, reliable and complementary Internet and digital communications via the GSM (Global System for Mobile) network. Our exclusive, Triple-Path Communications solution combines Internet service with GSM for added reliability and an extra level of security. The GSM radio technology is unique in that it uses GPRS service (General Packet Radio Service) for data and alarm communications and automatically switches to SMS (Short Message Service) for alarms if GPRS is unavailable. Through the Internet or GSM radio, the IPGSM-COM offers contact ID reporting with any Fire Alarm Control Panels.

All signals from the IPGSM-COM communicator panel are delivered to Honeywell's AlarmNet Network Control Center, which routes the information to the appropriate central station. The state of the art AlarmNet Network Control Center is fully redundant and monitored 24/7. AlarmNet has the ability to route messages using AlarmNet-i and 800 PLUS services, providing true redundancy and multi-path message delivery.

Features

- Saves the cost of two dedicated phone lines. Only the customer's shared IP equipment is required.
- Triple path communications: Uses Internet as primary with dual GSM technology as back-up. GSM path utilizes GPRS and automatically switches to SMS if GPRS is unavailable.
- Requires no change to the existing Fire Alarm Control Panel configuration. The IPGSM-COM connects directly to the primary and secondary telephone ports.
- Works over any type of customer provided Ethernet 10/100Base network connection (LAN or WAN), DSL modem or cable modem.
- Data transmits over standard contact-ID protocol but is secured with the industry's advanced encryption standard (AES 256 bit).
- Supports both dynamic (DHCP) or Public and Private Static IP addressing.
- Built-In Power Supply module: On board charging circuit design accommodates back-up battery. Includes primary power and battery supervision.
- Diagnostic LEDs: Signal strength and status indications.
- Reliable connection: IP and GSM tested everyday
- QOS: Quality of Service diagnostics via AlarmNet supply vital information including when message was received, battery voltage, input voltage, signal strength, and message path.
- Web-Based Programming or Handheld programmer for setup.



Operation

When an event occurs, the Fire Alarm Control Panel goes off-hook to dial the central station. The IPGSM-COM Dialer Capture Module detects the off-hook condition and provides the fire panel with a dial tone. When the fire panel detects the dial tone, it begins dialing the central station. The Dialer Capture Module considers the three second period after dialing as the number dialing has been completed. After the dialing is completed, the Dialer Capture Module returns a handshake to the fire panel. The fire panel then sends the contact ID reports to the Dialer Capture Module, which in turn sends a kiss-off after the report is successfully received from the fire panel. The Dialer Capture Module sends the contact ID reports over the ECP bus to the iGSM communications module. When all the reports are sent, the fire panel goes on-hook. The iGSM communications module then transmits the messages to the central station (either over the internet (primary) or the GSM network).

Easy to Program

There are two ways to configure the IPGSM-COM communicator panel:

1. Handheld programmer 7720P
2. Web-Based Programming - Allows complete interactive programming from AlarmNet Direct.
<https://services.alarmnet.com/AlarmNetDirect>

The IPGSM-COM Communicator can be pre-programmed. Use the 7720P programmer or the Web-Based Program to enter all central-station information. This is saved to the IPGSM-COM communicator panel memory. When the IPGSM-COM Communicator is installed at the site and connected to the Internet/Intranet, it registers itself with the AlarmNet receiver. This eliminates the need for a PC at the remote site for programming.

For most installations, the only required parameters are:

- Primary City ID (two digits) obtained from your monitoring station.
- Primary Central Station ID (two digits) obtained from your monitoring station.
- Primary Subscriber ID (four digits) obtained from your monitoring station.
- Communication Module's MAC ID, and MAC CRC number located on outside of box, and inside of the module.

All of these parameters are assigned by the monitoring station.

See *IPGSM-COM Installation and Setup Guide* for full details. NOTE: Some assembly is required.

Panel Capabilities

The IPGSM-COM communicator panel is compatible with fire panels that use the Contact ID communications format as described in the SIA DC-05 standard.

AlarmNet

Honeywell's AlarmNet has been the nationwide leader in alarm communications technology since 1986. A reliable alternative for the transmission of alarm signals, our radio network provides extensive coverage in the United States and Canada.

AlarmNet Network Control center processes signals from powerful servers in multiple locations equipped with 24/7 infrastructure support. The AlarmNet network consist of redundant hardware servers, hot back-up databases and generators with battery back-up at all locations to ensure continuity of service. Signals from AlarmNet are transmitted to the central station's receivers using multiple communications paths consisting of the Internet, radio network or toll-free POTS service.

Installation Requirements

UL COMPLIANCE

To meet UL864/NFPA compliance, ensure the following:

- IPGSM-COM must be mounted within the same room and within 20 feet of host Fire Alarm Control Panel sounder, or other remote sounder.
- IPGSM-COM must be powered from the same un-switched facility power source branch as the host Fire Alarm Control Panel.
- IPGSM-COM must use the 7AH battery to provide 24-hour backup capability.

Electrical Specifications

- **Transformer:**
 - Primary: 120 VAC, 60 Hz, 0.50 A.
 - Secondary: 18VDC, 50 VA.
- **Current Requirements:**
 - PowerBoost1 power supply: 90mA Standby, 90 mA Active
 - iGSM Communications Module: 80mA Standby, 500mA Active (peak during transmission)
 - Dialer Capture Module: 40mA Standby, 85mA Active
 - LED Display board: 10mA Standby, 10mA Active
 - TOTAL: 220mA Standby, 685mA Active
- **Battery:** One 12 V 7.0 AH lead-acid battery (not supplied). (IPGSM-COM cabinet holds one 7.0 AH battery.)

Cabinet Specifications

- **Dimensions:** 14.875" H x 12.75" W x 3.0" D (37.8 cm H x 32.4 cm W x 7.6 cm D)
- **Color:** Red

Shipping Specifications

- **Weight:** 5.3 lbs. (6.94 kg)
- **Dimensions:** 15.625" H x 13.79" W x 9.25" D (39.7 cm H x 34.9 cm W x 23.9 cm D)

Temperature and Humidity Ranges

This system meets NFPA requirements for operation at 0 – 49°C/32 – 120°F and at a relative humidity 93% ± 2% RH (non-condensing) at 32°C ± 2°C (90°F ± 3°F). However, the useful life of the system's standby batteries and the electronic components may be adversely affected by extreme temperature ranges and humidity. Therefore, it is recommended that this system and its peripherals be installed in an environment with a normal room temperature of 15 – 27°C/60 – 80°F.

Product Line Information

IPGSM-COM: Internet and Digital Cellular Fire Communicator Panel. Includes red cabinet with key, wall outlet box, Dialer Capture Module, iGSM Communications Module, antenna and mounting adapter, PowerBoost1 power supply, LED display board, transformer, manual, and required screws, cables, etc.

GSM-ANT3DB: 3db gain external/remote antenna

7626-50HC: 50 ft. antenna cable, low loss

7626-25HC: 25 ft. antenna cable, low loss

WA7626-CA: SNA to N Adapter

7720P: IPGSM-COM handheld programmer

HPTCOVER: Plug in transformer box for IPGSM communicator

BAT-1270: Battery 12 Volts, 7 AH, sealed

Agency Listings and Approvals

The listings and approvals below apply to the basic **IPGSM-COM** communicator panel. In some cases, certain modules may not be listed by certain approval agencies, or listing may be in process. Consult factory for latest listing status.

- **UL:** S789
- **CSFM:** 7300-1645:0183

This document is not intended to be used for installation purposes. We try to keep our product information up-to-date and accurate. We cannot cover all specific applications or anticipate all requirements. All specifications are subject to change without notice.
©2011 by Honeywell International Inc. All rights reserved. Unauthorized use of this document is strictly prohibited.

Automation and Control Solutions

Honeywell

12 Clintonville Road
Northford, CT 06472-1610
www.honeywellpower.com

1(877) HPP-POWER
hpp_techserv@honeywell.com

DH-60661:B1 • ECN 11-0070
February 2011
© U.S. Registered Trademark
© 2011 Honeywell International Inc.
Page 2 of 2



Honeywell

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-1645:0199 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: HONEYWELL SECURITY2 Corporate Center Dr, Ste. 100, Melville, NY 11747
Contact: Issa Khouryawad (516) 577-2312 Fax (516) 577-3540
Email: issa.khouryawad@Honeywell.com

DESIGN: Models iPGSM-COM, iPGSM-DP, iPGSM-4G and *IGSMCFP4G Internet and Digital Cellular Fire Communicators. Units are suitable for residential and commercial applications. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as a control unit accessory for use with separately listed compatible commercial and residential fire alarm control units. *Model IGSMCFP4G is intended for use with specific Honeywell Security control units that employ the ECP bus. Refer to listee's installation Instruction Manual for details.

NOTE: Burglary and other non-fire functions were not examined.

iPGSM-COM, iPGSM-DP formerly listed in 7300-1645:0183.

*Rev 07-01-14 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2016**

Listing Expires **June 30, 2017**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division