

ENVIROTECH LABORATORIES, INC.
MA CERT. NO.: M-MA 063

8 Jan Sebastian Drive
 Sandwich, MA 02563
 (508)888-6460 1-800-339-6460
 FAX (508)888-6446

Monday, July 18, 2011

Plymouth Environmental Management
 Kim Michaelis
 11 Lincoln St. Plymouth

ProjectName: Herring Pond Emergency Test **Comments:**
Project Number: NA
Collection Date: 7/14/11 **Collection Time:** NA
Sampled By: EB VomGoebler
Lab Order Number: WW-111631
Date Received: 07/14/11

Sample Type	Sample Time	Sample Date	Comments			
GH1 A	11:49	7/14/11	Grab 8:30			
Parameters	Units	Test Results	Reportable Limits	Date Analyzed	Analyst	Method
pH	pH units	6.99	NA	07/14/11	LL	4500 H-B
Total Nitrogen	mg/L	< 0.2	NA	07/15/11	MC	Calculation
Total Phosphorous (P)	mg/L	0.080	0.013	07/15/11	MC	4500-P
E-coli	/100 ml	110	0/100 ml	07/14/11	RS	9213 D
Specific Conductance	uhoms/cm	80	10	07/14/11	LL	120.1
Nitrate-N	mg/L	BRL	0.01	07/14/11	LL	300.0
Nitrite-N	mg/L	BRL	0.004	07/14/11	LL	300.0
Total Kjeldhal Nitrogen	mg/L	BRL	0.2	07/18/11	MC	SM4500 NH3 C
Turbidity	NTU	2.2	1.0	07/14/11	LL	2130 B
Sample Type	Sample Time	Sample Date	Comments			
GH 13 B	12:33	7/14/11				
Parameters	Units	Test Results	Reportable Limits	Date Analyzed	Analyst	Method
pH	pH units	7.29	NA	07/14/11	LL	4500 H-B
Total Nitrogen	mg/L	0.21	NA	07/18/11	MC	Calculation
Total Phosphorous (P)	mg/L	0.45	0.013	07/15/11	MC	4500-P
E-coli	/100 ml	20	0/100 ml	07/14/11	RS	9213 D
Specific Conductance	uhoms/cm	80	10	07/14/11	LL	120.1
Nitrate-N	mg/L	BRL	0.01	07/14/11	LL	300.0
Nitrite-N	mg/L	BRL	0.004	07/14/11	LL	300.0
Total Kjeldhal Nitrogen	mg/L	0.21	0.2	07/18/11	MC	SM4500 NH3 C
Turbidity	NTU	1.0	1.0	07/14/11	LL	2130 B

BRL=below reportable limits

*see attached

By: _____
Ronald J. Saari
 Laboratory Director