



Eastern Interconnection Planning Collaborative

---

# Gas-Electric System Interface Study Summary

May 28, 2015

**LEVITAN & ASSOCIATES, INC.**  
MARKET DESIGN, ECONOMICS AND POWER SYSTEMS

# Acknowledgement and Disclaimer

## The EIPC appreciates and acknowledges the support of DOE for the Eastern Interconnection Studies Project

### Acknowledgement:

- ◆ This material is based upon work supported by the Department of Energy, National Energy Technology Laboratory, under Award Number DE-OE0000343.

### Disclaimers:

- ◆ This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

# Overview

---

- ◆ Highlights
- ◆ Study Region
- ◆ Adequacy Analysis
- ◆ Hydraulic Analysis
- ◆ Dual-Fuel Analysis
- ◆ Appendix


# Study Highlights

- ◆ Character of service: Most generators do not hold firm transportation entitlements, except in TVA and Ontario
- ◆ Gas infrastructure adequacy analysis: Constraints affect generation in ISO-NE, NYISO, EMAAC and SWMAAC
- ◆ Contingency analysis: Most gas contingencies allow time for PPAs to schedule alternative resources
- ◆ Fuel assurance: Dual-fuel capability less expensive than incremental FT in almost all cases


# Study Overview – Four Targets

- ◆ Target 1: Develop baseline assessment of natural gas-electric system interfaces, interaction effects, and the current level of coordination between the electric and gas systems
- ◆ Target 2: Evaluate capability of the natural gas systems to supply the electric power sector fuel requirements over a five and ten year study horizon while serving higher priority firm shippers
- ◆ Target 3: Identify contingencies on the natural gas & electric systems that could adversely affect electric system reliability
- ◆ Target 4: Review operational / planning issues related to dual fuel capability, including the net benefits of fuel assurance alternatives

# PPAs and Study Region Pipelines



# Model Framework




# Constraint Identification Approach

- ◆ Develop electric system chronological dispatch model for 2018 and 2023 to estimate hourly gas demands for each generator
- ◆ Combine forecasts of RCI and generator gas demand to represent seasonal coincident peak days
- ◆ Quantify unserved gas demand using optimization modeling of the gas infrastructure network for seasonal peak hours, and allocate the unserved demand to affected generators
- ◆ Quantify frequency and duration of pipeline constraints during seasonal daily peak hours
- ◆ Identify gas transportation constraints causing unserved peak hour demand
- ◆ Identify potential mitigation measures to reduce or eliminate transportation constraints affecting generation




# Constraints: Reference Demand Scenario Winter 2018




“Affected Generation” does not imply a risk to electric reliability

Peak Hour Unserved Generation Gas Demand: 165 MDth (27.6%)

Peak Hour Affected Generation: 21,707 MWh (26.8%)




# Constraints: High Demand Scenario Winter 2018




“Affected Generation” does not imply a risk to electric reliability

Peak Hour Unserved Generation Gas Demand: 351 MDth (29.4%)

Peak Hour Affected Generation: 45,269 MWh (29.3%)




# Constraints: Low Demand Scenario Winter 2018




“Affected Generation” does not imply a risk to electric reliability

Peak Hour Unserved Generation Gas Demand: 64 MDth (17.6%)

Peak Hour Affected Generation: 8,350 MWh (16.6%)







# Winter 2018: Affected Generation by Scenario




“Affected Generation” indicates the amount of energy for gas-fired generation that cannot be supplied due to the limitations of the pipeline system – which represents either full or partial scheduled requirements. Mitigation measures include switching to liquid fuel and/or redispatch.

# Affected Generation by Season





# Frequency-Duration Results Format




- Dominion Southeast
- Direct-Connect Generator
- LDC-Served Generator
- Downstream Pipeline-Served Generator
- Downstream Pipeline → LDC-Served Generator

Note: Frequency-Duration charts are examples, not for this specific segment



# Hydraulic Model Study Region Footprint




# Contingency Analysis Approach

- ◆ Emphasis is placed on the physical capability of the consolidated network of pipeline and storage infrastructure to maintain service to RCI and generation customers post-contingency
  - Pipeline contractual obligations are not modeled
  - Generator and RCI demands not differentiated, revealing the outer bound in terms of continued service to scheduled gas-fired generators
- ◆ Identify plants that trip off line due to delivery pressures below 485 psig, and the time interval between the contingency event and the pressure trigger
- ◆ Affected generation following a contingency is not tantamount to unserved electric energy since mitigation measures are available
- ◆ MISO South not hydraulically modeled due to its robust available capacity
- ◆ LDC assessments either included in hydraulic models or evaluated by LDC separately



# Baseline Hydraulic Results: 2018 RGDS



“Affected Generation” does not imply a risk to electric reliability

IESO is not included because it was not hydraulically modeled by LAI

- ◆ Baseline examines gas infrastructure adequacy to meet peak day demands under normal operating conditions
- ◆ Undeliverable generator volumes due to prioritization of RCI customer deliveries, delivery pressures below 485 psig

# Contingency Analysis Results



## ◆ Gas contingencies

- Types: line breaks, compressor outages, loss of supply, loss of storage
- Line breaks are the most impactful in each PPA

## ◆ Electric contingencies

- Types: outages of large non-gas generators, loss of large transmission lines
- Most severe contingencies are generator outages in PJM
  - Time before plants trip offline likely sufficient for PPA to take remedial action, *i.e.*, system redispatch

# Example Contingency Result Outputs




Plant	Time to Trip Following Contingency (h:m:s)	Scheduled Energy (MWh)	Undeliverable Energy (MWh)	Undeliverable Energy (%)
Plant 1	N/A	5,000	0	0
Plant 2*	3:30:00	2,500	2,200	88%
Plant 3	N/A	10,000	0	0
Plant 4*	N/A	15,000	0	0
Plant 5*	N/A	315	0	0
Plant 6	N/A	600	0	0
Plant 7	N/A	750	0	0
Plant 8	4:48:41	5,000	4,000	80%
Total			4,000 (gas only) 2,200 (dual fuel)	


# Contingency Results Summary by Type

## Reference Scenario, Winter 2018


### Gas-Side Contingencies



### Electric-Side Contingencies




# Individual Gas-Side Contingency Results



\* Scheduled energy with undeliverable gas

# Individual Electric-Side Contingency Results



\* Scheduled energy with undeliverable gas

# LDC Contingency Analysis Approach

- ◆ Evaluation at specific temperatures rather than peak day
  - On a peak day, interruptible service typically not available to generators
- ◆ Evaluation by LAI (Central Hudson Gas & Electric, New Jersey Natural Gas, Public Service Electric & Gas, Washington Gas Light)
  - LDCs provided hydraulic details of segments that serve generation
  - Segments added to regional hydraulic models
  - Results and assessment reviewed with LDCs
- ◆ Evaluation by LDC (Con Edison, National Grid, Baltimore Gas & Electric, Nicor Gas, Peoples Gas, Enbridge Gas, Union Gas)
  - LAI provided generator gas demands to LDCs
  - LDCs provided results to LAI
  - Assessment reviewed with LDCs

# Fuel Assurance Analysis Approach


- ◆ SC and CC configurations based on recently constructed and planned dual-fueled plants across the Study Region
  - Performance and operating characteristics from manufacturers
  - Cost estimates from turbine manufacturers, recent CONE studies, FERC filings
  - Dual-fuel capable plants incur higher fixed O&M costs
- ◆ Dual-fuel capability compared to incremental FT service for 27 locations
  - Dual-fuel cost inputs: labor cost factor, tax rates, permit restrictions, fuel source, delivery logistics
  - FT cost inputs: reservation charges for incremental capacity, avoided cost of non-firm transportation, # of days w/ interrupted non-firm service, LDC transportation costs (where appropriate)
  - Inputs differentiated between locations
- ◆ Costs expressed as an annual levelized cost per kW over a 20-year term beginning in 2018
  - Allows for relative comparison between different capacities and heat rates




# Fuel Assurance Analysis Results

- ◆ Cost of dual-fuel capability generally similar across locations
  - Variations between barge- and truck-supplied locations
- ◆ Cost of incremental FT varies across Study Region
  - Expensive in New England due to existing bottlenecks
  - Expensive at the local level (New York Facilities System, in particular)
- ◆ Dual-fuel capability typically much lower cost for a new combined-cycle (CC) plant than FT; far more pronounced for simple cycle (SC) plants
  - LDC-served generators additionally incur local facility improvement costs
  - Restrictive environmental permit requirements limit liquid fuel usage
  - Structural changes continue to improve ULSD replenishment logistics

# Fuel Assurance Analysis: Combined Cycle



# Fuel Assurance Analysis: Simple Cycle



# Gas-Electric Interface Attributes

	Criterion	IESO	ISO-NE	MISO	NYISO	PJM	TVA
Natural Gas Supply	Gas Supply Portfolio Diversity	Green	Red	Green	Green	Green	Yellow
	Pipeline Connectivity	Yellow	Red	Green	Green	Green	Yellow
	Conventional Storage Deliverability	Green	Red	Green	Yellow	Green	Yellow
	LNG Storage Capability	Yellow	Green	Yellow	Yellow	Yellow	Yellow
Electric-Gas Interface	Firm Transportation Entitlements	Green	Red	Yellow	Yellow	Yellow	Green
	Direct Pipeline Connectivity	Green	Green	Green	Yellow	Green	Green
Electric-Gas Tariff	Pipeline or LDC Penalties	Green	Red	Red	Red	Red	Red
	LDC Provision of Flexible Service	Green	Yellow	Yellow	Green	Green	Yellow
	Active Secondary Market	Red	Green	Green	Green	Green	Yellow

<b>Legend</b>	Favorable Relative to Other PPAs	Neutral	Unfavorable Relative to Other PPAs
---------------	----------------------------------	---------	------------------------------------

# Risk Factors and Market Dynamics

Market Dynamic and/or Risk Factor	IESO	ISO-NE	MISO North/Central	MISO South	NYISO	PJM	TVA
Transport Deficits	Green	Red	Green	Green	Red	Red	Green
New Pipeline Additions	Yellow	Red	Green	Yellow	Yellow	Green	Green
Proximity to Shale Gas	Yellow	Red	Green	Yellow	Yellow	Green	Yellow
Reversal-of-Flow	Green	Red	Green	Yellow	Green	Green	Green
Available Coal Output	Green	Yellow	Red	Yellow	Yellow	Red	Yellow
Nuclear Retirements	Red	Green	Green	Green	Yellow	Yellow	Green
LNG Import Constraints	Green	Red	Green	Green	Green	Yellow	Green
LNG Export Constraints	Green	Green	Green	Yellow	Green	Yellow	Green
Generator FT Entitlements	Green	Yellow	Yellow	Yellow	Yellow	Yellow	Green
Generator Reliance on Non-Firm Arrangements	Green	Red	Green	Green	Red	Red	Green
Dual Fuel Capability	Yellow	Green	Yellow	Yellow	Green	Yellow	Green
Renewables Penetration	Green	Yellow	Yellow	Green	Yellow	Yellow	Green

<b>Legend</b>	Negligible or no impact on affected generation	Low to moderate impact on affected generation	High impact on affected generation
---------------	--	---	------------------------------------