

College View Community Association

Water Quality Report - 2017

This year, as in the years past, your tap water met all US Environmental Protection Agency and Illinois Environmental Protection Agency drinking water health standards. Our system safeguards its groundwater supply and we are pleased to report that the community had **No Violations** of any contaminant level or of any other water quality standard in the previous year. This report summarizes the quality of water that we provided last year, including details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. College View Community Association provides you with this information because informed residents and neighbors are our best allies.

If you have any questions about this report or concerns about your water system please contact Carl Groth, President of College View Community Association at 1-815-838-9025. If you would like to learn more, you are welcome to attend any of our regularly scheduled meetings at the Miller Field House in College View Park on the third Tuesday of every month at 6:30 pm.

The College View subdivision is in Lockport Township, in the county of Will, state of Illinois, located one half mile from Rt. 53, north of Airport Road, and is supplied with water by community wells owned and operated by the College View Community Association, a not for profit organization. The water system consists of four shallow wells, three storage tanks, 9000 feet of water main, valves, and other related and necessary equipment needed for treatment, all located within our community. This system provides an adequate supply of water for the 190 homes in the community. In accordance with IEPA regulations, daily water samples are taken and measured for proper content of chlorine and fluoride. The association is responsible for maintenance of water mains and lines up to, but **Not** including the buffalo box, service line, and shut-off valve. **It is the responsibility of the homeowner to provide a service line shut-off valve that is operational and above ground level, so that in case of an emergency it may be turned off for repairs.**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, persons with HIV/AIDS, or other immune system disorders, some elderly, and infants can be particularly at risk for infections. These people should seek advice about drinking water from their healthcare providers. US EPA/CDC guidelines on appropriate means to lessen the risk of infections by cryptosporidium, and other microbiological contaminants are available from the US EPA Safe Drinking Water Hotline @ 1-800-426-4791.

If present, elevated levels of lead can cause serious health issues, especially for pregnant woman and children. Lead in drinking water is primarily from materials in components in home plumbing. We cannot control the materials used in your home plumbing. **There are no lead water mains or service lines in our community.** When your water has been unused for several hours you can minimize the potential for lead exposure by flushing your tap for a couple of minutes before using it for drinking or cooking. If you are concerned about lead in your water you may wish to have it tested. For more information, you can call the US EPA Safe Drinking Water Hotline @ 1-800-426-4791 or on-line internet @ <http://www.epa.gov/safewater/lead>.

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	12/31/2017	0.4	0.3 - 0.5	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Haloacetic Acids (HAAs)	2017	3	2.74 - 2.74	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2017	7	7.07 - 7.07	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	05/13/2015	0.022	0.022 - 0.022	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	05/13/2015	1.21	1.21 - 1.21	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Iron	05/13/2015	0.17	0.17 - 0.17		1.0	ppm	N	This contaminant is not currently regulated by the USEPA. However, the state regulates. Erosion of natural deposits.
Manganese	05/13/2015	14	14 - 14	150	150	ppb	N	This contaminant is not currently regulated by the USEPA. However, the state regulates. Erosion of natural deposits.
Nitrate [measured as Nitrogen]	2017	1	0.04 - 0.59	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Sodium	05/13/2015	14	14 - 14			ppm	N	Erosion from naturally occurring deposits. Used in water softener regeneration.
Zinc	05/13/2015	0.38	0.38 - 0.38	5	5	ppm	N	This contaminant is not currently regulated by the USEPA. However, the state regulates. Naturally occurring; discharge from metal
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	05/13/2015	1.29	1.073 - 1.29	0	5	pCi/L	N	Erosion of natural deposits.
Gross alpha excluding radon and uranium	05/13/2015	2.47	2.03 - 2.47	0	15	pCi/L	N	Erosion of natural deposits.

2017 Regulated Contaminants Detected

Lead and Copper

Definitions:

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	08/19/2016	1.3	1.3	0.17	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	08/19/2016	0	15	3.3	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Water Quality Test Results

Definitions:

The following tables contain scientific terms and measures, some of which may require explanation.

Avg:

Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment:

A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment:

A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL:

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG:

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL:

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG:

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

na:

not applicable.

mrem:

millirems per year (a measure of radiation absorbed by the body)

ppb:

micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

Source Water Assessment

College View Community Association wants to keep you informed about your water quality. If you would like more information, please attend our regularly scheduled monthly meetings at the Miller Field House in College View Park or call Carl Groth, President at 1-815-838-9025. The source water assessment for our supply has been completed by the IEPA. To view a summary version of the completed source water assessment including the importance of source water, susceptibility to contamination, determination and documentation/recommendation of source water protection efforts, you may access the IEPA web site at <http://www.epa.state.il.us/cgi-bin/wfp/swap-fact-sheets.pl>.

Source of Water

Based on information obtained in a well site survey published in 1992 by the IEPA, nine potential sources of possible problem sites were identified within the survey area of College View Subdivision wells. Furthermore, information provided by the Leaking Underground Storage Tank and Remedial Project Management sections of the IEPA indicated several additional sites with ongoing remediation that may be of concern. The IEPA has determined that the source water obtained from College View Subdivision wells #1, #2, & #3, is susceptible to contamination. This determination is based on a number of criteria including: monitoring conducted at the wells, monitoring conducted at the entry point to the distribution system, and the available hydrogeological data on the wells.