



(N) POLYMER SHAKE ROOF TILES BEARING UNDERWRITERS LABORATORIES INCORPORATED CLASS 'A' LABEL 0 / 30 # NON-PERFORATED ASPHALT SATURATED FELT MEETING REQUIREMENTS OF ASTM D 226 (SEE KEYNOTE) O / CDX APA-RATED PLYWD. ROOF SHEATHING O / (E) 2 x R.R. ALSO SEE KEY NOTES AND STRUCT. DRWG'S. FOR FRAMING / SHEATHING

(E) 2x4 FLAT LOOKOUT @ 24" O.C. NOTCH THRU END RAFTER (EXTENDS FROM BARGE RAFTER TO THE FIRST COMMON RAFTER AS SHOWN. ALSO SEE STRUCT.

CONT. 24 GA. G.I. EDGE FLASHING W/ DRIP (LAPS AS SHOWN PLACED OVER FELT ALONG RAKE)

(E) 2 x BARGE RAFTER (MATCH EXIST.)

(E) 1 x 6 T&G @ UNDERSIDE OF RAKE AS SHOWN (TYP.) TO MATCH EXISTING VERIFY IN FIELD

OVERHANG DIM. TO MATCH (E) VERIFY IN FIELD

TYP. (E) EXTERIOR CEMENT PLASTER O / METAL LATH O / 2-LAYERS OF GRADE 'D' BLDG. PAPER O / PLYWD. WALL SHEATHING WHERE OCCURS SEE STRUCT. DRWG'S.

2 x STUD WALL ASSEMBLY

SEE STRUCT. DRWG'S

SIMP A35 @ 24" O.C.

ICYNENE FOAM INSUL.

2 x CEILING JOIST REF. TO STRUCT. DRWG'S.

(E) DBL. 2X TOP PLATE

(E) GYP. B.D.W / TEXTURED FINISH AT CEILING & WALLS

(E) R-15 BATT INSULATION IN (N) WALLS W/ VAPOR BARRIER ON WARM SIDE OF EXT. WALLS TYP.

**TYP. RAKE DETAIL (AT FLAT CEILING)**