



Arkansas Department of Health

4815 West Markham Street • Little Rock, Arkansas 72205-3867 • Telephone 501-661-2000

Governor Asa Hutchinson

Nathaniel Smith, MD, MPH, Director and State Health Officer

Engineering Section, Slot 37
www.HealthyArkansas.gov/eng/

Telephone 501-661-2623

Fax 501-661-2032

After Hours Emergency 800-554-5738

July 30, 2018

System is in compliance
with MCLs and OELs

CITY OF WARD
WARD WATERWORKS
P.O. BOX 334
WARD AR 72176

RE: Stage 2 Disinfectants and Disinfection Byproducts Rule
Total Trihalomethanes and Haloacetic Acids (TTHM & HAA5) Analyses
PWS ID: 345

Dear Operator:

Attached are the results of the Stage 2 Total Trihalomethanes (TTHM) and Haloacetic Acids (HAA5) analyses of the water samples collected from your public water system during the third quarter, 2018. Also attached is a report summarizing compliance calculations and Operational Evaluation Levels (OELs) based on the results.

The Stage 2 Disinfectants and Disinfection Byproducts Rule establishes the Maximum Contaminant Levels (MCLs) to be 80 ppb for TTHM and 60 ppb for HAA5, as Locational Running Annual Averages (LRAAs) calculated quarterly at each monitoring site.

If an OEL exceeds 80 ppb or 60 ppb for TTHM or HAA5 respectively, the system must conduct an operational evaluation and submit a written report of the evaluation to the state no later than 90 days after the receipt of the analytical result that caused the exceedance. The written report must be made available to the public upon request. If a system is readily able to identify the cause of the OEL exceedance, it may request permission to limit the scope of the evaluation.

All TTHM and HAA5 LRAAs were within the allowable limits of the Primary Drinking Water Standards of the Safe Drinking Water Act, and no OELs were exceeded this monitoring period.

Federal law requires that the water system keep a copy of the analytical reports for a minimum of ten years. If you have any questions or need assistance, feel free to contact your district staff or me at 501-661-2623.

Sincerely,

Jack Wilson
Disinfection Byproducts Environmental Specialist
Engineering Section

AH:CA:GAG:JC:GS:jw

enclosures



Report of Sample Analysis

Organic Chemistry Laboratory
Arkansas Public Health Laboratory
201 South Monroe
Little Rock AR 72205

Program

Collection Report Number: 154953

PHE-SDWA

Bottle ID # 25-133

Date: July 04, 2018

Time: 10:00

By: Cary McManus

Receipt Information

Date: July 05, 2018

Received By: FGULLEY

Time: 10:39

Submitted By: Cary McManus

Site Information

Water System: Ward Waterworks

PWS#: 345

Sampling site: 307 Cross Street, Bacti Site 345B002

District: 4

Location Site Code: 345YD010

County: Lonoke

Sample Description

Profile: THMMS

Type: DIS

Category: PUB

Source: Well

Condition: N/A

Purpose: CMP

Sample Number: O18186015302

Analytical Method

524.2

"Measurement of Purgeable Organic Compounds in Water by Capillary Column Gas Chromatography/Mass Spectroscopy", 1995, U. S. EPA Environmental Monitoring Systems Laboratory, Cincinnati, Ohio 45268 (Revision 4.1)

Analytical Results

Regulated Analytes

Bromoform	<1.0	ug/L
Chloroform	55.0	ug/L
Dibromochloromethane	1.0	ug/L
Dichlorobromomethane	7.3	ug/L
Total Trihalomethanes	63.3	ug/L

Result reported may differ from the summation of the individual analytes due to rounding.

Sample Result Comments

Sample Comments:

Batch Run# 33538

Report Date: 07/11/2018

Extract Date: 07/06/18

Analysis Date: 6 Jul 2018 6:32 pm

BJ Jefferson, Chemist II

Dorothy Ferguson, Supervisor



Report of Sample Analysis

Organic Chemistry Laboratory
Arkansas Public Health Laboratory
201 South Monroe
Little Rock AR 72205

Program

PHE-SDWA

Collection Report Number: **154954**

Bottle ID # 25-132

Date: **July 04, 2018**

Time: **09:40**

By: **Cary McManus**

Receipt Information

Date: July 05, 2018

Received By: FGULLEY

Time: 10:39

Submitted By: Cary McManus

Site Information

Water System: Ward Waterworks

PWS#: 345

Sampling site: 161 Prairie Lane, Bacti Site 345B005

District: 4

Location Site Code: 345YD011

County: Lonoke

Sample Description

Profile: THMMS

Type: DIS

Category: PUB

Source: Well

Condition: N/A

Purpose: CMP

Sample Number: **018186015202**

Analytical Method

524.2

"Measurement of Purgeable Organic Compounds in Water by Capillary Column Gas Chromatography/Mass Spectroscopy", 1995, U. S. EPA Environmental Monitoring Systems Laboratory, Cincinnati, Ohio 45268 (Revision 4.1)

Analytical Results

Regulated Analytes

Bromoform	<1.0	ug/L
Chloroform	57.3	ug/L
Dibromochloromethane	<1.0	ug/L
Dichlorobromomethane	7.0	ug/L
Total Trihalomethanes	64.3	ug/L

RECEIVED BY: [Signature]

JUL 13 2018

AR Dept of Health

Result reported may differ from the summation of the individual analytes due to rounding.

Sample Result Comments

Sample Comments:

Batch Run# 33538

Report Date: 07/11/2018

Extract Date: 07/06/18


Analysis Date: 6 Jul 2018 7:03 pm

BJ Jefferson

Dorothy M. Ferguson

BJ Jefferson, Chemist II

Dorothy Ferguson, Supervisor



Report of Sample Analysis

Organic Chemistry Laboratory
Arkansas Public Health Laboratory
201 South Monroe
Little Rock AR 72205

Program

Collection Report Number: 154953

PHE-SDWA

Bottle ID # 27-699

Date: July 04, 2018

Time: 10:00

By: Cary McManus

Receipt Information

Date: July 05, 2018

Received By: FGULLEY

Time: 10:39

Submitted By: Cary McManus

Site Information

Water System: Ward Waterworks

PWS#: 345

Sampling site: 307 Cross Street, Bacti Site 345B002

District: 4

Location Site Code: 345YD010

County: Lonoke

Sample Description

Profile:HAA

Type:DIS

Category: PUB

Source:Well

Condition:N/A

Purpose:CMP

Sample Number: O18186015301

Analytical Method

552.2

"Determination of Haloacetic Acids and Dalapon by Liquid-Liquid Extraction, Derivatization, and Gas Chromatography with Electron Capture Detection", 1995, U.S. EPA Environmental Monitoring Systems, Cincinnati, Ohio 45268 (Revision 1.0)

Analytical Results

Regulated Analytes

DBAA	<1.0	ug/L
DCAA	14.2	ug/L
MBAA	<1.0	ug/L
MCAA	2.6	ug/L
TCAA	9.9	ug/L
Total HAA	26.7	ug/L

Result reported may differ from the summation of the individual analytes due to rounding.

Unregulated Analytes

BCAA	2.1	ug/L
------	-----	------

Sample Result Comments

Sample Comments:

Batch Run# 33546

Report Date: 07/24/2018

Extract Date: 07/14/18

Analysis Date: 7/16/2018

2:15:09 AM

Jimmy Threet, Chemist I

Dorothy Ferguson, Supervisor



Report of Sample Analysis

Organic Chemistry Laboratory
Arkansas Public Health Laboratory
201 South Monroe
Little Rock AR 72205

Program

Collection Report Number: 154954

PHE-SDWA

Bottle ID # 27-696

Date: July 04, 2018

Time: 09:40

By: Cary McManus

Receipt Information

Date: July 05, 2018

Received By: FGULLEY

Time: 10:39

Submitted By: Cary McManus

Site Information

Water System: Ward Waterworks

PWS#: 345

Sampling site: 161 Prairie Lane, Bacti Site 345B005

District: 4

Location Site Code: 345YD011

County: Lonoke

Sample Description

Profile:HAA

Type:DIS

Category: PUB

Source:Well

Condition:N/A

Purpose:CMP

Sample Number: O18186015201

Analytical Method

552.2

"Determination of Haloacetic Acids and Dalapon by Liquid-Liquid Extraction, Derivatization, and Gas Chromatography with Electron Capture Detection", 1995, U.S. EPA Environmental Monitoring Systems, Cincinnati, Ohio 45268 (Revision 1.0)

Analytical Results

Regulated Analytes

DBAA	<1.0	ug/L
DCAA	14.5	ug/L
MBAA	<1.0	ug/L
MCAA	2.6	ug/L
TCAA	9.7	ug/L
Total HAA	26.9	ug/L

Result reported may differ from the summation of the individual analytes due to rounding.

Unregulated Analytes

BCAA	2.0	ug/L
------	-----	------

Sample Result Comments

Sample Comments:

Batch Run# 33546

Report Date: 07/24/2018

Extract Date: 07/14/18

Analysis Date: 7/16/2018

2:57:43 AM

Jimmy Threet, Chemist I

Dorothy Ferguson, Supervisor

Stage 2 D/DBPR

TTHM/HAA5 LRAA and OEL Calculations Report

PWS ID: 345

PWS Name: Ward Waterworks

3rd Quarter, 2018

Status: Reduced

Frequency: Every 90 Days

Pop: 11635

Number of Sites: 2

Frequency Approved: 1/23/2018

Sample Site	Analyte	Jan, Feb, Mar	Apr, May, Jun	Jul, Aug, Sep	Oct, Nov, Dec	OEL	LRAA
345YD008	TTHM	14.5	27.1		36.4		
345YD009	TTHM	11.4	23.2		33.7		
345YD010	TTHM	15.4	29.7	63.3	39.7	43	37
345YD011	TTHM	15.9	32.4	64.3	42.7	44	39
345YD008	HAA	10.8	16.4		16		
345YD009	HAA	8.8	16.9		14.3		
345YD010	HAA	10.9	13.5	26.7	15.7	19	17
345YD011	HAA	11.1	16.4	26.9	13.1	20	17