

## Access Control System Questions/Answers

1. **Question:** During the site visit, it was stated that there will be no internet in 16 of the 19 buildings needing access control & that RHA would not be interested in any recurring expenses. Can an exception be granted if the access control platform offers cellular communication/hosted services that will remove the need for internet in the buildings? **Response: NO**
2. **Question:** Will wireless locks be acceptable to avoid the need to run wire/power throughout the buildings? **Response: NO**
3. **Question:** Please confirm quantities – Per observations during site survey we have: 28 total “reader only ”doors & 18 total intercom/reader doors (broken down below)

**Wellsweep Circle Community/Office Building** – 8 doors with reader only access control

**Main Campus Apartment Buildings at Wellsweep Circle** - (14) Intercom/readers at front doors that can call to the 4 units in each of the 2 story buildings for remote entry & (14) back doors with reader- only

**Remote Sites at Magic Ave/Felker** - (4) Intercom/readers at front doors that can call to the 4 units in each of the 2 story buildings & (6) Reader- only doors- rear doors and laundry room. **Response: These quantities are correct.**

4. **Question:** What type of credential/format does RHA require for the readers – Card, fob,etc. Also, assuming **not** 125KHZ (easily duplicatable) **Response: Fob, not 125KHZ.**

5. **Question:** Can a vendor submit more than one bid? (Enabling a vendor to offer more than one platform/technology type) **Response: NO**

6. **Question:** Is there more than 1 laundry room needing access control at Magic Ave, Felker, or any other RHA buildings? **Response: NO**

7. **Question:** Is there an analog phone line in the basement of each building?  
**Response: NO, the phone lines in the buildings are voice over IP**