



Addendum #1: Clarification of Light Pole Specifications

RFP No.: TCF-2024-LTG01

Project Name: Light Pole Installation Services

Issue Date: April 25, 2025

This Addendum is issued to clarify project specifications in response to bidder inquiries for the Light Pole Installation Project at Trinity County Fairgrounds.

Pole and Fixture Specifications

Contractors shall base their proposals on the following minimum standards unless otherwise proposed in detail:

- Pole Height: 25 feet
- Pole Base: Elevated concrete base, 4 feet high, 24 inches in diameter
- Light Fixtures: 300-watt LED fixtures
- Fixture Quantity Per Pole: Minimum of two (2) 300-watt LED lights per pole
- Trenching: Required where indicated on site map (Attachment A)
- Installation Requirements include:
 - Secure anchoring and grounding of poles
 - Light positioning for optimal coverage
 - Compliance with California Title 24 and NEC
 - Inclusion of all labor, conduit, wiring, and power connection

Contractors may propose equivalent or better alternatives provided that all performance, energy efficiency, and safety standards are met. Any deviations must be clearly described in the bid.

Proposal Deadline

This clarification does not alter the proposal deadline. Submissions are still due by May 5, 2025, at 5:00 PM PST.



This addendum must be acknowledged in the proposal submission, either by completing Attachment E (Walkthrough Acknowledgment Form) or submitting a signed letter of acknowledgment.