



Environmental Testing and Research Laboratories, Inc.

Top Choice Home Inspections
12841 Iowa Ave. N.E.
Alliance, OH 44601-

Phone (330) 614-0054

Report #: 121113218

Date : 12/11/2013

P.O.Number:

Matrix: Drinking Water

Client: John Doe

Sample Location 123 Main St

Anywhere OH 44999

This sample taken by Todd Hoffmeyer at 10:30:00 AM on 12/9/2013. Point of collection: Kitchen

Comprehensive Scan Report

Table with 4 columns: Test Name, Results, Description, and Public Drinking Water EPA Limits. Rows include General Bacteria (Total Coliform, Fecal/E. Coli), General Chemistry (Sodium, Potassium, Copper, Iron, Manganese, Magnesium, Calcium, Arsenic, Lead, Zinc, pH, Turbidity, Color, Odor, Conductivity, T.D.S., Sediment, Alkalinity, Chlorine, Chloride, Hardness, Nitrate as Nitrogen, Nitrite as Nitrogen, Ammonia as Nitrogen, Sulfate), Radiochemistry (Radon in Water), and Organic Analysis (Benzene, Bromobenzene).

The integrity of the sample and results are dependent on the quality of sampling. The results apply only to the actual sample tested. Environmental Testing and Research Laboratories shall be held harmless from any liability arising out of the use of such results.



Environmental Testing and Research Laboratories, Inc.

Top Choice Home Inspections
12841 Iowa Ave. N.E.
Alliance, OH 44601-

Phone (330) 614-0054

Report #: 121113218

Date : 12/11/2013

P.O.Number:

Matrix: Drinking Water

Client: John Doe

Sample Location 123 Main St

Anywhere OH 44999

This sample taken by Todd Hoffmeyer at 10:30:00 AM on 12/9/2013. Point of collection: Kitchen

Comprehensive Scan Report

Table with 3 columns: Chemical Name, Results, and Public Drinking Water EPA Limits. Lists various chemicals like Bromochloromethane, Chloroform, etc., with their detection status and limits.

The integrity of the sample and results are dependent on the quality of sampling. The results apply only to the actual sample tested. Environmental Testing and Research Laboratories shall be held harmless from any liability arising out of the use of such results.



Environmental Testing and Research Laboratories, Inc.

Top Choice Home Inspections
12841 Iowa Ave. N.E.
Alliance, OH 44601-

Phone (330) 614-0054

Report #: 121113218

Date : 12/11/2013

P.O.Number:

Matrix: Drinking Water

Client: John Doe

Sample Location 123 Main St

Anywhere OH 44999

This sample taken by Todd Hoffmeyer at 10:30:00 AM
on 12/9/2013. . Point of collection: Kitchen

Comprehensive Scan Report

	<u>Results</u>	<u>Public Drinking Water EPA Limits</u>
p-Isopropyltoluene	Not Detected	No Limit
Methylene Chloride	Not Detected	5.0 ug/L
Monochlorobenzene	Not Detected	100.0 ug/L
Napthalene	Not Detected	No Limit
n-Propylbenzene	Not Detected	No Limit
Styrene	Not Detected	100.0 ug/L
1,1,1,2-Tetrachloroethane	Not Detected	No Limit
1,1,2,2-Tetrachloroethane	Not Detected	No Limit
Tetrachloroethylene	Not Detected	5.0 ug/L
Toluene	Not Detected	1000.0 ug/L
1,2,3-Trichlorobenzene	Not Detected	No Limit
1,2,4-Trichlorobenzene	Not Detected	70.0 ug/L
1,1,1-Trichloroethane	Not Detected	200.0 ug/L
1,1,2-Trichloroethane	Not Detected	5.0 ug/L
Trichloroethylene	Not Detected	5.0 ug/L
1,2,3-Trichloropropane	Not Detected	No Limit
1,2,4-Trimethylbenzene	Not Detected	No Limit
1,3,5-Trimethylbenzene	Not Detected	No Limit
Vinyl Chloride	Not Detected	2.0 ug/L
o-Xylene	Not Detected	T. Xylenes 10K ug/
m+p Xylenes	Not Detected	T. Xylenes 10K ug/

The integrity of the sample and results are dependent on the quality of sampling. The results apply only to the actual sample tested. Environmental Testing and Research Laboratories shall be held harmless from any liability arising out of the use of such results.