

Addendum #1: Clarification of LED Fixture Specifications and Compliance Requirements

RFP No.: TCF-2024-LTG02

Project Name: LED Lighting Replacement and Upgrade

Issue Date: April 25, 2025

This Addendum provides clarification regarding the fixture quantities, installation locations, and compliance expectations for the LED Replacement and Upgrade Project at the Trinity County Fairgrounds. This information is provided in response to bidder inquiries and is considered an official part of the RFP. All contractors must incorporate the following details into their proposals.

1. LED Fixture Distribution

Contractors shall base their proposals on the following quantities and locations:

- 37 individual light fixtures replaced with 300-watt LEDs:
- • 5 at Grandstands
- • 24 at Exhibit Hall
- • 8 at Large Animal Barn
- 6 individual lights installed on 6 existing light poles at Maintenance and South RV Park
- 4 individual lights installed on 5 existing poles in the Beer Garden and Midway areas
- 3 individual lights installed on 2 existing poles in the Main Parking Lot
- 2 individual lights installed on 3 existing poles in the Main Parking Lot

2. California Title 24 and Lighting Standards

All fixtures and lighting controls must comply with the California Energy Code (Title 24, Part 6). This includes required cutoff shielding where applicable, automatic shut-off controls, photo sensors, and wattage limitations. Contractors must submit product cut sheets and documentation to confirm Title 24 compliance.



3. Fixture Product Submittal Requirements

All proposals must include detailed lighting specifications, including:

- Manufacturer and model
- Wattage and lumen output
- Color temperature (Kelvin)
- Fixture cut sheets
- Warranty period
- Description of lighting controls or timers

4. Federal Grant Compliance

This project may be funded through the California State Nonprofit Security Grant Program (CSNSGP) and subject to federal procurement requirements under 2 C.F.R. Part 200. All contractors must ensure their bid and invoicing processes comply with applicable sections of the Uniform Guidance.

5. Proposal Deadline and Addendum Acknowledgment

This addendum does not change the submission deadline. Proposals are still due by May 5, 2025, at 5:00 PM PST.

This addendum must be acknowledged in the proposal submission, either by completing Attachment E (Walkthrough Acknowledgment Form) or providing a signed letter of acknowledgment.