

ANNUAL EMERGENCY LIGHT PERFORMANCE TEST LOG

YEAR _____

Name _____

ADDRESS _____

| Unit # | JANUARY | FEBRUARY | MARCH | APRIL | MAY | JUNE | JULY | AUGUST | SEPTEMBER | OCTOBER | NOVEMBER | DECEMBER | ANNUAL |
|--------|---------|----------|-------|-------|-----|------|------|--------|-----------|---------|----------|----------|--------|
| 1 | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | |
| 13 | | | | | | | | | | | | | |
| 14 | | | | | | | | | | | | | |
| 15 | | | | | | | | | | | | | |
| 16 | | | | | | | | | | | | | |
| 17 | | | | | | | | | | | | | |
| 18 | | | | | | | | | | | | | |
| 19 | | | | | | | | | | | | | |
| 20 | | | | | | | | | | | | | |
| 21 | | | | | | | | | | | | | |
| 22 | | | | | | | | | | | | | |
| 23 | | | | | | | | | | | | | |
| 24 | | | | | | | | | | | | | |
| 25 | | | | | | | | | | | | | |

CSFC Part V 14.13.2 Periodic Testing of Emergency Lighting Equipment.

A functional test shall be conducted on every required battery-powered emergency lighting system at 30 day intervals for a minimum of 30 seconds. An annual test shall be conducted for 90 minutes. Equipment shall be fully operational for the duration of the test. Written records of visual inspections and tests shall be kept by the owner for inspection by the Fire Marshal upon his request.

Exception: Self-testing/self -diagnostic, battery operated emergency lighting equipment that automatically performs a minimum 30 second test and diagnostic routine at least once every 30 days and indicates failures by a status indicator, shall be exempt from the 30 day functional test, provided a visual inspection is performed at 30 day intervals.