



GROVE CONCRETE & SUPPLY, INC.
 18426 DURAND AVENUE P.O. BOX 363
 UNION GROVE, WISCONSIN 53182
 (262) 878-2030 FAX (262) 878-4222
 GroveConcrete.com

NOTES:

- 4,000 PSI AIR ENTRAINED CONCRETE, STEEL REINFORCED TO MEET REQUIREMENTS.
- #4 REBAR 5" ON CENTER.

COM-ED #C5286-H

FOR ANY MODIFICATIONS CALL GROVE CONCRETE

DRAWN BY: RAY		DATE: 4/29/15
SCALE: NTS	EST. WIEGHT: 4,900 LBS.	VERSION: 00001

DWG. #
COM-ED-C5286-H

APPROVED BY:

THIS DRAWING AND THE INFORMATION CONTAINED HEREIN IS THE EXCLUSIVE PROPERTY OF GROVE CONCRETE & SUPPLY, INC., AND SHALL NOT BE REPRODUCED, USED, OR DISCLOSED TO OTHERS EXCEPT AS AUTHORIZED THROUGH WRITTEN CONCENT FROM GROVE CONCRETE & SUPPLY, INC.