

Annual Drinking Water Quality Report for 2025

Randolph Town Water District

72 Main Street, Randolph, N.Y. 14772

Public Water Supply ID# NY0400348

Conewango Town Water District

Public Water Supply ID # NY0430112

INTRODUCTION

To comply with State and Federal regulations, the Town of Randolph will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. We are proud to report that our system did not violate a maximum contaminant level or any other water quality standard. Last year, your tap water met all State drinking water health standards. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, contact **Jason Beaver, Chief Water Operator (716) 397-3313**. If you want to learn more, please attend any of our regularly scheduled Board meetings. They are held on the 2nd Wednesday of the month, at 7:30 P.M. in the Board Room at the Municipal Building, 72 Main Street. We want you to be informed about your drinking water.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Your water is obtained from ground water sources. Two drilled wells on Church Street now serve the majority of the district and the school. The East Randolph Well Field (which supplies parts of Randolph and the Conewango Town Water District) is located off Hatchery Road and consists of three drilled wells. There is an interconnection between the two systems, so one can supply the other in an emergency. Sodium hypochlorite is added to the source waters prior to entering the distribution system to ensure proper disinfection. The Randolph Town Water District serves approximately 1,738 people through 788 service connections. The Conewango Town Water District serves approximately 217 people through 79 service connections.

In 2003, the NYS DOH completed a source water assessment for our water systems, based on available information. Possible and actual contamination threats to the drinking water sources were evaluated. The source water assessment includes susceptibility ratings based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential contamination of the source water. It does not mean that the water delivered to consumers is, or will become contaminated. See section "ARE THERE CONTAMINANTS IN OUR DRINKING WATER?" for a list of the contaminants that have been detected. The source water assessments provide resource managers with additional information for protecting source waters into the future.

The source water assessment has rated the combined susceptibility to contamination for the East Randolph Wells Field as medium-high from enteric bacteria, enteric viruses and nitrates; and medium from cations/anions (salts, sulfate), halogenated solvents, metals, other industrial organics, petroleum products and protozoa. These ratings for the wells are due to their proximity to underground storage tanks and a permitted discharge facility (industrial/commercial facility that discharges wastewater into the environment and is regulated by the state and/or federal government). While the assessment rates our sources as being susceptible to enteric bacteria, please note that our water is disinfected to ensure that the finished water delivered into your home meets New York State's drinking water standards.

A copy of this assessment, including a map of the assessment area, can be obtained by contacting the Town of Randolph Water Department as noted above. Be advised there is not a source water assessment available for the Church Street wells.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: coliform bacteria, inorganic compounds, volatile organic compounds, nitrate, lead and copper, total trihalomethanes, haloacetic acids, radiological compounds and synthetic organic compounds. In addition, we test for chlorine daily. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791 or the Cattaraugus County Health Dept. at (716) 701-3386. Information is also available from the EPA website at: <https://www.epa.gov/dwreginfo/drinking-water-regulations>.

Table of Detected Contaminants							
Contaminant	Violation Yes/No	Date of Sample	Level Detected (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
Disinfectants							
Chlorine Residual	No	2025	Avg. = .66 (.27-1.45)	mg/l	N/A	MRDL = 4	Water additive used to control microbes.
Inorganic Contaminants							
Barium	No	11/5/24	High = 168 (132 - 203)	ug/l	2,000	MCL = 2,000	Discharge of drilling wastes.
Copper ¹ - Randolph	No	6/26/23– 6/27/23	90 th = 309 (50.5 - 418)	ug/l	1,300	AL = 1,300	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
- ER & Conewango	No	6/8/24 - 6/10/24	90 th = 57.8 (5.7 - 153)				
Lead ² - Randolph	No	6/26/23– 6/27/23	90 th = 3.1 (ND – 3.1)	ug/l	0	AL = 15	Corrosion of household plumbing; erosion of natural deposits.
- ER & Conewango	No	6/8/24 - 6/10/24	90 th = 2.2 (1 – 4)				
Nitrate	No	11/5/24	High = 2.5 (2.5 – 2.5)	mg/l	10	MCL = 10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
Disinfection By-Products							
Total Trihalomethanes - Randolph	No	8/13/25	High = 18.1 (1.16 – 18.1)	ug/l	N/A	MCL = 80	By-product of drinking water disinfection needed to kill harmful organisms. TTHMs are formed when source water contains large amounts of organic matter.
Haloacetic Acids - Randolph	No	8/13/25	High = 1.3 (ND – 1.3)	ug/l	N/A	LRAA = 60	By-product of drinking water disinfection needed to kill harmful organisms.

1 - The levels presented represent the 90th percentile of the 10 sites tested for the Randolph portion and 10 sites for the former East Randolph portion. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper or lead values detected at your water system. The 90th percentile value for copper from the Randolph portion was 309 ug/l in 2023. The 90th percentile value from the ER and Conewango portion was 57.8 ug/l in 2024. The action level for copper was not exceeded at any of the sites tested.

2- The 90th percentile level for lead in the Randolph portion was 3.1 ug/l in 2023. The 90th percentile from the ER & Conewango portion was 2.2 ug/l in 2024. None of the sites exceeded the action level of 15 ug/l.

Definitions:

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

N/A: Not applicable.

Nanograms per liter (ng/l): Corresponds to one part of liquid to one trillion parts of liquid (parts per trillion – ppt).

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State. However, we are required to present the following information on lead in drinking water:

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Randolph is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and take steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Jason Beaver (716) 397-3313. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

INFORMATION ON LEAD SERVICE LINE INVENTORY

A Lead Service Line (LSL) is defined as any portion of pipe that is made of lead which connects the water main to the building inlet. An LSL may be owned by the water system, owned by the property owner, or both. The inventory includes both potable and non-potable SLs within a system. In accordance with the federal Lead and Copper Rule Revisions (LCRR) our system has prepared a lead service line inventory and have made it publicly accessible by keeping a record at the Town's clerk office at 72 Main St. Randolph NY 14772.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ♦ Saving water saves energy and some of the costs associated with both of these necessities of life;

- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ◆ Saving water lessens the strain on the water system during a dry spell or drought, and helps to avoid severe water use restrictions, so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ◆ Turn off the tap when brushing your teeth.
- ◆ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it, and you can save almost 6,000 gallons per year.
- ◆ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these, otherwise, invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

CLOSING

Thank you for allowing us to continue to provide your household and family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments are occasionally necessary in order to address these improvements and keep pace with inflation. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please call our office if you have questions.