



OFFICIAL LISTING

NSF International Certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI Standard 61 - Drinking Water System Components - Health Effects

This is the Official Listing recorded on March 16, 2009.

SPRAYROQ, INC.
P.O. BOX 101717
BIRMINGHAM, AL 35210-6717
205-957-0020

Facility: ST. LOUIS, MO

Trade Designation	Protective (Barrier) Materials		Water Contact Temp	Water Contact Material
	Water Contact Size Restriction			
Coatings - Fittings				
SprayShield Green 1 ^[2] [3]	>= 30"		CLD 23	PUR
SprayWall@[1]	>= 4"		CLD 23	PUR
Coatings - Pipe				
SprayShield Green 1 ^[2] [3]	>= 30"		CLD 23	PUR
SprayWall@[1]	>= 4"		CLD 23	PUR
Coatings - Pipe - Immediate Return to Service				
SprayShield Green 1 ^[2] [3]	>= 30"		CLD 23	PUR
Coatings - Tank				
SprayShield Green 1 ^[2] [3]	>= 300 gal.		CLD 23	PUR
SprayWall@[1]	>= 5 gal.		CLD 23	PUR
Coatings - Valve				
SprayShield Green 1 ^[2] [3]	>= 30"		CLD 23	PUR
SprayWall@[1]	>= 4"		CLD 23	PUR

- [1] Number of Coats: N/A
Sequence of Coats: N/A
Maximum Field Use Dry Film Thickness (in mils): 100 - 1000
Maximum Thinner: N/A
Recoat Cure Time and Temperature: 2 hours final cure
Special Comments: Mix ratio of Part A:Part B is 0.509:1
- [2] Evaluated for Immediate Return to Service.
- [3] Colors: Light green
Number of Coats: 1-3
Maximum Field Use Dry Film Thickness (in mils): Maximum 80 per coat; not to exceed a total maximum DFT of 240
Maximum Thinner: None
Recoat Cure Time and Temperature: 15 minutes at ambient temperature
Final Cure Time and Temperature: 24 hours at ambient temperature
Special Comments: Mix ratio of Part A:Part B is 1:1 by volume. Application is by plural component spray gun.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF International.