

BRIAN S. McFEATERS

SEWAGE ENFORCEMENT OFFICER

SPECIALIZING IN ON-LOT SOIL TESTING AND DESIGN

664 BRICKER LANE ANNVILLE PA 17003

BRIAN 717-813-6492 CARRIE 717-813-7239

WHAT IS REQUIRED FOR NEW SEWER CONNECTION INSPECTION

1. INSPECTIONS WILL OCCUR ON MONDAYS AND FRIDAYS. PLEASE SCHEDULE ACCORDINGLY. OTHER TIMES MAY BE AVAILABLE IF WE ARE IN THE AREA.
2. INSTALLER MAY USE PVC SCHEDULE 40 OR SDR 35 PIPE.
3. SANITARY SEWER LATERALS SHALL BE INSTALLED WITH A MINIMUM SLOPE OF 1%.
4. MUST HAVE SEWER LINE AIR PRESSURE TEST FOR INSPECTION. 5 PSI IS THE CORRECT PRESSURE AND THE PRESSURE SHALL BE ON THE PIPE AT LEAST AN HOUR BEFORE INSPECTION.
5. SANITARY SEWER LATERAL BEDDING SHALL BE 6" OF ASHTO NO. 8 CRUSHED STONE OR GRAVEL AGGREGATE ABOVE AND BELOW THE SANITARY SEWER LATERAL.
6. NATIVE BACKFILL SHALL BE MATERIAL EXCAVATED FROM THE SITE FREE OF STONES LARGER THAN 6" IN SIZE AND FREE OF WET, FROZEN, AND ORGANIC MATERIALS AND REFUSE.
7. ALL CONSTRUCTION SHALL COMPLY WITH STANDARD CONSTRUCTION SPECIFICATIONS AND DETAILS OF HAWASA.

WHAT IS REQUIRED FOR SEPTIC TANK ABANDONMENT INSPECTION

1. THE INSPECTIONS WILL BE ON MONDAYS AND FRIDAYS. PLEASE SCHEDULE ACCORDINGLY. OTHER TIMES MAY BE AVAILABLE IF WE ARE IN THE AREA.
2. SEPTIC TANKS MUST BE PUMPED BY A REPARABLE PUMPER AND THE CONTENTS DISPOSED AT AN APPROVED D.E.P. DISPOSAL FACILITY.
3. A COPY OF THE PUMPING RECEIPT WILL NEED TO BE PROVIDED TO THE INSPECTOR AT THE TIME OF INSPECTION.
4. PHOTOS OF THE TANK SHOWING WHAT METHOD (CRUSHING, PHYSICALLY REMOVING, FILLING...) WAS USED TO ELIMINATE THE VOID IN THE GROUND.
5. A CHECK OR MONEY ORDER IN THE AMOUNT OF \$150.00, MADE PAYABLE TO HALIFAX TOWNSHIP, WILL NEED TO BE GIVEN TO THE INSPECTOR AT THE TIME OF INSPECTION.
6. THE OWNER WILL RECEIVE AN INSPECTION REPORT FROM THE INSPECTOR STATING THE SEPTIC TANK WAS ABANDONED CORRECTLY.