

## ANSWERS TO REQUESTS FOR INFORMATION

1. Is there an engineer's cost estimate for the project? The District has budgeted \$625,000 for the project based on prior experience.
2. What does SY represent in the bid schedule? Square Yards
3. Is the striping thermoplastic or paint? Paint
4. Where is the speed bump located? Calle Los Callados
5. Is there a staging area for construction use? No
6. What are the limits for the 10 streets listed? We don't have a surveyor map of each street, but the District expects that the new asphalt will simply replace the existing asphalt.
7. Do you have a plan holders' list? No
8. What about golf cart services for residents to and from their vehicles and home during construction? Contractor needs to provide shuttle service for residents to and from vehicle and residence,
9. How will the Stop and Bar be paid? Assuming the Bar is the wide white line in front of the stop sign, the Bar is paid for by the same unit of measure in the bid item #6 (linear foot).
10. How is one speed bump being paid? Include the speed bump in bid item #5 as part of HMA tonnage.
11. How are the lowering and raising of the 4-6 utility boxes being paid? We did not anticipate having to lower and raise the utility boxes. Please call out as separate item and include the cost in the total.