



GROVE CONCRETE & SUPPLY, INC.
 18426 DURAND AVENUE P.O. BOX 363
 UNION GROVE, WISCONSIN 53182
 (262) 878-2030 FAX (262) 878-4222
 GroveConcrete.com

- NOTES:**
1. GALLONS PER INCH:
 1,100 COMPARTMENT - 17.74 gal/in.
 500 COMPARTMENT - 8.06 gal/in.
 2. REINFORCED CONCRETE 4,000 PSI MIN.
 3. (GASKETED 4" OR 6" OPENING) PRESS SEAL, TUFF TITE OR EQUAL.
 4. (LABEL APPLIED TO COVER), WHEN USED AS A GREASE INTERCEPTOR.
 5. 5' MAX DEPTH OF COVER, 8' BURIAL DEPTH WITH HEAVY DUTY COVER.
 6. ALL BAFFLES & FILTERS TO BE INSTALLED TO MEET STATE & LOCAL CODES.
 7. THIS TANK IS BUILT IN COMPLIANCE OF SECT. 905.40 IL. PRIVATE SEWAGE CODE.

(1,100 / 500 / 1,100) 2,700 3C
 GALLON PUMP, SEPTIC, HOLDING TANK,
 GREASE INTERCEPTOR

FOR ANY MODIFICATIONS CALL
 GROVE CONCRETE

DRAWN BY: RAY DATE: 3/8/16

SCALE: NTS EST. WIEGHT: 25,080 LBS. VERSION: 00002

DWG. # TNK-2700-3C-VER-2 ILL. APPROVAL # 114
 WIS. STATE APPROVED

THIS DRAWING AND THE INFORMATION CONTAINED HEREON IS THE EXCLUSIVE PROPERTY OF GROVE CONCRETE & SUPPLY, INC., AND SHALL NOT BE REPRODUCED, USED, OR DISCLOSED TO OTHERS EXCEPT AS AUTHORIZED THROUGH WRITTEN CONCENT FROM GROVE CONCRETE & SUPPLY, INC.

