

Annual Drinking Water Quality Report For 2019
Cedar Ridge Children's Home & School, Inc.
PWSID 0210020
April, 2020

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the water quality and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from four wells located on the Cedar Ridge property which draw from underground aquifers at varying depths from 400 feet to 525 feet. From the wells, the water is chlorinated and stored in a 5,800 gallon storage tank. It is then treated by a water softener system, UV light, and a filter system that removes microbes to provide safe drinking water. This filter removes cysts and other harmful organisms.

This report shows our water quality and what it means. If you have any questions about this report or concerning your water, please contact Paula Shatzer, Chief Operations Officer, at 301-582-0282. We want our residents, employees, and students to be informed about their water. A Source Water Assessment is available From MDE.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Cedar Ridge Children's Home routinely monitors for contaminants in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2019. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

- *Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.
- *Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- *Action Level* - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- *Maximum Contaminant Level* - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- *Maximum Contaminant Level Goal* - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- *Nephelometric Turbidity Unit (NTU)* - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.
- *Picocuries per liter (pCi/L)* - picocuries per liter is a measure of the radioactivity in water.

TEST RESULTS						
Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Volatile Organic Contaminants						
TTHM (Distribution) [Total trihalomethanes] Range Highest Locational Running Average (2019)	N	30.4-30.4 30	ppb	0	80	By-product of drinking water disinfection
HAA5 (Haloacetic acids) (distribution) Range Highest Locational Running Average (2019)	N	7.7-7.7 8	ppb	0	60	By-product of drinking water disinfection
Microbiological Contaminants						
Turbidity (2018)	N	3	ntu	n/a	TT	Soil runoff
Inorganic Contaminants						
Copper (distribution) (2018)	N	0.33	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Chlorine (2019)	N	1.5	ppm	4	4	Water Additive used to control microbes
Nitrate (as Nitrogen) (2019)	N	6	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage, erosion of natural deposits
Fluoride (2019)	N	0.58	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Radioactive Contaminants						
Alpha emitters (2017)	N	2	pCi/l	0	15	Erosion of natural deposits
Combined radium (2017) (226 & 228)	N	1.6	pCi/l	0	5	Erosion of natural deposits

Note: Test results are for year 2019 unless noted otherwise; testing for all contaminants is not required annually.

We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected. The EPA has determined that your water IS SAFE at these levels.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Cedar Ridge Children's Home is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.

NOTE: As can be seen by results listed in the above tables, lead, which is tested for annually at Cedar Ridge, has not been detected in our most recently collected samples in 2018.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Nitrate [measured as Nitrogen] - Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Please call Paula Shatzer at 301-582-0282 if you have any questions about this report.

Code of Maryland Regulations (COMAR) **26.04.01.20-2 Consumer Confidence Report Delivery**

(G.) Report Delivery and Record Keeping.

(1) Except as provided in §H of this regulation, each supplier of water to a community water system shall mail or otherwise directly deliver* one copy of the report to each customer.

(2) The supplier of water to a community water system shall make a good faith effort to reach consumers who do not get water bills, using means recommended by the State. Good faith effort will be tailored to the consumers who are served by the system but are not bill-paying customers, such as renters or workers. A good faith effort to reach consumers would include a mix of methods appropriate to the particular system such as: posting the reports on the Internet; mailing to postal patrons in metropolitan areas; advertising the availability of the report in the news media; publication in a local newspaper; posting in public places such as cafeterias or lunch rooms of public buildings; delivery of multiple copies for distribution by single-biller customers such as apartment buildings or large private employers; or delivery to community organizations.

(3) Not later than the date the system is required to distribute the report to its customers, each supplier of water for a community water system shall mail a copy of the report to the State, followed within 3 months by a certification that the report has been distributed to customers, and that the information is correct and consistent with the compliance monitoring data previously submitted to the State.

(4) Not later than the date the system is required to distribute the report to its customers, each community water system shall deliver the report to any other agency or clearinghouse identified by the State.

(5) Each community water system shall make its reports available to the public upon request.

(6) Each community water system serving 100,000 or more persons shall post its current year's report to a publicly accessible site on the Internet.

(7) Any supplier of water subject to this regulation shall retain copies of its consumer confidence report for no less than 3 years.

SYSTEMS SERVING < 10,000

(H.) The requirement of §G(1), (5) and (6) of this regulation for a supplier of water to a community water systems serving less than 10,000 persons has been waived. Such systems shall:

(1) Publish the reports in one or more local newspapers serving the area in which the system is located;

(2) Publish a notice in the newspaper, or by other means approved by the State, that informs the customers that the reports will not be mailed; and

(3) Make the reports available to the public upon request.

SYSTEMS SERVING ≤ 500

(I.) Supplier of water to systems serving 500 or fewer persons may forego the requirements of paragraphs §H (1) and (2) if they provide notice at least once per year to their customers by mail, door-to-door delivery or by posting in an appropriate location that the report is available upon request.

** Electronic delivery may be used to fulfill direct delivery requirements. However, each water system must obtain approval from MDE prior to implementation of electronic delivery. Refer to the following document for information regarding acceptable electronic delivery methods:*

<https://www.epa.gov/ccr/how-water-utilities-can-electronically-delivery-their-ccr>