

I&C FOR SAFETY OF NPP

by

A. K. Chandra

Exec. Dir. (C&I, Electrical, R&D-ES)

NPCIL

ISA(D)-POWAT-2012

New Delhi, January 13-14, 2012

CONTENTS

- Role of I&C in Safety of NPP
- Safety Life Cycle of Digital I&C

Nuclear Power Plants

- Steady increase in energy requirement to maintain growth rate
- Need to address global warming issues
- Required to have a suitable technology mix
 - Nuclear power must play a significant role as part of the mix
- Impact of Fukushima

Lessons from Fukushima

- Inevitability of Nuclear Events
- Reliable Post Shutdown Cooling
- Essential Safety of Nuclear Power

(Source: IAEA Conference June 2011)

NPP Capacity in India

- PHWR Program
 - 20 in operation, (capacity 4780 MWe)
 - 4 x 700 plants launched 6 under launch
- LWR program (imported)
 - 40,000 MWe planned
- LWR program (indigenous)

NPP – Safety Aspects

- Primary safety functions in NPP are
 - Regulation of reactivity in core and Reactor shutdown
 - Heat removal from fuel core (including decay heat)
 - Containment of radioactivity

Safety-Critical Systems

- A system is safety-critical, if a failure of the system could lead to consequences that are determined to be unacceptable.
 - In general, this implies that the failure of the system may lead to injury or death of human beings.
 - Damage to property can also be a consideration

Safety-Critical Systems Design

- Safety-critical systems need to be designed such that they perform desired function reliably even in harsh environments, are testable and design is verifiable.
- Extent of reliability required is determined by the tolerable rate of failures
 - Higher the damage potential of an event, lower should be the probability of the same

Role of I&C in NPP

- I&C systems monitor and display vital parameters for status of various systems and processes in the plant and carry out automatic control and protection functions
- I&C Systems play key role for actuation and monitoring of safety functions

I&C for Safety

- Designs follow standard techniques including fault tolerance, guard against common cause failures, diversity, use of qualified components, etc.
- Protection systems now use hardwired technologies (earlier some used digital).
- All other systems now use digital I&C

Use of Digital I & C

- Digital I&C systems offer several advantages but also offer challenges to the development and review processes
 - The main challenge is in proving the correctness of software
- Since software failures result from systematic faults, only qualitative analysis can be employed.

Integrity of Digital I&C

- Qualitative Issues
 - Use of rigorous software development process
 - Use of safe subsets of languages
 - Use of good development practices (IEC 60880)
 - Verification of implementation by tracing to requirements
 - Exhaustive documentation

Assessment of Digital I&C

- Safety standards demand definition of an appropriate safety life cycle
- Process has checks and balances to assure safety requirements met
- Demonstration of safety requires evidence that process was followed

Safety Life Cycle Of Dig. I&C

- The safety life cycle consists of activities from defining the requirements through development and installation and commissioning to the operation of the system
- Includes concurrent Verification & Validation activities

Engineering Procedures

- define the work methods for implementing the Safety Life Cycle
- define the documents to be produced at various stages of life cycle (and the nature and structure of information content of the same)

Procedures for Digital I&C

- System Requirements
- Digital I&C Systems
- Pre Developed Systems
- Newly Developed Systems
- Concession Request
- Requirements Change Notice

Regulatory Perspective 1/2

- Nuclear Industry is a heavily regulated industry (in every country)
 - Regulatory permission is required at each stage of design, construction and operation

Regulatory Perspective 2/2

- Defines recommended Safety Life Cycle
- Defines Safety Case and lists Regulatory Requirements
- Describes the Regulatory Review Process

Recommended Safety Life Cycle

- Generation of System Requirements
- Project Planning
- QA and V&V Planning
- Step-wise refinement of design
- System Integration and Testing
- System Safety and Reliability Analysis

Safety Case


- Documentary evidence to demonstrate
 - Compliance to regulatory requirements
 - Subjected to V&V
 - System meets safety and reliability goals

Regulatory Review Process

- Review of System Requirements, Plans
- Review / Audit of Design Outputs
- Review of System Validation
- Review of Analysis Reports

System Safety Analysis

- Confirmation of Safety Function implementation
- Failure Analysis (to meet single failure requirements)
- Analysis for Common Cause Failure




Thank you



Performance Analysis Diagnostics & Optimization

PADO



**The Power Of Optimisation
Now At Your Fingertips**



WHAT IS PADO?


- *PADO is a software based optimization and diagnostics system based on client-server architecture.*
- *It's a package rich in intensive information which aids plant operator to run the plant with most optimum efficiency , availability and maintainability.*
- *Massive Computation Engine for monitoring and analysis of Performance Parameters of Power Plant.*



Terminologies Used in Presentation

- *Heat Rate*: Ratio of fuel energy input and Gross power generated.
- *TTD* (Terminal Temp Diff): Logarithmic diff value of terminal temperatures.
- *DCA* (Drain Cooler Approach): Diff of drain temp and inlet temp of feed water.
- *MLP* (Multilayer Perception)
- *SOM* (Self Organising Map): Neural Network Techniques.
- *SPO* : Set Point Optimisation
- *CEO* : Combustion Emission Optimisation
- *MTM* : Metal Temperature Measurement
- *BCM* : Boiler Cleaning Module , *LTM* : Life Time Monitoring

PADO CONFIGURATION




PADO STRUCTURE FOR PERFORMANCE ANALYSIS AND OPTIMISATION



OFFLINE

ON LINE




PADO STRUCTURE FOR DIAGNOSTICS



OFFLINE

ON LINE





THE BUILDING BLOCKS (BBs)


- *BB1: PERFORMANCE ANALYSIS & MONITORING MODULE*
- *BB2: SYSTEM & PERFORMANCE OPTIMISATION*
- *BB3: BPOS (BOILER PERFORMANCE OPTIMISATION SYSTEM)*
- *BB4: BOILER STRESS CONDITION ANALYSER*
- *BB5: SYSTEM & PERFORMANCE DIAGNOSIS MODULE*
- *BB6: INTELLIGENT WATER & STEAM CHEM. MGT*

BB-1: PERF. ANALYSIS & MONITORING




PERFORMANCE EVALUATION

- *HEAT RATE*
 - Net HR, Gross HR, Turbine HR, Unit HR*
- *EQUIPMENT EFFICIENCY CALCULATIONS*
- *Controllable losses*
 - Throttle Temp. & Pressure*
 - RH Temp & Pressure drop*
 - Condenser Back Pressure.*
 - SH & RH spray Flow*
 - Final FW Temp*
 - Blow Down, MU Flow, Frequency & Auxiliary Steam Flow*





CONDENSER




Rihand 5			
12/20/2011 4:30:00 PM-4:35:00 PM			
Status	Unit	Boiler	Measurements
	steady state	operating	okay
Generator el. output power gross			500.1 MW
Unit efficiency net			36.5 %
Unit heat rate gross			2264 kcal/kWh
Boiler Load Index			*** %
Boiler efficiency			85.8 %
Station load			20.0 MW
	Reference	Actual	
condenser vacuum	-0.928 kg/cm ²	0.105 kg/cm ²	
condensing temp.	46.3 °C	46.3 °C	
efficiency	100.0 %	100.0 %	
TTD	3.3 °C	4.3 °C	
heat rate deviation		0 kcal/kWh	
heat rate deviation air ingress		0 kcal/kWh	
heat rate deviation fouling		*** kcal/kWh	
monetary loss		0 Rs/h	

CW diff. pressure	0.22 kg/cm ²
Reference pressure	1.03 kg/cm ²





TRAFFIC LIGHT SYSTEM IMPLEMENTED FOR DEGRADATION OF EQUIPMENT



BB-1: PERF. ANALYSIS & MONITORING



PERFORMANCE EVALUATION

- *WHAT IF ANALYSIS*
 - *MS TEMP*
 - *CONDENSER BACK PRESSURE*
 - *CW INLET TEMPERATURE*
 - *COOLING WATER MASS FLOW*
 - *EXCESS AIR*
 - *MILL COMBINATION*
 - *BURNER TILT*



Offline What-If Module - PADO 500MW




Parameters	Act-Value	Sim Value		Rel. Diff.	Abs. Diff	Simulate	Simulation status		Reset
		Set-Value	Calc-Value				calculating	2	
LOAD Load definition									
<input checked="" type="radio"/> Pel Generator	500.0 MW	500.0 MW	500.0 MW	0.00%	0.01 MW		Calculation time	4.00 s	
<input type="radio"/> Pel Net	470.0 MW	470.0 MW	470.0 MW	0.00%	0.01 MW		# iterations	212	
<input type="radio"/> F coal	94.9 kg/s	94.9 kg/s	94.9 kg/s	0.00%	0.0 kg/s				
Aux. power consumption	30.0 MW	30.0 MW	30.0 MW	0.00%	0.0 MW				
T MS Mainsteam temperature									
	536.9 °C	536.9 °C	536.9 °C	0.00%	0.0 °C				
P MS Mainsteam pressure									
<input type="radio"/> Defined	174.2 bar	174.2 bar	174.2 bar	0.00%	0.0 bar				
<input checked="" type="radio"/> Calculated									
T HRH Hot reheat temperature									
	564.9 °C	564.9 °C	564.9 °C	0.00%	0.0 °C				
T FW Feedwater temperature									
<input checked="" type="radio"/> Defined	253.2 °C	260.0 °C	253.2 °C	0.00%	0.0 °C				
<input type="radio"/> Calculated									
<input checked="" type="checkbox"/> HPH 5 (lev)	0 mm	0 mm	0 mm	0.00%	0 mm				
<input checked="" type="checkbox"/> HPH 6 (lev)	0 mm	50 mm	0 mm	0.00%	0 mm				
<input checked="" type="checkbox"/> LPH 1	0 mm	0 mm	0 mm	0.00%	0 mm				
<input checked="" type="checkbox"/> LPH 2	0 mm	0 mm	0 mm	0.00%	0 mm				
<input checked="" type="checkbox"/> LPH 3	0 mm	0 mm	0 mm	0.00%	0 mm				
RHSF Reheater sprayflow									
	0.0 kg/s	0.0 kg/s	0.0 kg/s	0.00%	0.0 kg/s				
SHSF Superheater sprayflow									
	6.9 kg/s	6.9 kg/s	6.9 kg/s	0.00%	0.0 kg/s				
P Cond Condenser pressure									



Offline What-If Module - PADO 500MW



Results	Act Value	Sim Value	Rel. Diff.	Abs. Diff.
Fluegas temp. aft. AH	125.1 °C	125.2 °C	0.07%	0.1 °C
Boiler				
Boiler efficiency	85.44%	85.43%	-0.01%	-0.01%
Drygas loss	1.10%	1.10%	0.10%	0.00%
Loss D/T H ₂ O in Fuel	2.64%	2.64%	0.01%	0.00%
Loss D/T H ₂ O from H ₂ in Fuel	5.59%	5.59%	0.01%	0.00%
Loss D/T H ₂ O in air	0.11%	0.11%	0.03%	0.00%
Loss D/T UBC	1.00%	1.00%	0.00%	0.00%
Loss D/T radiation	0.15%	0.15%	0.00%	0.00%
Other losses	0.67%	0.68%	0.11%	0.00%
Total losses	14.56%	14.57%	0.04%	0.01%
Heatrates				
Unit Gross	2264 kcal/kWh	2260 kcal/kWh	-0.18%	-4 kcal/kWh
Unit Net	2409 kcal/kWh	2404 kcal/kWh	-0.18%	-4 kcal/kWh
Cycle Gross	1934 kcal/kWh	1931 kcal/kWh	-0.19%	-4 kcal/kWh
Cycle Net	2058 kcal/kWh	2054 kcal/kWh	-0.19%	-4 kcal/kWh
Boiler heating surfaces				
Furnance				
Fouling	267.1 %	267.1 %	0.00%	0.0 %
Heat Absorption	416.5 MW	416.4 MW	-0.03%	-0.1 MW
Adiabatic combustion temp.	1736.1 °C	1736.3 °C	0.01%	0.2 °C
Fluegas output temp.	1244.6 °C	1244.1 °C	-0.05%	-0.6 °C
Weater input temp.	361.3 °C	361.4 °C	0.02%	0.1 °C
Water output temp.	360.8 °C	360.9 °C	0.02%	0.1 °C
SHPL				
Fouling	71.1 %	71.1 %	0.00%	0.0 %
Heat Absorption	92.5 MW	94.2 MW	1.81%	1.7 MW
Adiabatic combustion temp.	1075.9 °C	1069.6 °C	-0.59%	-6.3 °C
Fluegas output temp.	957.1 °C	948.3 °C	-0.92%	-8.8 °C
Water input temp.	463.5 °C	462.6 °C	-0.18%	-0.8 °C
Water output temp.	540.0 °C	540.0 °C	0.01%	0.0 °C



Preparation Parameter Results Daten



THE BUILDING BLOCKS (BBs)

- *BB 1: PERFORMANCE ANALYSIS & MONITORING MODULE*
- *BB2: SYSTEM & PERFORMANCE OPTIMISATION*
- *BB3: BPOS (BOILER PERFORMANCE OPTIMISATION SYSTEM)*
- *BB4: BOILER STRESS CONDITION ANALYSER*
- *BB5: SYSTEM & PERFORMANCE DIAGNOSIS MODULE*
- *BB6: INTELLIGENT WATER & STEAM CHEM. MGT*




BB-2: SYS & PERF. OPTIMISATION

FEATURES:

- *OPTIMISATION OF BOILER SOOTBLOWING*
- *SET POINT OPTIMISATION*
- *MONITORS EMISSIONS OF SO_x, NO_x, CO etc.*
- *NO_x OPTIMISATION*

SOOT BLOWER OPTIMISATION



SET POINT OPTIMISATION



Rihand 5
12/20/2011 4:30:00 PM-4:35:00 PM

Set point optimization

Boiler	Act value	Opt value
O2 at Eco outlet	3.15 %Vol	5.50 %Vol
Burner tilt	0.0 °	3.9 °

Turbine Cycle	Act value	Opt value
MS temperature	540.00 °C	540.33 °C
MS pressure	173.19 bar	173.00 bar
Reheat temperature	568.00 °C	568.30 °C
Unit Heat Rate gross	2264 kcal/kWh	2266 kcal/kWh
Avg Mill Height FbH1	34 m	35.500 m

Mill Recommendations

	Maint.	Status		Load	
		Current	Optimized	Current	Optimized
MILL K	1	0	0	0.00 kg/s	0.00 kg/s
MILL J	1	1	1	46.71 t/h	58.00 t/h
MILL H	1	1	1	46.71 t/h	58.00 t/h
MILL G	1	1	1	46.71 t/h	58.00 t/h
MILL F	1	1	1	46.71 t/h	58.00 t/h
MILL E	1	1	1	46.71 t/h	58.00 t/h
MILL D	1	1	0	46.71 t/h	0.00 t/h
MILL C	1	1	1	46.71 t/h	37.00 t/h
MILL B	1	0	0	0.00 t/h	0.00 t/h
MILL A	1	0	0	0.00 t/h	0.00 t/h

Unit Critical Calculated Outputs

Superheater Spray	25.0 t/h
Reheater Spray	0.0 t/h
Furnace Exit Flue Gas Temp	1305 °C
APH-A Leakage	15.758 %
APH-B Leakage	15.758 %
Platten SH Max Metal Temp	573 °C
RH Max Metal Temp	641 °C
HPH-5 Drain O/L Flow	118 t/h
HPH-6 Drain O/L Flow	75 t/h

Total consumption of pumps	6610.3 kW	6.610 MW
Total consumption of mills	2136.6 kW	2.137 MW
Total consumption of fans	4797.8 kW	4.798 MW
Total consumption of aux. consumers	13544.7 kW	13.545 MW
Station load	20006.0 kW	20.006 MW

Set point optimization here refers to the heat rate optimization with Nox and metal temperature as a constraint.

HR = f (rhs,egl,mst,rht,msp)

NN €rhs,egl,Nox



THE BUILDING BLOCKS (BBs)

- *BB 1: PERFORMANCE ANALYSIS & MONITORING MODULE*
- *BB2: SYSTEM & PERFORMANCE OPTIMISATION*
- *BB3: BPOS (BOILER PERFORMANCE OPTIMISATION SYSTEM)*
- *BB4: BOILER STRESS CONDITION ANALYSER*
- *BB5: SYSTEM & PERFORMANCE DIAGNOSIS MODULE*
- *BB6: INTELLIGENT WATER & STEAM CHEM. MGT*

BB-3: BOILER PERFORMANCE OPTIMISATION (BPOS)



FEATURES:

- ***BACKWARD CALCULATIONS***

- ZONAL FG & FLUID TEMPERATURE

- HEAT BALANCE

- LOSSES (*Dry gas, H₂O in fuel, UBC, Radiation, H₂O in air*)

- ***FORWARD CALCULATIONS***

- COAL, AIR, SPRAY FLOWS

- BOILER EFFICIENCY

- ***METAL TEMP. CALCULATION***

- ***METAL HOT SPOTS***



Edit View Insert HTML-Lists Parameter Process Sheets Documentation Window Help

5-Werte

7/13/2009 11:15:00 PM-11:20:00 PM

BPOS Backward Calculation Screen

Vindhyachal 9
7/13/2009 11:15:00 PM-11:20:00 P

Load [MW]	522
MS flow [t/h]	450
MS temp [°C]	538
RH temp [°C]	539

Fouling Factor

Zonal heat absorption

FG Temp b/w heating surfaces

Ambient air temperature [°C]	28
Relative humidity [%]	60
Flue gas oxygen at Eco outlet	3.48
Flue gas oxygen at AH outlet	5.50
Burner tilt [°]	29
Mills in operation	A on B on C off D on E off F off G on H on J on K off

Section	Flue gas temperature [°C]		Fluid temperature [°C]		Fouling factor	Zonal heat absorption [MW]	Maximum metal temperature [°C]
	Inlet	Outlet	Inlet	Outlet			
Economiser	571	283	263	337	0.88	162	
Waterwalls	1818	1418	360	360	0.74	366	
LTSH	905	571	360	470	0.88	280	502 °C
Panel SH	1418	1265	407	478	0.79	137	524 °C
Platen SH	1265	1172	478	538	0.86	89	584 °C
Reheater	1172	905	538	539	0.76	239	609 °C
Air heater	365	137			0.67	156	

Coal mass flow [t/h]	358
Bottom ash removal rate [%]	20
Duct ash removal rate [%]	5
AH ash removal rate [%]	3
Fly ash removal rate [%]	72
UBC in ash [%]	2.4

Coal analysis	
GCV [kcal/kg]	4000
Proximate	
Total moisture [%]	20.0
Ash [%]	30.7
Volatile matter [%]	***
Fixed carbon [%]	28.0
Ultimate	
Carbon [%]	40.5
Hydrogen [%]	2.4
Nitrogen [%]	0.9
Oxygen [%]	5.0
Sulphur [%]	0.5
Total moisture [%]	20.0
Ash [%]	30.7


Heat balance		
	Act	Req
Boiler efficiency [%]	86.55	86.80
Losses		
Dry gas [%]	4.73	4.30
H2O in fuel [%]	3.11	2.21
H2O from H2 in fuel [%]	3.42	4.21
H2O in air [%]	0.07	0.11
UBC [%]	1.50	1.50
Radiation [%]	0.11	0.12
Others [%]	0.51	0.78
Total losses [%]	13.45	13.20

Boiler Losses

Manual Inputs fuel data

Ready

5-Werte






REH Metal Temperature Calculation

Section view at 66.643 (8.000 below roof)

Measured values from DCS



Calculated values based on Geometrical dimensions like

- wall thickness
- tube diameter
- heated length of tubes

and actual values like

- outlet temp steam
- inlet temp. steam
- inlet temp. fluegas
- inlet flow steam
- total FG flow



Hot Spot Analysis Report

HOT SPOT Vindhyachal 9
7/13/2009 11:15:00 PM-11:20:00 PM

Platen SH	
SHPL highest temp	584 °C
SHPL highest temp slice	13
SHPL highest temp tube	4
SHPL highest temp length	0 m

Reheater	
REH highest temp	609 °C
REH highest temp slice	37
REH highest temp tube	9
REH highest temp length	0 m

Location and value of hotspots in heating surfaces

SH Division Panel	
SHDP highest temp	524 °C
SHDP highest temp slice	24
SHDP highest temp tube	2
SHDP highest temp length	0 m

LTSH	
LTSH highest temp	502 °C
LTSH highest temp slice	62
LTSH highest temp tube	2
LTSH highest temp length	0 m



THE BUILDING BLOCKS (BBs)

- *BB 1: PERFORMANCE ANALYSIS & MONITORING MODULE*
- *BB2: SYSTEM & PERFORMANCE OPTIMISATION*
- *BB3: BPOS (BOILER PERFORMANCE OPTIMISATION SYSTEM)*
- *BB4: BOILER STRESS CONDITION ANALYSER*
- *BB5: SYSTEM & PERFORMANCE DIAGNOSIS MODULE*
- *BB6: INTELLIGENT WATER & STEAM CHEM. MGT*



THE BUILDING BLOCKS (BBs)

- *BB 1: PERFORMANCE ANALYSIS & MONITORING MODULE*
- *BB2: SYSTEM & PERFORMANCE OPTIMISATION*
- *BB3: BPOS (BOILER PERFORMANCE OPTIMISATION SYSTEM)*
- *BB4: BOILER STRESS CONDITION ANALYSER*
- *BB5: SYSTEM & PERFORMANCE DIAGNOSIS MODULE*
- *BB6: INTELLIGENT WATER & STEAM CHEM. MGT*

BB-5: BOILER STRESS CONDITION ANALYSER



FEATURES:

- *CALCULATION OF CREEP & FATIGUE*
 - *DRUM*
 - *SH O/L HDR*
 - *RH O/L HDR*
 - *Y PIECE IN MS LINE*
- *REMAINING LIFETIME INDICATION*
- *LIST OF LARGE LOAD CHANGES*
- *ALLOWABLE OPERATING PARAMETERS*



Hourly values 4/29/2009 8:30:00 AM-9:30:00 AM

THICK WALL COMPONENTS CONSIDERED FOR LTC

steag SR1

ketek IT

BHEL Ramagundam 70

Overview Degradation

4/29/2009 8:30:00 AM-9:30:00 AM

Component	operating time [h]		life time consumption [%]			increment (24h)
	monitored	down time	creep	fatigue	total	
1. Drum 1, upper side 70HAD01	18899.3 h	4380.8 h	2.720 %	0.151 %	2.871 %	0.000159 %
2. Drum 1, lower side 70HAD01	18899.3 h	4380.8 h	3.099 %	0.099 %	3.198 %	0.000181 %
3. HRH1, outlet header, tee, upper side 70LBB01	18899.3 h	4922.4 h	0.977 %	0.000 %	0.977 %	0.000065 %
4. HRH1, outlet header, tee, lower side 70LBB01	18899.3 h	4922.4 h	1.055 %	0.000 %	1.055 %	0.000071 %
5. HRH1, outlet header, middle, lower side 70LBB01	18899.3 h	4922.4 h	3.319 %	0.000 %	3.319 %	0.000219 %
6. HRH1, outlet header, left, upper side 70LBB01	18899.3 h	4922.4 h	1.998 %	0.000 %	1.998 %	0.000133 %
7. HRH1, outlet header, left, lower side 70LBB01	18899.3 h	4922.4 h	3.319 %	0.000 %	3.319 %	0.000219 %
8. MSH1, outlet header, tee, upper side 70LBA01	18899.3 h	4381.1 h	1.356 %	1.202 %	2.557 %	0.000077 %
9. MSH1, outlet header, tee, lower side 70LBA01	18899.3 h	4381.1 h	4.245 %	1.202 %	5.447 %	0.000244 %
10. MSH1, outlet header, left, upper side 70LBA01	18899.3 h	4381.1 h	14.486 %	0.426 %	14.911 %	0.000836 %
11. MSH1, outlet header, left, upper side 70LBA01	18899.3 h	4381.1 h	14.486 %	0.426 %	14.911 %	0.000836 %
12. YP1, 70LBB01	18899.3 h	4807.7 h	1.673 %	0.001 %	1.674 %	0.000111 %
13. YP1, 70LBA01	18899.3 h	4381.1 h	1.397 %	2.620 %	4.017 %	0.000081 %
14. MSH1, outlet header, tee, lower side 70LBA01	18899.3 h	4381.1 h	4.245 %	1.202 %	5.447 %	0.000244 %



steag SR1

ketek IT

BHEL Ramagundam 70 Allowable Operating Parameters

5/20/2009 3:30:00 AM-4:30:00 AM


Measurement Values from
DCS

Component

Component	Pressure		Temperature		Difference of Temperature		
	allowable	current	allowable	current	upper allow.	current	lower allow.
1. Drum 1, upper side 70HAD01	200.0	176.4	370	356	15	-0	-43
2. Drum 1, lower side 70HAD01	200.0	176.4	370	356	12	-0	-45
3. HRH1, outlet header, tee, upper side 70LBB01	52.0	35.6	540	532	27	1	-32
4. HRH1, outlet header, tee, lower side 70LBB01	52.0	35.6	540	532	27	1	-32
5. HRH1, outlet header, middle, lower side 70LBB01	52.0	35.6	540	532	27	0	-31
6. HRH1, outlet header, left, upper side 70LBB01	52.0	35.6	540	532	27	0	-31
7. HRH1, outlet header, left, lower side 70LBB01	52.0	35.6	540	532	27	0	-31
8. MSH1, outlet header, tee, upper side 70LBA01	186.0	163.5	540	536	25	4	-33
9. MSH1, outlet header, tee, lower side 70LBA01	186.0	163.5	540	536	25	4	-33
10. MSH1, outlet header, left, upper side 70LBA01	186.0	163.5	540	536	25	3	-34
11. MSH1, outlet header, left, upper side 70LBA01	186.0	163.5	540	536	25	3	-34
12. YP 1, 70LBB01	52.0	35.6	540	532	27	0	-32
13. YP 1, 70LBA01	186.0	163.5	540	536	15	1	-26
14. MSH 1, outlet header, tee, lower side 70LBA01	186.0	163.5	540	536	25	4	-33



CONCEPT OF DATA VALIDATION





CONCEPT OF DATA VALIDATION

Final Value

The screenshot shows a software window titled 'ECON_M_T_FG_OUT_G' with two tabs: 'Dependencies' and 'Formula'. The tree view contains the following items:

- ECON_M_T_FG_OUT_G - avg. value - FG TMP AT ECO 0/1 - checked value [365 °C]
- ECON_M_T_FG_OUTL_G - FG TMP AFT ECO-3 (L) - checked value [365 °C]
- ECON_M_T_FG_OUTL_V - FG TMP AFT ECO-3 (L) - validated value [365 °C]
- ECON_M_T_FG_OUTL_P - FG TMP AFT ECO-3 (L) - plausible value [*** °C]
- ECON_M_T_FG_OUTL_N\$ - FG TMP AFT ECO-3 (L) - neural flag [-1 BIN]
- ECON_M_T_FG_OUTL - FG TMP AFT ECO-3 (L) [*** °C]
 - SHNA10CT101_XQ03 - FG TMP AFT ECO-3 (L) [*** °C]
 - ECON_M_T_FG_OUTL_N - FG TMP AFT ECO-3 (L) - neural value [343 °C]
- ECON_M_T_FG_OUTR_G - FG TMP AT ECO3-R - checked value [365 °C]
- ECON_M_T_FG_OUTR_P - FG TMP AT ECO3-R - plausible value [344 °C]
- ECON_M_T_FG_OUTR_N - FG TMP AT ECO3-R - neural value [343 °C]

Buttons for 'OK' and 'Cancel' are visible at the bottom.

Value After Heat Mass Balance

Value from Neural Network

Value After Range Check

DCS Value

SEAMLESS INTEGRATION OF PADO RESULTS AND RECOMMENDATIONS IN DCS HMI SCREENS



SEAMLESS INTEGRATION OF PADO RESULTS AND RECOMMENDATIONS IN DCS HMI SCREENS

[PADO RESULTS UNIT #9 - SET POINT OPTIMISATION]

TIME 21.09.11/18:40:00 Unit Load **487.61MW**

O2 AT ECONOMISER O/L	3.00%	REF TG HEAT RATE(GROSS)	2027.74kCAL/KV
BURNER TILT	7.00DEG	TG HEAT RATE(GROSS)	2054.62kcal/kWh
M S PRESSURE	168.71kg/cm²	TG HEAT RATE(ACTUAL)	2142.59kcal/kWh
M S TEMPERATURE	545.14°C	UNIT HEAT RATE NET	2492.97kcal/kWh
R H TEMPERATURE	544.53°C	UNIT HEAT RATE GROSS	2390.03kcal/kWh
UNIT HEAT RATE OPT	2387.64kCAL/KV		

MILL OPTIMISATION RECOMMENDATION

	CURRENT STATUS	CURRENT FLOW	OPTIMISED STATUS	OPTIMISED FLOW
MILL K	0.0	0.01 TPH	0.0 NO CHANGE	0.00 TPH
MILL J	0.0	0.00 TPH	0.0 NO CHANGE	0.00 TPH
MILL H	1.0	39.45 TPH	1.0 NO CHANGE	38.82 TPH
MILL G	1.0	38.18 TPH	1.0 NO CHANGE	38.18 TPH
MILL F	0.0	0.07 TPH	0.0 NO CHANGE	0.00 TPH
MILL E	1.0	50.13 TPH	1.0 NO CHANGE	50.13 TPH
MILL D	0.0	0.00 TPH	0.0 NO CHANGE	0.00 TPH
MILL C	1.0	53.43 TPH	1.0 NO CHANGE	53.43 TPH
MILL B	1.0	53.35 TPH	1.0 NO CHANGE	53.35 TPH
MILL A	1.0	53.59 TPH	1.0 NO CHANGE	54.29 TPH

PADO

18:54:25 21Sep11

Main	Last
SG	TC
Set	Trd
Point	Point
MS. TMP	539
MS. PR	171.8
HR. TMP	538
BU	1498
DR. LVL	-14.5
FW FL	1544
AIR FL	1685
DR. PR.	190.2
FUR. PR	-10.7
PA. HDR	829.9
COND. FL	1188
HW LVL	5.5
CD VAC	-0.87
TAG	Print
Silence	Alarm
Ack All	Ack Top
SOE	TRND BAR

FO APTAR	SEC AIR	SAIB	PAHA	MILL F-K	SL-SC FAN	BCW	TDHP-A	DEARLATOR	IP HTR	CRUSTRLET	COAL OV	OIL SUPPLY	GEN-SEAL	UNIT OVE
IDFA	IDFARS	PHAB	PAHB	GR CHL	CMC	DEHP-C	TDHP-B	HOTWELL	LP HTR	SHSTRAM	TUR EVAC	TUR C&E	GRN PR WTR	ICW-TDRY
IDFE	SAHA	PAFARB	MILL A-E	SADC	FW & DRUM	SDTC	COND CY	CEP	GRS400+	RHSTRAM	LPEP	TEI	CW&ACW	DM REACTS

COOLING TOWER CALCULATIONS




COOLING TOWER

The calculation is made by means of characteristics obtained from design data.

The characteristic curve defines the cooling zone width (or the cold-water-temperature) as a function of

- air moisture,
- air temperature,
- load factor (cooling water mass flow) and
- warm water temperature and Cold water temperature



12/20/2011 4:30:00 PM-4:35:00 PM

Status	Unit	Boiler	Measurements
	steady state	operating	okay
Generator el. output power gross			500 MW
Unit efficiency net			36.5 %
Unit heat rate gross			2264 kcal/kWh
TG heat rate net, actual			2017 kcal/kWh
Boiler efficiency			85.8 %
Station load			20.0 MW

Cooling Tower	Actual	Reference
Cooling zone width	12 K	9 K
Discharged heat	615 MW	
Warm water temperature	45 °C	
Cold water temperature	35 °C	33 °C
Evaporation	854 t/h	
Efficiency	129 %	

- reference value of cooling zone width
 - reference value of cold water temp
 - discharged heat
 - evaporation efficiency



THE BUILDING BLOCKS (BBs)


- *BB 1: PERFORMANCE ANALYSIS & MONITORING MODULE*
- *BB2: SYSTEM & PERFORMANCE OPTIMISATION*
- *BB3: BPOS (BOILER PERFORMANCE OPTIMISATION SYSTEM)*
- *BB4: CONTROL LOOP OPTIMISATION*
- *BB5: BOILER STRESS CONDITION ANALYSER*
- *BB6: SYSTEM & PERFORMANCE DIAGNOSIS MODULE*
- *BB7: INTELLIGENT WATER & STEAM CHEM. MGT*

BB-6: SYS & PERFORMANCE DIAGNOSIS



- *A SUPERVISORY MONITORING SYSTEM OVER AND ABOVE THE PLANT PERFORMANCE MONITORING SYSTEM.*
- *PERFORMS DIAGNOSIS OF SYSTEM & INDIVIDUAL EQUIPMENTS WITH ON-LINE DATA.*
- *THE PURPOSE OF THIS MODULE IS TO PIN-POINT ROOT CAUSE OF ABNORMALITIES EXISTING IN THE PROCESS.*

BB-6: SYS & PERFORMANCE DIAGNOSIS




GROUPS OF FAULT DIAGNOSIS TREES



- *Boiler System*
- *Turbine System*
- *Condenser System*
- *Feed Water System*
- *Regenerative Heating System*



The information contained in this document is the property of BHEL and is not to be used for any purpose other than for its intended use.





WS_LTSH_MTH

LTSH Mtl Temp High ← Fault observed

LTSH Mtl Temp High

LMTD for LTSH High

Alarm Messages

U3 BOILER Alarm Queue

Time	Sv	Alarm Message	Ack
14/2007 09:46:12	1	LTSH outlet hdr metal temp high: Check Measurements	Yes
14/2007 09:46:12	1	Unburnt Carbon Loss High. Maintain Fineness as recommended in Mill-K.	Yes
14/2007 09:38:33	1	LTSH outlet hdr metal temp high: Check Measurements	Yes

Strm Temp LTSH IL Low

SHMTH_ST_IL

Poor

RHPPP

Press Low

EB_LTSHMTH_MSPL Mg 7

Performance Diagnosis Module of P&ID



THE BUILDING BLOCKS (BBs)


- *BB 1: PERFORMANCE ANALYSIS & MONITORING MODULE*
- *BB2: SYSTEM & PERFORMANCE OPTIMISATION*
- *BB3: BPOS (BOILER PERFORMANCE OPTIMISATION SYSTEM)*
- *BB4: CONTROL LOOP OPTIMISATION*
- *BB5: BOILER STRESS CONDITION ANALYSER*
- *BB6: SYSTEM & PERFORMANCE DIAGNOSIS MODULE*
- *BB7: INTELLIGENT WATER & STEAM CHEM. MGT*

BB-7:INTELLIGENT WATER & STEAM CHEMISTRY MANAGEMENT



Water & Steam Cycle

- *Optimized consumption of dosing chemicals*
- *Reduction in degradation of turbine components*
- *Reduction of boiler tube scale formation*
- *Trending of parameters*






NTPC Korba Stage III - Trend Plot, Cation Conductivity

Trend Plot, Cation Conductivity, micro Siemens/cm

MW 500.0

30 Apr 2009 11:39:43 a.m.

Drum Pressure, kg/cm2 190.0



- 0.07
- 0.04
- 0.033
- 0.085
- 0.11
- 0.14



Parameters Limits

Parameters for Alarm queue

1. Boiler Water – pH 9.1-9.4
2. Boiler Water - Specific Conductivity < 20.0 micro-siemens/cm
3. Boiler Water - Silica < 100 ppb
4. Boiler Water - Phosphate 1000-2000 ppb
5. Boiler Water - Chloride < 0.5 ppm
6. Deaerator Outlet – Dissolved Oxygen < 7 ppb
7. Feed Water – Hydrazine 10-20 ppb
8. Feed Water – pH 9.0-9.2
9. Feed Water – Specific Conductivity 3-5 micro-siemens/cm
10. Feed Water – Cation Conductivity <0.2 micro-siemens/cm
11. Feed Water – Dissolved oxygen <=5 ppb
12. Main Steam – Specific Conductivity < 5 micro-siemens/cm
13. Main Steam – Cation Conductivity < 0.2 micro-siemens/cm
14. Main Steam – pH 9.0-9.2
15. Main Steam – Sodium < 10.0 ppb
16. Condensate Polisher Outlet – Sodium < 5 ppb
17. Condensate Polisher Outlet – Silica < 5 ppb
18. Condensate Polisher Outlet – Sp. Conductivity < 5 micro-siemens/cm
19. Condensate Polisher Outlet – pH 6.8-9.2
20. Condensate Polisher Outlet –Cation Conductivity <0.1 micro-siemens/cm
21. Hotwell Condensate Left– Sp. Conductivity 3-5 micro-siemens/cm
22. Hotwell Condensate Right– Sp. Conductivity 3-5 micro-siemens/cm
23. CEP Discharge – Cation Conductivity < 0.2 micro-siemens/cm
24. CEP Discharge – Sodium < 5 ppb
25. CEP Discharge – Dissolved Oxygen < 20 ppb
26. CEP Discharge – pH 9.0-9.2
27. CEP Discharge – Sp. Conductivity < 5 micro-siemens/cm
28. Saturated Steam – Sp. Conductivity 3-5 micro-siemens/cm



PADO FUNCTIONS IN PLANT DEPARTMENTS

MANAGEMENT:

- *Overview of efficiencies of the plant*

EFFICIENCY GROUP:

- *Monitoring efficiencies of important plant components*

OPERATION GROUP:

- *Following the indication for sootblowing*
- *Following the set point optimization*


MAINTENANCE MECHANICAL AND C&I GROUPS:

- *Monitoring of Measurements (Data Reconciliation)*



PADO FOR MANAGEMENT

PLANT OVERVIEW



PADO FOR MANAGEMENT REPORTS



DAILY REPORT							
Daily Efficiency Report for Vindhyachal Unit 9							
Date:		7/12/2009					
	Description	Unit	Availability (Hr)	No of samples	Average	Min	Max
1	UNIT ACTIVE POWER (AVG) - checked value	GJ/s	24.00	288	516.01	501.81	523.22
2	unit efficiency, net (calc.)	g/kg	21.08	253	33.82	33.21	34.54
3	unit heat rate, gross (calc.)	kcal/kWh	21.08	253	2440.78	2392.55	2481.11
4	boiler efficiency British standard (calc.)	%	21.08	253	83.04	79.73	86.74
5	dry gas loss (calc.)	%	21.08	253	7.76	4.54	10.68
6	loss due to moisture in fuel (calc.)	%	21.08	253	3.28	3.11	3.42
7	loss due to moisture in air (calc.)	%	21.08	253	0.13	0.07	0.17
8	loss due to unburnt carbon (calc.)	%	21.08	253	1.50	1.50	1.50
9	radiation loss (ABMA curve) (calc.)	%	21.08	253	0.11	0.11	0.11
10	other losses (sensible heat of ash etc.) (calc.)	%	21.08	253	0.57	0.50	0.63
11	total losses (calc.)	%	21.08	253	16.96	13.26	20.27
12	gross heat rate, actual (calc.)	kcal/kWh	21.08	253	1998.50	1922.78	2087.91
13	gross heat rate, actual (calc.)	kcal/kWh	21.08	253	2079.47	1995.00	2179.55
14	gross heat rate, reference (calc.)	kcal/kWh	17.92	215	1952.24	1885.83	2009.49



PADO FOR EFFICIENCY GROUP

BOILER EFFICIENCY

STEAG Ketek IT - PADO VINDHYACHAL 10 - [BPOS]

File Edit View Insert HTML-Lists Parameter Process Sheets Documentation Window Help

5-Write 7/12/2009 3:30:00 PM-3:35:00 PM

BPOS Backward Calculation Screen

Vindhyachal 10
7/12/2009 3:30:00 PM-3:35:00 PM

Load [MW]	516	Ambient air temperature [°C]	28
MS flow [t/h]	443	Relative humidity [%]	60
MS temp [°C]	540	Flue gas oxygen at Eco outlet	3.50
RH temp [°C]	539	Flue gas oxygen at AH outlet	4.78
		Burner tilt [°]	11
		Mills in operation	A on
			B on
			C on
			D on
			E off
			F on
			G off
			H on
			J off
			K off

Boiler thermal performance data							
Section	Flue gas temperature [°C]		Fluid temperature [°C]		Fouling factor	Zonal heat absorption [MW]	Maximum metal temperature [°C]
	Inlet	Outlet	Inlet	Outlet			
Economiser	526	342	260	323	0.88	138	
Waterwalls	1812	1334	359	359	0.88	418	
LTSH	819	526	359	437	0.85	232	462 °C
Panel SH	1334	1169	403	477	0.91	140	525 °C
Platen SH	1169	1071	477	540	1.01	89	585 °C
Reheater	1071	819	321	539	0.85	214	605 °C
Air heater	342	128			0.73	145	

Coal analysis	
Coal mass flow [t/h]	348
GCV [kcal/kg]	4000
Bottom ash removal rate [%]	20
Duct ash removal rate [%]	5
AH ash removal rate [%]	3
Fly ash removal rate [%]	72
UBC in ash [%]	2.4
Total moisture [%]	20.0
Ash [%]	30.7
Volatile matter [%]	xxx
Fixed carbon [%]	28.0
Ultimate	
Carbon [%]	40.5
Hydrogen [%]	2.4
Nitrogen [%]	0.9
Oxygen [%]	5.0
Sulphur [%]	0.5
Total moisture [%]	20.0
Ash [%]	30.7

Heat balance		
	Act	Ref
Boiler efficiency [%]	87.36	86.81
Losses		
Dry gas [%]	4.00	4.28
H2O in fuel [%]	3.08	2.21
H2O from H2 in fuel [%]	3.39	4.21
H2O in air [%]	0.06	0.11
UBC [%]	1.50	1.50
Radiation [%]	0.11	0.12
Others [%]	0.50	0.76
Total losses [%]	12.64	13.19



PADO FOR EFFICIENCY GROUP **CONTROLLABLE LOSSES**

Controllable Losses	Actual	Reference	HR Dev. [kcal/kWh]	Losses expr. in extra fuel	Monetary loss [Rs/h]
Throttle temperature	536 °C	537 °C	0.121	0.0 t/h	19
Throttle pressure	168 kg/cm ²	170 kg/cm ² a	3.152	0.5 t/h	508
Reheat temperature	536 °C	537 °C	-0.370	-0.1 t/h	-60
Reheat pressure drop	3.5 kg/cm ²	4.5 kg/cm ² a	-3.462	-0.5 t/h	-558
Condenser back pressure	-0.86 kg/cm ²	-0.89 kg/cm ²	39.789	5.8 t/h	6410
Superheater spray flow	105.9 t/h	8.3 t/h	4.700	0.7 t/h	757
Reheat spray flow	44.6 t/h	0.0 t/h	14.003	2.1 t/h	2256
Final FW temperature	260 °C	255.1 °C	0.249	0.0 t/h	40
Blow down flow	0.4 t/h	0.5 t/h	-0.047	-0.0 t/h	-8
Auxiliary steam flow	12.0 t/h	10.0 t/h	3.816	0.6 t/h	615
Frequency	49.70 Hz	50.00 Hz	0.021	0.0 t/h	8
Make-up flow	12.8 t/h	0.0 t/h	27.854	4.1 t/h	4487
TG heat rate gross, actual	2026 kcal/kWh		TG heat rate net, actual	**** kcal/kWh	
TG heat rate gross, reference	1966 kcal/kWh				


PADO FOR EFFICIENCY GROUP REPORTS



DAILY REPORT							
Daily Efficiency Report for Vindhyachal Unit 9							
Date:		7/12/2009					
	Description	Unit	Availability (Hr)	No of samples	Average	Min	Max
1	UNIT ACTIVE POWER (AVG) - checked value	GJ/s	24.00	288	516.01	501.81	523.22
2	unit efficiency, net (calc.)	g/kg	21.08	253	33.82	33.21	34.54
3	unit heat rate, gross (calc.)	kcal/kWh	21.08	253	2440.78	2392.55	2481.11
4	boiler efficiency British standard (calc.)	%	21.08	253	83.04	79.73	86.74
5	dry gas loss (calc.)	%	21.08	253	7.76	4.54	10.68
6	loss due to moisture in fuel (calc.)	%	21.08	253	3.28	3.11	3.42
7	loss due to moisture in air (calc.)	%	21.08	253	0.13	0.07	0.17
8	loss due to unburnt carbon (calc.)	%	21.08	253	1.50	1.50	1.50
9	radiation loss (ABMA curve) (calc.)	%	21.08	253	0.11	0.11	0.11
10	other losses (sensible heat of ash etc.) (calc.)	%	21.08	253	0.57	0.50	0.63
11	total losses (calc.)	%	21.08	253	16.96	13.26	20.27
12	gross heat rate, actual (calc.)	kcal/kWh	21.08	253	1998.50	1922.78	2087.91
13	gross heat rate, actual (calc.)	kcal/kWh	21.08	253	2079.47	1995.00	2179.55
14	gross heat rate, reference (calc.)	kcal/kWh	17.92	215	1952.24	1885.83	2009.49




PADO FOR OPERATION GROUP BOILER






PADO FOR OPERATION GROUP SOOTBLOWING MANAGEMENT





PADO FOR OPERATION GROUP SOOTBLOWING MONITORING





PADO FOR OPERATION GROUP METAL TEMPERATURES

STEAG Ketek IT - PADO VINDHYACHAL 10 - [HOTSPOT]

File Edit View Insert HTML-Lists Parameter Process Sheets Documentation Window Help

5-Werte 7/12/2009 3:30:00 PM-3:35:00 PM

HOT SPOT Vindhyachal 10
7/12/2009 3:30:00 PM-3:35:00 PM

Platen SH		Reheater	
SHPL highest temp	585 °C	REH highest temp	605 °C
SHPL highest temp slice	13	REH highest temp slice	37
SHPL highest temp tube	4	REH highest temp tube	9
SHPL highest temp length	0 m	REH highest temp length	0 m

SH Division Panel		LTSH	
SHDP highest temp	525 °C	LTSH highest temp	462 °C
SHDP highest temp slice	24	LTSH highest temp slice	62
SHDP highest temp tube	2	LTSH highest temp tube	2
SHDP highest temp length	0 m	LTSH highest temp length	0 m



PADO FOR OPERATION GROUP SET POINT OPTIMIZATION

STEAG Ketek IT - PADO WINDHYACHAL 10 - [Set]

File Edit View Insert HTML-Lists Parameter Process Sheets Documentation Window Help

5-Werte 7/12/2009 3:30:00 PM-3:35:00 PM

Vindhyachal 10
7/12/2009 3:30:00 PM-3:35:00 PM

Set point optimization

	act value	opt value
Boiler		
O2 at Eco outlet	3.47 %	3.00 %Vol
Burner tilt	11°	11°
Turbine Cycle		
MS temperature	539.53 °C	545.00 °C
MS pressure	170.62 kg/cm ²	170.00 kg/cm ²
Reheat temperature	538.85 °C	545.00 °C
Condenser back pressure	-0.86 kg/cm ²	-0.89 kg/cm ²
Windbox Furn. pressure	79.87 mmWC	89.74 mmWC
PA HDR Pressure	839.16 mmWC	800.05 mmWC
Unit Heat Rate gross	2351 kcal/kWh	2312 kcal/kWh



PADO FOR OPERATION AND EFFICIENCY GROUP

HEAT RATE POTENTIAL



13/01/2012

POWAT 2012

58



PADO FOR OPERATION/EFFICIENCY GROUP

WHAT-IF

Offline What-if Calculation Sheet V1.4 01.07.09						EVONIK Evonik Energy Services					Offline What-if Calculation Sheet V1.4 01.07.09				
NAME	UNIT	LIMITS LO UP	CURRENT VALUE	CASE STUDY	DATE 07/17/2009 16:05	GROUP	NAME	UNIT	CURRENT VALUE	CASE STUDY					
AUXILIARY POWER	MW	0 0	0.0	0.0 UNIT_M_FEL_SELF		WHATIF	STATUS	-	0	0					
MS TEMPERATURE	°C	482 509	535.8	540.0 HP1_M_T_MS		COAL	GENERATOR POWER	MW	508.80	508.73					
MS PRESSURE	kg/cm²	151 184	167.7	167.7 HP1_M_P_MS		STEAM OUTPUT CONDITIONS	COAL MASS FLOW	t/h	276.37	277.84					
RH TEMPERATURE	°C	484 591	537.3	537.3 IF1_M_T_RH			MS FLOW	t/h	1584.4	1578.3					
FV INPUT TEMPERATURE	°C	230 201	255	255 VSC0_R_T_FV			MS TEMPERATURE	°C	535.8	540.0					
HP HEATER 5 STATUS	-	0 1	1.0	1.0 HPHS_I_STA			RH TEMPERATURE	°C	537.3	537.3					
HP HEATER 6 STATUS	-	0 1	1.0	1.0 HPHS_I_STA		SPRAYS	RH SPRAY FLOW	t/h	68.70	68.70					
RH SPRAY FLOW	t/h	0 80	68.70	68.70 BOIL_M_FM_SF_RH			SH SPRAY FLOW	t/h	38.04	38.04					
SH SPRAY FLOW	t/h	0 50	38.04	38.04 DCS_M_TFM_SF_SH		AIR & FLUE GAS CONDITIONS	AIR MASS FLOW	t/h	1704.8	1703.8					
CW FLOW	m³/h	47542	43220	43220 COND_M_FV_CW			FG MASS FLOW	t/h	1937.5	1933.8					
CONDENSER BACK PRESSURE	kg/cm²	0.02 0.2	0.129	0.129 COND_M_P_2			FEGT	°C	1555.1	1553.8					
CW INLET TEMPERATURE	°C	20 40	31.71	31.71 COND_M_T_CW_INP			FG TEMP. AFT ECO	°C	382.59	381.37					
AMBIENT AIR TEMPERATURE	°C	15 40	26.57	26.57 PAFA_M_T_AR_INP		HEAT BALANCE	FG TEMP. AFT AH	°C	159.09	158.61					
AMBIENT RELATIVE HUMIDITY	%	10 100	60	60 RWB_P_PSI			BOILER EFFICIENCY	%	87.32	87.34					
O2 AFT ECO	%	2 5	3.28	3.28 BOIL_M_O2V_FG_AVG			DRY GAS	%	5.06	5.05					
O2 AFT PAHA	%	2 10	3.8	3.8 PAHA_M_O2V_FG_OUT			H2O IN FUEL	%	2.46	2.46					
UBC IN % GCY	%	0.11 50	0.71	0.71 BOIL_P_CUC_UC_LOSS		LOSSES	H2O FROM H2 IN FUEL	%	3.10	3.09					
AH ASH REMOVAL RATE	%	1 50	3.00	3.00 BOIL_P_CAA			H2O IN AIR	%	0.07	0.07					
BOTTOM ASH REMOVAL RATE	%	1 50	20.00	20.00 BOIL_P_CBA			UBC	%	0.71	0.71					
DUCT ASH REMOVAL RATE	%	1 50	5.00	5.00 BOIL_P_CUA			RADIATION	%	0.11	0.11					
FLY ASH REMOVAL RATE	%	0 100	72.00	72.00 BOIL_C_CFA			OTHERS	%	0.57	0.57					
GCY	kgal/kg	2500 8000	4399	4399.35 BOIL_P_HHV_CO			TOTAL LOSSES	%	12.09	12.06					
ASH	%	0.1 99	37.00	37.00 BOIL_P_CA		HEAT RATES	UNIT HEAT RATE GROSS	kcal/kWh	24218	24171					
TOTAL MOISTURE	%	0.1 99	17.00	17.00 BOIL_P_CVA			UNIT HEAT RATE NET	kcal/kWh	2548.1	2541.2					
CARBON	%	0.1 99	37.60	37.60 BOIL_P_CC			TG HEAT RATE GROSS	kcal/kWh	2056.2	2053.1					
HYDROGEN	%	0.1 99	2.38	2.38 BOIL_P_CH			TG HEAT RATE NET	kcal/kWh	2163.7	2159.8					
NITROGEN	%	0.1 99	0.92	0.92 BOIL_P_CN			HEATING SURFACE EFF.	MW	61.28	61.28					
OXYGEN	%	0.1 99	5.00	5.00 BOIL_P_CO			HEAT ABSORPTION	MW	439.29	441.71					
SULPHUR	%	0.01 99	0.10	0.10 BOIL_P_CS			FLUE GAS TEMP. INLET	°C	2152.90	2149.93					
BURNER TILT	GRAD	-30 30	-3.61	-3.61 BOIL_M_BT		FURNACE	FLUE GAS TEMP. OUTLET	°C	1555.03	1553.76					
MILL A IN OPERATION	-	0 1	1	1 MLLA_I_STA			FLUID TEMP. INLET	°C	359.43	359.38					
MILL B IN OPERATION	-	0 1	1	1 MLLB_I_STA			FLUID TEMP. OUTLET	°C	359.43	359.37					
MILL C IN OPERATION	-	0 1	1	1 MLLC_I_STA			HEATING SURFACE EFF.	%	71.12	71.12					
MILL D IN OPERATION	-	0 1	1	1 MLLD_I_STA			HEAT ABSORPTION	MW	144.92	145.71					
MILL E IN OPERATION	-	0 1	1	1 MLLE_I_STA		PANEL SH	FLUE GAS TEMP. INLET	°C	1555.03	1553.76					
MILL F IN OPERATION	-	0 1	1	1 MLLF_I_STA			FLUE GAS TEMP. OUTLET	°C	1551.68	1550.41					
MILL G IN OPERATION	-	0 1	1	1 MLLG_I_STA			FLUID TEMP. INLET	°C	338.97	331.83					
MILL H IN OPERATION	-	0 1	0	0 MLLH_I_STA			FLUID TEMP. OUTLET	°C	470.60	469.36					
MILL J IN OPERATION	-	0 1	1	1 MLLJ_I_STA			HEATING SURFACE EFF.	%	65.46	110.01					
MILL K IN OPERATION	-	0 1	0	0 MLLK_I_STA			HEAT ABSORPTION	MW	36.30	104.26					
BLOWDOWN FLOW	t/h	1 10	63.27	63.27 BOIL_C_FM_BD		PLATEN SH	FLUE GAS TEMP. INLET	°C	1351.68	1350.41					
GENERATOR H2 PRESSURE	kg/cm²	1 5	3.45	3.45 GENV_M_P_H2			FLUE GAS TEMP. OUTLET	°C	1625.45	1616.90					
FREQUENCY	Hz	47.5 51.5	49.35	49.35 GENV_M_FG			FLUID TEMP. INLET	°C	470.60	469.36					
AIR HEATER LEAKAGE	t/h	50 400	341.33	341.33 AH00_C_FM_LEAK			FLUID TEMP. OUTLET	°C	541.17	545.41					
HP EFFICIENCY	%	76.3 93.2	84.74	84.74 HP1_C_EFF			HEATING SURFACE EFF.	%	65.24	65.24					



PADO OPERATION/EFFICIENCY GROUPS

WHAT-IF

Microsoft Excel - SR4WhatIf.xls

File Edit View Insert Format Tools Data Window Help SRx WhatIf?

B66

GROUP	NAME	UNIT	CURRENT VALUE	CASE STUDY	SR4-NAME
WHATIF	STATIIS	-	n	n	what_if_status
	GENERATOR POWER	MW	506.80	506.73	UNIT_M_PEL_GRS
COAL	COAL MASS FLOW	t/h	278.37	277.84	BOIL_M_FM_CO
	MS FLOW	t/h	1584.4	1578.9	BOIL_M_FM_MS
STEAM OUTPUT CONDITIONS	MS TEMPERATURE	°C	535.8	540.0	HP1_M_T_MS
	RH TEMPERATURE	°C	537.3	537.3	IP1_M_T_RH
SPRAYS	RH SPRAY FLOW	t/h	68.70	68.70	BOIL_M_FM_SF_RH
	SH SPRAY FLOW	t/h	98.04	98.04	BOIL_M_FM_SF_SH
AIR & FLUE GAS CONDITIONS	AIR MASS FLOW	t/h	1726.2	1722.9	BOIL_M_FM_AR_TOT
	FG MASS FLOW	t/h	1937.5	1933.8	BOIL_C_FM_FG
	FEGT	°C	1555.1	1553.8	FURN_C_T_FG_OUT
	FG TEMP. AFT ECO	°C	382.59	381.37	ECON_M_T_FG_OUT
	FG TEMP. AFT AH	°C	159.09	158.61	AH00_C_T_FG_OUT
HEAT BALANCE	BOILER EFFICIENCY	%	87.92	87.94	BOIL_C_EFF_BS
	DRY GAS	%	5.06	5.05	BOIL_C_DG_LOSS
	H2O IN FUEL	%	2.46	2.46	BOIL_C_CWA_FU_LOSS
	H2O FROM H2 IN FUEL	%	3.10	3.09	BOIL_C_CH_FU_LOSS
	H2O IN AIR	%	0.07	0.07	BOIL_C_CWA_AR_LOSS
	UBC	%	0.71	0.71	BOIL_C_CUC_UC_LOSS
	RADIATION	%	0.11	0.11	BOIL_C_RAD_LOSS
	OTHERS	%	0.57	0.57	BOIL_C_OTH_LOSS
	TOTAL LOSSES	%	12.06	12.06	BOIL_C_TOT_LOSS
HEAT RATES	UNIT HEAT RATE GROSS	kcal/MWh	2421.6	2417.1	UNIT_C_HCS_GRS
	UNIT HEAT RATE NET	kcal/MWh	2548.1	2541.2	UNIT_C_HCS_NET
	TG HEAT RATE GROSS	kcal/MWh	2056.2	2053.1	WSC0_C_HCS_GRS
	TG HEAT RATE NET	kcal/MWh	2163.7	2158.8	WSC0_C_HCS_NET
FURNACE	HEATING SURFACE EFF.	%	61.28	61.28	FURN_C_PFF
	HEAT ABSORPTION	MW	439.29	441.71	FURN_C_Q
	FLUE GAS TEMP. INLET	°C	2132.90	2148.89	FURN_C_T_FG_ADB
	FLUE GAS TEMP. OUTLET	°C	1555.09	1553.76	FURN_C_T_FG_OUT
	FLUID TEMP. INLET	°C	359.43	359.38	FURN_C_T_INP
	FLUID TEMP. OUTLET	°C	359.43	359.37	FURN_C_T_OUT
	HEATING SURFACE EFF.	%	71.12	71.12	SHDP_C_PFF

Ready



CASE STUDIES

- SET POINT OPTIMIZATION
- HPH DRAIN TEMPERATURE

SET POINT OPTIMIZATION EXPERIMENT- RAMAGUNDAM

File Edit View Insert HTML-Lists Parameter Process Sheets Documentation Window Help
 5-values 23/05/2008 18:25:00-18:30:00

Set point optimization

Ramagundam 7

	act value	opt value
Boiler		
O2 at Eco outlet	3.99 %	5.00 %Vol
Burner tilt	10°	10°
Turbine Cycle		
MS temperature	536.50 °C	545.00 °C
MS pressure	171.72 kg/cm ²	170.00 kg/cm ²
Reheat temperature	530.93 °C	545.00 °C
Condenser back pressure	-0.87 kg/cm ²	-0.87 kg/cm ²
Windbox Furn. pressure	76.80 mmWC	89.74 mmWC
PA HDR Pressure	812.92 mmWC	800.1
Unit Heat Rate gross	2396.19	2337

Initial condition

LOAD=511 MW

Coal Mass Flow=391.6T/Hr

Unit Efficiency = 34.8

Boiler Efficiency = 87.1

Econ. O/L Temp. = 338.85 °C

FEGT = 1204 °C

File Edit View Insert HTML-Lists Parameter Process Sheets Documentation Window Help
 5-values 23/05/2008 18:45:00-18:50:00

Set point optimization

Ramagundam 7

Parameters changed

	act value	opt value
Boiler		
O2 at Eco outlet	4.36 %	5.00 %Vol
Burner tilt	13°	13°
Turbine Cycle		
MS temperature	542.09 °C	545.00 °C
MS pressure	168.66 kg/cm ²	170.00 kg/cm ²
Reheat temperature	536.23 °C	545.00 °C
Condenser back pressure	-0.87 kg/cm ²	-0.87 kg/cm ²
Windbox Furn. pressure	85.45 mmWC	89.74 mmWC
PA HDR Pressure	805.19 mmWC	800.1
Unit Heat Rate gross	2335.17	2329

LOAD=504 MW

Coal Mass Flow=391.35T/Hr

Unit Efficiency = 35.7

Boiler Efficiency = 86.6

Econ. O/L Temp. = 340.05 °C

FEGT = 1187 °C

SAVING

10 T/Hr

240 T/Day

Rs 240000/- per day

Taking Coal price as Rs 1000/- per Tonne as of July'08




CASE STUDY FOR HPH DRAIN TEMPERATURE

STEAG Ketek IT - PADO Ramagundam 7 - [HP]

File Edit View Insert HTML-Lists Parameter Process Sheets Documentation Window Help

values 5/19/2009 3:30:00 PM-3:35:00 PM




Ramagundam 7 5/19/2009 3:30:00 PM-3:35:00 PM			
Status	Unit	Boiler	Measurements
steady state		operating	look status
Generator el. output power gross			529 MW
Unit efficiency net			36.4 %
Unit heat rate gross			2298 kcal/kWh
Boiler Load Index			1607.58 t/h
Boiler efficiency			87.2 %
Station load			15.0 MW
High pressure heater		TTD actual	TTD reference
on	HPH 6A	-1.42 K	0.20 K
on	HPH 6B	-3.06 K	0.20 K
on	HPH 5A	-1.05 K	0.25 K
on	HPH 5B	-4.13 K	0.25 K
High pressure heater:		DCA actual	DCA reference
	HPH 6A	6.19 K	5.22 K
	HPH 6B	5.00 K	5.22 K
	HPH 5A	5.64 K	4.92 K
	HPH 5B	6.16 K	4.92 K

case	pump in operation	max load per pump	recommended load distribution
1	1	990 t/h	1 x [] t/h
2	2	990 t/h	2 x [823 t/h]






CASE STUDY FOR HPH DRAIN TEMPERATURE





GRAPHICAL PLOT OF THE ABOVE CASE STUDY


HPH DRAIN TEMPERATURE





GRAPHICAL PLOT OF THE ABOVE CASE STUDY

HPH DRAIN TEMPERATURE






DATA EXPORT FACILITY FROM DIAGRAM TO EXCEL

2.168.120.254 - Terminal Services Client

AG Ketek IT - PADO Ramagundam 7 - [Diagram1]





DATA EXPORT FACILITY FROM DIAGRAM TO EXCEL

Microsoft Excel - Book1

File Edit View Insert Format Tools Data Window Help

D13 14.292977

	A	B	C	D	E	F	G
1	Time	BOIL_M_T_MS_G	BOIL_M_P_MS_G	BOIL_C_FM_SF_SH	BOIL_C_FM_SF_RH	FURN_C_T_FG_OUT	UNIT_M_PEL_GRS_G
2	3/26/2009 11:15	541.540031	171.737078	0.000007	28.599163	1273.947654	518.038725
3	3/26/2009 11:20	545.98328	171.983408	14.593378	28.667549	1291.655681	519.190588
4	3/26/2009 11:25	540.215661	173.014665	18.065099	28.714936	1284.209713	520.893648
5	3/26/2009 11:30	543.734656	171.100809	13.445369	28.636903	1284.592661	517.205509
6	3/26/2009 11:35	543.652048	171.692085	10.465426	28.579191	1285.32054	517.840951
7	3/26/2009 11:40	543.637352	172.198211	16.781962	28.657268	1293.927173	520.410201
8	3/26/2009 11:45	543.458054	171.790413	6.902958	28.571646	1295.323332	518.401331
9	3/26/2009 11:50	545.432136	170.787374	13.881216	28.367076	1294.29108	517.207353
10	3/26/2009 11:55	542.210936	172.072001	29.415827	28.465363	1301.950066	520.415682
11	3/26/2009 12:00	543.428051	172.136387	22.663056	28.488451	1297.320822	519.481763
12	3/26/2009 12:05	543.820996	171.94005	14.386503	28.508104	1293.857271	518.868278
13	3/26/2009 12:10	546.031558	169.946318	14.292977	75.979686	1281.920383	515.387069
14	3/26/2009 12:15	543.843851	172.08316	42.419206	28.466487	1307.149516	520.679382
15	3/26/2009 12:20	537.797214	173.363604	29.57972	28.637625	1304.251298	521.439368
16	3/26/2009 12:25	540.625729	171.048897	20.411498	28.418703	1294.324915	516.711084
17	3/26/2009 12:30	546.85449	170.896506	29.488038	28.388178	1299.958023	518.857292
18	3/26/2009 12:35	539.683249	173.461177	37.347786	75.979686	1304.983835	521.424723
19	3/26/2009 12:40	541.013951	172.384748	23.732828	75.979686	1291.463019	519.124658
20	3/26/2009 12:45	545.835608	171.812482	2.87457	75.979686	1288.153614	519.071558
21	3/26/2009 12:50	543.354289	170.989558	27.356533	75.979686	1289.126828	517.40695
22	3/26/2009 12:55	546.39116	170.61587	9.356384	75.979686	1288.777811	516.37961
23	3/26/2009 13:00	544.219192	172.440259	25.316578	75.979686	1299.327807	521.01818
24	3/26/2009 13:05	542.755681	173.27977	18.567395	75.979686	1290.047452	520.767293
25	3/26/2009 13:10	544.493187	172.19304	24.155994	75.979686	1288.449522	519.243681
26	3/26/2009 13:15	544.932787	173.547018	29.705701	75.979686	1299.378103	522.349488
27	3/26/2009 13:20	543.106319	173.126972	24.012039	75.979686	1291.551745	519.659391
28	3/26/2009 13:25	545.078117	169.684793	29.373211	75.979686	1285.837594	511.744718
29	3/26/2009 13:30	546.120826	171.826217	51.500223	75.979686	1308.454941	522.173706
30	3/26/2009 13:35	538.498208	171.268256	36.252325	75.979686	1283.515171	519.529374
31	3/26/2009 13:40	545.437092	167.62292	24.947616	75.979686	1270.044194	509.924465
32	3/26/2009 13:45	547.196403	169.363753	33.490689	75.979686	1285.719919	515.301017
33	3/26/2009 13:50	539.0231	171.920639	38.807205	75.979686	1287.141034	521.007194

PADO PROJECTS IMPLEMENTATION BY BHEL

UNIT RATING	NO OF SETS	CUSTOMERS
490/500	46	NTPC, KPCL, MAHAGHENCO, GEB, CSEB
525	4	TATA POWER, HNPL
600	5	TNEB, MPEB, APGENCO
195/250	9	NTPC
660, 700 (Super critical)	3	NTPC, KPCL



PADO REMOTE CONNECTIVITY TO VARIOUS SITES

The Remote Connectivity to sites is through the ISDN line. The PADO Server at the site can be accessed from EDN, Bangalore. Following sites are now remotely connected to EDN, Bangalore:

- SIMHADRI
- RAMAGUNDAM
- RIHAND
- VINDHYACHAL
- TALCHER
- SIPAT
- BELLARY
- DADRI
- KORBA



THANK YOU

