

Water Coordinator's Report June 21, 2025

Water System Report

a) abnormal/unusual usage reports-none

b) water quality reports all is normal

c) a description of any notable repairs and maintenance activities

In April, the electrical box at well number two was replaced and wiring updated. At that time a leak was found above ground and so well number two was capped off in the well house and shut off so repairs could be made. By April 23 the repairs to the pipes were completed.

A system flush was completed in May.

Todd Albi reported yesterday that his water was brown and cloudy. I was out of town and unable to contact NWNWS. I will call them on Monday to find out the problem.

d) notice of upcoming system activities and/or maintenance.

Coming up later in the summer will be a reservoir cleaning.

A clean-up of the grounds around the well house will be done later in June or early July.

e) The Management Program Binder for our water system needs to be updated. I would like the board to begin a search for a new water coordinator. I will be retiring by the end of the year. It would be nice if the new water coordinator would be found soon, so we could work on the updates together.