



*Certificate of Analysis*

**Client:**  
Combustion Technologies  
179 E Main Street  
Sandy, Utah 84070

**Test Control #'s:**  
V7022813  
V7024995

**Dates:**  
Received: 10/20/2015  
Report Date: 10/26/2015

**Remarks:**  
Baseline #2 Diesel (Sinclair Fuel)  
Test: Baseline #2 Diesel + CleanBoost SnoCat (rev) ratio (1:2000)

<u>ASTM Method</u>	<u>Test Description</u>	<u>Base Fuel</u>		<u>CleanBoost SnoCat (rev): (1:2000)</u>	
D97 Degrees C	Pour Point °C	-22		-42	Not Tested
D97 Degrees F	Pour Point °F	-8		-44	Not Tested
D2500 Degrees C	Cloud Point °C	-12		-20	Not Tested
D2500 Degrees F	Cloud Point °F	10		-4	Not Tested
D6371 Degrees C	Cold Filter Plugging °C	-18		-41	Not Tested
D6371 Degrees F	Cold Filter Plugging °f	-2		-42	Not Tested

**Note:** Results appear acceptable for this specific fuel, results may vary depending on fuel supplier and base stock fuel.

**Lab Analyst:** Bobby Licu (Evaluations Manager)