



# Karnataka Material Testing & Research Centre

(ASSISTED BY GOVT. OF KARNATAKA & GOVT. OF INDIA)



G-4 & 5, Industrial Estate, Gokul Road, HUBLI-580 030 (Karnataka)  
 Tel. : 0836 - 2330423 Cell: 09448124486 • Email : kmtrc\_hubli96@yahoo.co.in  
 Website : www.materialtestinghubli.com

**NABL ACCREDITED, BIS RECOGNISED, ISO 9001 CERTIFIED LABORATORY**

## DRINKING WATER CERTIFICATE

### CHEMICAL TEST REPORT

Sheet No. 1 of 1

Customer : <b>J.K. Education Society (R),</b> Smt. Drakshyani Kalyanshetkar Public School, Shakti Colony, Near Adhyapaknagar, HUBLI - 580 031.		Report No. : <b>KMTRC/20-21 / 366 / Aa</b> Date of Issue : 21.01.2021 Date of Test : 20.01.2021 Tested at : KMTRC Y/R No. & Date : DK/19/2020-21 / 18.01.2021 Date of Receipt : 19.01.2021	
Sample Details : Material / Speciman :	Water Sample - Drinking Water		
Test Device Details :	Instruments & Volumetric		
Test Details :			
Sl. No.	PARAMETER	STANDARD REQUIREMENT IS : 10500 : 1991	ACTUAL
1.	Hydrogen Ion Concentration (pH)	6.50 TO 8.50	7.70 at 25.0 <sup>o</sup> C
2.	Electric Conductivity (EC)	-- --	237.00 $\mu$ S at 25.0 <sup>o</sup> C
3.	Total Dissolved Solids mg / l, max (TDS)	-- 500.00	154.00 ppm at 25.0 <sup>o</sup> C
4.	Calcium mg / l, max (Ca)	-- 075.00	21.60 mg/ltr
5.	Magnesium mg / l, max (Mg)	-- 030.00	10.69 mg/ltr
6.	Total Hardness mg / l, max (TH)	-- 300.00	98.00 mg/ltr
Other Details :			
1. Procedure Used : IS:3025			
<b>REMARK :</b>			
STATEMENT : 1) This report should not be reproduced except in full without written approval of the laboratory. 2) The test results relate only to the items/samples tested. 3) Feed back complaints if any, to be intimated within 10 days from date of receipt of the Test Report / Calibration Certificate			
for <b>KARNATAKA MATERIAL TESTING &amp; RESEARCH CENTRE,</b>			
Tested by / Checked by: 		Approved by: 	
NAME : T.A. Hebbar Designation : Chemical Head		N.H. Kulkarni Quality Manager	

Format : KMT/CHEM/F/01 Rev 01





SANITARY CONDITION CERTIFICATE

No. HDMC-06/SCE/01

Date: 28-01-2021

It is certified that an inspection team headed by NAZIYA JIFATH,  
Environmental Engineer (Name of Officers  
with designation) from HDMC, Zonal office - 06 (Name of  
Department/Office) inspected the JK Education Society (R) - Smt. Drakshayani  
Kalyanshettar Public School, Shakti Colony, Hubli. (Name & Address of the School) on  
25-01-2021 and found that the Smt. Drakshayani Kalyanshettar Public School,  
Shakti Colony, Hubli. (Name of school) facilities for the students and members of staff of the  
institution and is maintaining the hygienic sanitation condition in the school building & the campus  
as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of One year.

Signature with Seal: [Signature]

Name : NAZIYA JIFATH

Designation : Environmental Engineer  
Environmental Engineer  
S. W. M. Dept.  
H. D. M. C. HUBLI

To

JK Education Society (R)  
Smt. Drakshayani Kalyanshettar Public School,  
Shakti Colony, Hubli.

(Name & Address of the Institution)