

WATERFALL HIGH RISE  
FIRE SPRINKLER SYSTEM  
HOUSING AUTHORITY OF THE CITY OF ELKHART

Elkhart, Indiana

ADDENDUM NO. 2

May 17, 2024

THIS ADDENDUM TO THE DRAWINGS AND SPECIFICATION IS ISSUED TO MODIFY, CLARIFY, OR CORRECT THE CONSTRUCTION DOCUMENTS AND IS HEREBY PART OF THE BIDDING DOCUMENTS.

**CLARIFICATION**

1. **Bid Date** has been changed from May 21, 2024 @ 3:00 pm. to **June 5, 2024 @ 3:00 pm.**

**SPECIFICATIONS**

None

**DRAWINGS**

Drawing Sheet: ME200

1. In the General Fire Protection Notes:
  - a. Add the following to Note 14. System design may be based on either one or two zones per floor. The system may also be looped if this can be coordinated with the Housing Authority to minimize disruption to building occupants.
  - b. Add the following Note 22: All piping shall be pre-painted, or field painted "safety red" or similar. This includes degreasing and painting of existing fire protection piping if reused.
  - c. Add the following Note 23: penetrations through walls to be caulked (coordinate color with Architect. Penetrations through corridor and stairwell walls shall be fire caulked. Where penetrations are core drilled through concrete, sleeving is not required.
  - d. Add the following Note 24: final design shall be based on the maximum fire pump horsepower noted on the drawings. If the bidder believes that this cannot be achieved, notify the Architect prior to bidding.

END OF ADDENDUM NO. 2