



Tentative Interim Amendment

NFPA 58

Liquefied Petroleum Gas Code

2008 Edition

Reference: 5.2.1.5 (New)

TIA 08-2

(SC 07-10-4/TIA Log #884)

Pursuant to Section 5 of the NFPA Regulations Governing Committee Projects, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 58, *Liquefied Petroleum Gas Code*, 2008 edition. The TIA was processed by the Technical Committee on Liquefied Petroleum Gases, and was issued by the Standards Council on October 4, 2007, with an effective date of October 24, 2007.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedures. It is interim because it is effective only between editions of the standard. A TIA automatically becomes a proposal of the proponent for the next edition of the standard; as such, it then is subject to all of the procedures of the standards-making process.

1. *Add the following text to NFPA 58:*

5.2.1.5 Except for containers used in cargo tank vehicle service, ASME containers of 3,000 gallons water capacity or less used to store anhydrous ammonia shall not be converted to LP-gas fuel service.

2. *Renumber current 5.2.1.5 through 5.2.1.9 as 5.2.1.6 through 5.2.1.10.*

Issue Date: October 4, 2007

Effective Date: October 24, 2007