

ADALET

A SCOTT FETZER COMPANY



SWITCHRACKS

Equipment Racks with NEMA 4/4X and NEMA 7/9 Explosionproof Classified Enclosures

FEATURES

- Wide variety of explosionproof motor control assemblies and panelboards
- Rugged frame and canopy design provide heavy duty protection and construction
- Single or double-sided assemblies are available in single or double rows
- Pre-drilled bus boxes provide easy-access changes and upgrades
- Premium, high strength stainless steel cover bolts
- Standard drawings of complete switchrack design provides detail on all enclosures, frame, canopy and wiring

MATERIALS

- All welded construction - sheet aluminum, stainless steel or sheet metal
- Rack Frame - hot dipped galvanized, structural steel
- Optional corrosion resistant primer and epoxy coating

CERTIFICATIONS

- Class I, Division 1, Gas Groups B, C, D
- Class II, Division 2, Gas Groups E, F, G
- Class III
- NEMA 4, 4X, 7BCD, 9EFG

CUSTOMER INFORMATION

DATE: _____ CONTACT NAME: _____
 CITY: _____ STATE: _____ PROJECT NAME: _____
 CONTACT PHONE: _____ CONTACT EMAIL: _____

Area Classifications for Enclosures:

Hazardous:
 Class: _____, Division: _____
 Group: _____
 Non-Hazardous:
 Ordinary Locations:
 NEMA 3R / 4 / 4X (circle one)

Switchrack Structural Frame:

_____ Steel - Hot Dipped Galvanized
 _____ Aluminum, not finished
 _____ Channel Feet Square Feet
 _____ Double Row
 _____ Single Row
 _____ Double Sided
 _____ Single Sided

Canopy:

_____ Painted Steel
 _____ Galvanized Steel
 _____ None

Roof Material: Corrugated:

Canopy and light fixtures will ship loose, due to height restrictions on motor transport.
 _____ Galvanized Steel
 _____ Aluminum

Rigid Conduit and Fittings:

_____ Galvanized Steel
 _____ Aluminum
 _____ PVC Coated
 _____ Non-Drain Type
 _____ Drain Type

Incoming Power Supply:

_____ Volts _____ Phase _____ Wire _____ Hz

Bus Enclosures:

_____ Painted Steel
 _____ Galvanized Steel
 _____ Aluminum
 _____ Stainless Steel
 _____ Amp Rating
 _____ Type

Bus Bar Modifications:

_____ Silver Plated _____ Tin Plated
 _____ Insulated

Optional Equipment: Provide detailed information

Motor Starters: _____

Panelboards: _____

Circuit Breakers/ Disconnects: _____

Distribution Transformers: _____

Receptacles: _____

Lighting Fixtures: _____

Control Stations: _____

FAX BACK QUOTE FORM

To receive an equipment quotation, please complete the information sections on this page and fax it to 216.267.1681