

## SECTION 00 91 11

### ADDENDUM NUMBER 2

#### PARTICULARS

- 1.01 DATE: MAY 18, 2018
- 1.02 PROJECT: AUSTIN HIGH SCHOOL CAREER TECH CENTER
- 1.03 PROJECT NUMBER: B. C. NO. 2018112
- 1.04 OWNER: DECATUR CITY SCHOOLS
- 1.05 ARCHITECT: NOLA | VAN PEURSEM ARCHITECTS, PC

#### TO PROSPECTIVE BIDDERS

- 2.01 THIS ADDENDUM FORMS A PART OF THE CONTRACT DOCUMENTS AND MODIFIES THE BIDDING DOCUMENTS DATED APRIL 25, 2018, WITH AMENDMENTS AND ADDITIONS NOTED BELOW.
- 2.02 ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED IN THE PROPOSAL FORM. FAILURE TO DO SO MAY DISQUALIFY THE BIDDER.
- 2.03 THIS ADDENDUM CONSISTS OF 2 PAGES.

#### CHANGES TO THE PROJECT MANUAL

- 3.01 APPROVED EQUALS, these approvals are based solely upon the manufacturers meeting all conditions of drawings and specifications presently set.

- A. Drawing E0.1: Fixture Schedule equals – The following Fixture Manufacturers and fixtures are approved to bid as equals:

Type	MFG	Part
RL1	ELITE LED LIGHTING	24-FPL1-LED-5000L-DIM10-MVOLT-40K-85
RL2	ELITE LED LIGHTING	22-FPL1-LED-5000L-DIM10-MVOLT-40K-85
RL3	ELITE LED LIGHTING	24-OT-LED-8000L-DIM10-MVOLT-40K-85-A19 & A-SFW-GDF-24-FA-DF
RC6	PATHWAY LIGHTING PRODUCTS	6VFL2X30004KD8/6VLEDMDSCLPF
LS	ELITE LED LIGHTING	4-OC4-LED-5000L-DIM10-MVOLT-40K-85
EM1	MULE LIGHTING, INC.	TSR-HO-W-SD
XC	MULE LIGHTING, INC.	SQC-LED-1-R-WW-SD
XD	LUMINAIRE	YWP1212-25W-4000K-120-277-CP-FINISH-PC-EMB310 /TX/SD
X1	MULE LIGHTING, INC.	MXBRUSD
P2\$	INTELLIGENT LIGHTING CONTROL	LS-G2-FINISH-2
P3\$	INTELLIGENT LIGHTING CONTROL	LS-G2-FINISH-3
\$OS	LEVITON	OSSMT-MD-FINISH
OS	LEVITON	OSC20-M0W
VS	LEVITON	OSC20-M0W
DP	INTELLIGENT LIGHTING CONTROL	R20D
RP	INTELLIGENT LIGHTING CONTROL	R20D
H	INTELLIGENT LIGHTING CONTROL	LL-EVO

**3.02 SECTION 00 22 00-OWNER'S SUPPLEMENTARY INSTRUCTIONS TO BIDDERS:**

- A. Paragraph 1.03.A – Change paragraph to read as follows, “All sealed bids containing two copies of the Proposal Form, two copies of the Bid Bond, and one copy of Supplement C - List of Alternates (Section 00 43 23) will be received by 2:00 p.m. CDT on **May 29, 2018**. Upon receipt of these documents the bids will be publicly opened and read aloud. Supplement A – List of Subcontractors (section 00 43 21) is to be hand delivered or emailed to the Architect within 24 hours after receipt of bids. No changes to the base bid will be allowed after 2:00 p.m.

**CHANGES TO THE DRAWINGS**

**4.01 SHEET E-0.1 - ELECTRICAL LEGEND:**

- A. Panelboard Schedule:
1. Panel MP (277/480V, 3p, 4w) Furnish and install 30/3 breaker, Furnish and install Surge Suppression Inc #CMLA3Y2-21 or pre-approved equal unit and connect as required.
  2. Panel PP (120/208V, 3p, 4w), Furnish and install 30/3 breaker, Furnish and install Surge Suppression Inc #CKLA3Y1-21 or pre-approved equal unit and connect as required.

**END OF ADDENDUM NUMBER 2**