

# Technical Bulletin

Copyright 2005 by Air Options, Inc.

## Actual Moisture Content in Compressed Air at Specific Dew Points


For the average compressed air user the measurement of water content in the system is usually indicated in dew point. Simply stated, dew point is the temperature at which the water vapor in compressed air will start to condense, hence its indication in °F or °C. The most significant problem with using dew point as an indicator of water content is that it references a logarithmic scale. That is to say, that as the dew point temperature lowers, the water content in the compressed air drops at a decreasingly lower rate. As an example, the percentage difference of water vapor between 100°F and 50°F is 5.2%. The percentage difference between 50°F and 38°F is just .3%. The temperature difference seems like a large amount, however, the actual difference in water content is, practically speaking, insignificant. This is the very reason that most refrigerated dryers are rated at both 50°F and 38°F. In most cases achieving an additional .3% reduction in moisture content is simply not worth the additional equipment, operating and maintenance costs associated with the lower temperature.

Most compressed air applications are considered general purpose in nature. A 50°F dew point is perfectly adequate for these applications. Lower dew points are generally not necessary and the additional expense for achieving them is unwarranted. The chart below shows the actual percentage of compressed air that is water vapor at various dew points. Take notice that 99% removal rate is achieved at approximately 50°F. Any lower temperatures are achieved at a significant rate of diminishing returns.

### Actual Water Vapor Content Versus Dew Point

Dew Point in °F	Water Vapor Content in %	Clean Air in %
130°F	25.50	74.50
120°F	12.00	88.00
100°F	6.30	93.70
80°F	5.00	95.00
50°F	1.10	98.90
38°F	0.80	99.20
0°F	0.10	99.90
-20°F	0.04	99.96
-40°F	0.01	99.99
-60°F	0.004	99.996

Comprehensive information on compressed air systems is provided in the book **“Compressed Air Operations Manual”** by Brian S. Elliott, ISBN: 0-07-147526-5 Published by the McGraw-Hill Book Co.



**Air Options, Inc.**  
P.O. Box 35984  
Houston, Texas 77235-5984  
Ph.: 713-721-9619  
Fax.: 713-721-1931

[www.Air-Options.com](http://www.Air-Options.com)

**AIR-OPTIONS, INC.**

Refrigerated Air Dryers • Traps • Oil/Water Separators • Compressor Mounts • Compressor Controls