

# INSTALLATION, OPERATION & MAINTENANCE MANUAL

MODEL E6CH1

6-POSITION TIMER CONTINUOUS CYCLE WITH HOLD-OFF

## **ELECTRONIC DESIGNS, INC.**

1683 Rock Hill Highway • Lancaster, SC 29720 Phone: (704) 545-1439 • Fax: (704) 545-8345

Website: <u>www.edi-usa.com</u> Email: info@edi-usa.com

#### **GENERAL DESCRIPTION – MODEL E6CH1:**

These solid state timers are capable of switching six (6) independent outputs. Each of the outputs has a switching capacity of 1 Amp at 120 VAC. By relocating the program wire from position #6 (on the Timer) to the number of positions desired, the timer will pulse only from 1 through the programmed number.

This is a continuous cycle timer, pulse rate is set and adjusted by the operator via OFF-ADJ and ON-ADJ potentiometers to preferred time settings. The timer cycling can be stopped or placed on "Hold" by energizing the timer Hold-Off circuit. This is accomplished by connecting the Hold-Off terminals together (Terminal 8 to Terminal 9). Isolation circuitry is incorporated into the timer which allows the Hold-Off function to be accomplished from a remote location.

### **FEATURES:**

- 120 VAC 50/60 Hz, Single Phase
- 1 amp maximum capacity per output
- 1 amp fuse protection
- All solid state industrial quality construction
- Hold-Off capability, either Local or Remote.
- LED indicates timer operation
- Line Surge Protection
- Start on Position 1
- Pilot lamp indicates power on
- Adjustable ON time 50 150 ms
- Adjustable OFF time 3 70 seconds
- UL Recognized to US and Canadian Standards under File E 60685
- Two year Factory warranty against parts or manufacturing defects.


## **GENERAL MOUNTING AND WIRING:**

- 1. Timer is to be mounted in a dust tight and water tight NEMA rated enclosure.
- 2. It is recommended to place conduit openings/holes in bottom of enclosure to prevent condensate or moisture from entering enclosure.
- 3. Mount the timer enclosure in a vibration-free area. (Use isolators to mount timer to sub plate.)
- 4. Run supply wiring to the timer, 120VAC, 1 Phase, 50/60 Hz from the line circuit protector.
- 5. Run wiring from the timer to the pilot valve box.

#### **ELECTRICAL WIRING:**

- 1. Connect 120VAC supply to HI (TERMINAL 11) and NEUTRAL (TERMINAL 10).
- 2. Connect one side of each valve to the COMMON (TERMINAL 7), sequentially.
- 3. Connect the other side of each solenoid valve to the SWITCHED OUTPUTS (TERMINAL 1 through 6), sequentially.
- 4. Set OFF ADJ potentiometer to desired time between pulses.
- 5. Set ON ADJ potentiometer to desired time duration of each pulse.
- 6. Connect Hold-Off Circuitry if needed to Terminals 8 and 9.

Website: www.electronicdesignsusa.com



#### NOTES:

- Adjust "ON" and "OFF" times on the Timer.
- 2. Program wire should be placed in desired output position.
- For Hold-Off Mode: Timer starts cycling when HIGH set point is reached and continues until ∆P falls. Signal is from external source.
- 4. Use of vibration isolators recommended for mounting timer to back plate.

PHYSICAL DIM. 5" X 5.25" MOUNTING DIM: 4.5" X 4.75"

