

City of Lenox
2024 Water Quality Report
Georgia Water System ID #: GA0750002

Water System Contact (Phone Number):

Teresa Barber (Day: 229-546-4252)

Chris Yawn (Night: 229-546-7816)

Summary of Water Quality Information

The **City of Lenox** drinking water system is owned and operated by the **City of Lenox**. The facility office is located at 15 East Colquitt Avenue in Lenox, Georgia. If there are any comments or inquiries to be made, please feel free to visit the City Hall or contact Teresa Barber, City Clerk, during regular working hours.

This report includes information about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. The **City of Lenox** is committed to providing your community with clean, safe, and reliable drinking water. For more information about your water or this report please call Teresa Barber. **A copy of this report will not be mailed to individual consumers but is available at City Hall upon request.**

Your water comes from four (4) community *groundwater* wells within the City of Lenox. Well 101 is located on Broad Street, well 102 is located at the corner of Hayes Road and Gray Avenue, well 103 is located on Hwy 41 S., and well 104 is located on Brad Street. Three (3) of the wells derive water from the *Unconfined Coastal Plain aquifer*, while the fourth taps into the confined *Coastal Plain* aquifer, all of which provide ample volumes of water for your community. Any necessary treatment, such as the removal of contaminants or addition of disinfectants, is performed at the well sites. All well properties are protected from activities that could potentially contaminate the water source.

A **Wellhead Protection Plan (WHPP)** has been completed for the **City of Lenox** by the Georgia Department of Natural Resources Environmental Protection Division (GA EPD). The **WHPP** identifies sources of pollution which could potentially contaminate the water supply. There are no cited potential pollution sources within the 15-foot control zone for any of the four (4) wells. Cited potential pollution sources within the 250-foot radius inner management zone of all four (4) wells include electrical transformers, utility poles, vehicle parking areas, sewer lines, access roads, secondary roads, and storm water run-off. Additional cited pollution sources for include abandoned vehicles for well 102; highway U.S. Route 41 for well 103; and agricultural fields and domestic septic systems for well 104. **The complete WHPP is available at the facility office by request.**

The **City of Lenox** water system is tested for more than eighty (80) drinking water parameters on a periodic basis determined by the GA EPD Drinking Water Program and/or the United States Environmental Protection Agency. Sampling/testing schedules are based on initial contaminant level assessments and can be changed if deemed necessary. Waivers may be issued for the analysis of any of the compounds mentioned if analytical data shows that the distributed drinking water in this area is not vulnerable to contamination from these chemicals. Samples are collected from the water system for the analysis of synthetic organic compounds, inorganic compounds, lead, and copper at least once in a three (3) year cycle. Well 101 is tested for volatile organic compounds annually while the remaining wells are tested once every three (3) years. Nitrate-nitrites, total trihalomethanes (TTHMs), and haloacetic acid (HAA5s) levels are analyzed annually, and bacteriological contaminants are monitored monthly. The **City of Lenox** also conducts radionuclide testing at a frequency between three (3) and nine (9) years.

During 2024, the **City of Lenox** water system was tested for the presence of bacteriological content, nitrate-nitrite, volatile organic compounds, TTHMs, and HAA5s. **We are pleased to inform you that The City of Lenox did not have any violations of water quality parameters during 2024.** All detected contaminants are delineated in the accompanying charts. Any contaminants not listed in the accompanying charts had results less than the detection limits and/or maximum contaminant levels.

During the most recent lead and copper monitoring event, ten (10) representative locations throughout your community were sampled for the analyses of lead and copper. Detectable levels were found in some of the analyzed samples, indicating the presence of some service lines containing these contaminants. This may indicate the presence of this contaminant in some service lines or home plumbing. To access all individual lead tap sample results for **City of Lenox** visit www.gadrinkingwater.net.

The Service Line Inventory (SLI) is a requirement under the Lead and Copper Rule Revisions (LCRR) to help water systems identify and replace lead service lines. It mandates that all public water systems develop and maintain an inventory of service line materials to assess the presence of lead and protect public health. The inventory will support proactive lead reduction efforts and ensure compliance with regulatory requirements to minimize lead exposure in drinking water. **The City of Lenox has submitted the required lead service line inventory. To review the complete SLI report, please visit City Hall.**

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing.

The City of Lenox is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact the City of Lenox. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

Additionally, the following measures may be taken to minimize exposure to lead and/or copper:

- *Use cold water for drinking or cooking.*
- *Do not cook with or consume water from the hot water faucet.*
- *Do not use hot water for making baby formula.*
- *Use only "lead-free" solder, fluxes and materials in new household plumbing and repairs.*

*Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the **EPA Safe Drinking Water Hotline (1-800-426-4791)**.*

*Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the **EPA Safe Drinking Water Hotline (1-800-426-4791)**.*

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include the following:

- ***Microbial contaminants***, i.e., viruses and bacteria from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- ***Inorganic contaminants***, i.e., salts and metals, can be naturally occurring or result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- ***Pesticides and herbicides*** may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- ***Organic chemical contaminants***, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, agricultural application, and septic systems.
- ***Radioactive contaminants***, which can be naturally occurring or the result of oil/gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

The City of Lenox strives to maintain the highest standards of performance and quality possible. In order to maintain a safe and dependable water supply, improvements that benefit the community must be made. Please help keep these costs as low as possible by utilizing good water conservation practices.

DEFINITION OF TERMS AND ABBREVIATIONS USED IN THIS REPORT

Maximum Residual Disinfectant Level (MRDL): "The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbiological contaminants."

Maximum Residual Disinfectant Level Goal (MRDLG): "The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants."

TTHMs (Total Trihalomethanes): One or more of the organic compounds Chloroform, Bromodichloromethane, Chlorodibromomethane, and/or Bromoform.

HAA5s (Haloacetic Acids): One or more of the organic compounds Monochloroacetic Acid, Dichloroacetic Acid, Trichloroacetic Acid, Monobromoacetic Acid, and Dibromoacetic Acid.

City of Lenox
2024 Water Quality Data
WSID: GA0750002

The table below lists all the drinking water contaminants that have been detected in your drinking water. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The data presented in this table is from testing done during the year noted. The Federal Environmental Protection Agency (EPA) and the Georgia Department of Natural Resources Environmental Protection Division (EPD) require monitoring for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Parameters, values, and/or sources may vary.

DETECTED INORGANIC CONTAMINANTS TABLE								
Parameter	Units	MCL [SMCL]	MCLG	City of Lenox Water System Results	Range of Detections	Sample Date	Violation No/Yes	Typical Source of Contaminant
Arsenic	ppb	10	**	7.6	ND to 7.6	2023	No ¹	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium	ppm	2	2	0.110	0.055 to 0.110	2023	No	Erosion of natural deposits
Chlorine	ppm	4	4	0.79	0.79 to 0.79	2024	No	Water additive used for control of microbes
Fluoride	ppm	4 [2]	4	0.48	0.41 to .048	2023	No	Erosion of natural deposits; water additive; discharge from fertilizer and aluminum factories

DETECTED ORGANIC CONTAMINANTS TABLE								
Parameter	Units	MCL	MCLG	City of Lenox Water System Results	Range of Detections	Sample Date	Violation No/Yes	Typical Source of Contaminant
Haloacetic Acids	ppb	60	**	1.8	1.8 to 1.8	2024	No	By product of drinking water disinfection
THHMs	ppb	80	**	1.6	1.6 to 1.6	2024	No	By product of drinking water disinfection
Xylenes, Total	ppm	10	10	0.53	ND to 0.53	2024	No	Discharges from petroleum and chemical factories; fuel solvent

OTHER DETECTED UNREGULATED CONTAMINANTS TABLE								
Parameter	Units	MCL [SMCL]	MCLG	City of Lenox Water System Results	Range of Detections	Sample Date	Violation No/Yes	Typical Source of Contaminant
Sodium	ppm	**	**	38.0	10.0 to 38.0	2023	No	Erosion of natural deposits

LEAD AND COPPER MONITORING RESULTS								
Parameter	Units	Action Level	MCLG	City of Lenox 90th Percentile	Range of Detections	Sample Date	Violation No/Yes	Typical Source of Contaminant
Lead	ppb	15	0	1.20	ND to 12.0	2023	No	Corrosion of household plumbing
Copper	ppm	1.3	1.3	0.053	0.0026 to 0.150	2023	No	Corrosion of household plumbing

MICROBIOLOGICAL MONITORING RESULTS								
Parameter	Units	MCL	MCLG	City of Lenox Number of Positive Samples	Positive Sample Date (Month)	Sample Year	Violation No/Yes	Typical Source of Contaminant
Total Coliform	Present/ Absent	1*	0	0	N/A	2024	No	Naturally present in the environment
E. coli		0	0	0	N/A	2024	No	Human and animal fecal waste

RADIONUCLIDES TABLE								
Parameter	Units	MCL	MCLG	City of Lenox Water System Results	Range of Detections	Sample Date	Violation No/Yes	Typical Source of Contaminant
Alpha emitters	pCi/L	15	0	3.78	3.78 to 3.78	2023	No	Erosion of natural deposits
Combined Radium 226/228	pCi/L	5	0	1.38	1.38 to 1.38	2023	No	Erosion of natural deposits

*Total Coliform Rule MCL= 1 positive sample for systems that collect <40 samples a month ** No established MCL, SMCL or MCLG

•N/A: Not applicable to this contaminant •ppb (ug/L): parts per billion or micrograms per liter •ppm (mg/L): parts per million or milligrams per liter •pCi/l: picocuries per liter, a measurement of radiation

•ND (Not Detected): By regulation, this substance or group of substances was tested for in our finished tap water; however, none was detected at the testing limit.

•Action Level (AL): "The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow."

•Maximum Contaminant Level (MCL): "The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG as feasible using the best available treatment technology."

•Maximum Contaminant Level Goal (MCLG): "The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety."

•Secondary Maximum Contaminant Level (SMCL): Reasonable goals for drinking water quality. Exceeding SMCL's may adversely affect odor or appearance, but there is no known risk to human health.

¹ While your drinking water meets EPA standards, it does contain low levels of arsenic; see full Water Quality Report for information regarding possible health effects.