



A NEW BUS MAINTENANCE FACILITY FOR

Unified School District #446

Independence, Kansas

ADDENDUM #2

ISSUED: 9 January 2019

The following items modify and supersede the Contract Documents and are hereby made a part of the Bid Documents. This addendum shall be acknowledged on the Bid Form.

1. General:

- A. Building Permit- Since the location of the building site will not be known at bid time, Bidders should not include cost for the building permit in their Bid.

2. Section 083613 – Sectional Doors

- A. Interior handles only are required on sectional door locks.
- B. Electric operator shall be center mounted on cross head shaft.
- C. Safety edge is not required. Only photo eye sensors are required.

3. Section 133419 – Metal Building Systems

- A. Behlen Building Systems, SBI Metal Buildings and CanAm Steel Building Corp. are approved manufacturers for Section 133419.

4. Sheet P-2 Plumbing Details

- A. The compressed air piping is specified on the Typical Compressed Air Drop Detail on sheet P-2.

5. Sheet E-1 Power Plan

- A. Macurco is an approved manufacturer for the gas detection equipment.
- B. Electrical Contractor to provide telephone and data outlet rough-in only. Cabling will be provided by Owner.

End of Addendum Number Two