



Fig. 105 BD

150# Flanged Wafer Style Stainless Steel

Transmitter Isolation Ball Valve

Installation, Operation and Maintenance Instructions

INTRODUCTION

This Instruction manual includes installation, operation, maintenance and engineering information for the Trans-Valve Fig. 105 BD Stainless Steel Transmitter Isolation Ball Valves.

STORAGE

Valves are shipped in individual plastic bags with added flange area protection. Valves should be stored in a clean, dry, sheltered area to prevent any possible contamination from weather or foreign materials. The valve seats and seals (soft goods) have an unlimited shelf life when properly stored.

PRE-INSTALLATION

It is the responsibility of the end user to ensure the valve materials, including soft goods, are compatible with the process media. All applicable valve/piping standards and best practices regarding valve installation procedures must be understood and followed. The following should be read and understood prior to the installation of the valve.

WARNING: To avoid personal injury to yourself, fellow workers, or possible damage to property from accidental release of process media, the following steps should always be taken prior to valve installation:

- A. Shut off all operating lines to the valve installation location and isolate the area completely from the process.
- B. Release the process pressure.
- C. Vent and drain the process fluid or media from the valve location.
- D. Cycle the valve to release any trapped pressure.

INSTALLATION

The Fig. 105 BD has a tank side flange drilled and tapped to accommodate a standard ANSI 150# 4 bolt flange pattern. When mounting on a standard ANSI 150# 4 bolt tank flange, the valve can be mounted in any quadrant.

Trans-Valve offers complete stainless steel fastener kits for both flange mounting patterns. Contact your distributor for pricing.

Instructions for mounting Fig. 105 BD to 3" ANSI 150# tank flange

1. Install four 5/8-11 x 4-3/4" threaded studs into the tapped holes of the tank flange.
2. Install a gasket between the tank flange and tank side of the valve body.
3. Push the tank side of the valve (handle in any quadrant) up against the tank flange, allowing the center protrusion of the valve to enter the bore of the tank flange. The four studs will pass through the mating holes of the valve body.
4. Install four 5/8-11 hex nuts and lock washers on the four threaded studs and tighten in a staggered sequence to compress the gasket between the tank flange and the valve until a leak-tight seal is accomplished.
5. Install a gasket between the instrument side of the valve and the transmitter flange.
6. Push the transmitter flange up against the instrument side of the valve body, allowing the four studs to pass through the holes of the transmitter flange.
7. Install four 5/8-11 hex nuts and lock washers on the four threaded studs and tighten in a staggered sequence until a leak-tight seal is accomplished.
8. Connect purge ports as needed (see section on purge port use and connection below).

Purge Port Use and Connection

The Fig. 105 BD Transmitter Isolation Ball Valve has (2) ¼" FNPT purge ports plugged with 316 stainless steel MNPT plugs. With the ball in the closed position and the calibration port (marked with letter "C" on body) plugged, the purge material flows through (3) holes in the body of the valve behind the cavity of the ball which exhausts on the tank side. Purge material exhausts to tank and must be compatible with tank contents. The calibration port (marked with letter "C" on body) is used for relieving pressure, some discharge and then calibration of the instrument. Calibrate with the ball in the closed position. The calibration port can be used as a purge port, with the ball in the open position, to briefly clean the recess of the diaphragm sensing area and port area. Purge material must be compatible with tank contents as purge exhausts off of instrument diaphragm face, upstream through ball port and back into the tank.


OPERATION

The Fig. 105 BD is designed for service in level transmitter isolation applications that meet the pressure/temperature limits of the valve materials (*see chart below*).


All valves are supplied with lever handles for quarter-turn manual operation. The sliding latch device locks the handle in the closed position and prevents accidental lever operation. Also, the valve can be padlocked in the closed position, if needed.

To manually operate the valve, slide the latch device and turn the handle 90° clock-wise to open. Turning the handle 90° counter clock-wise will close the valve. Valve position can be determined by the position of the handle in relation to the instrument. The handle will be parallel to the instrument when open and perpendicular to the instrument when closed.

Avoid operating and/or purging the valve with the ball in a partially open/closed position. Critical pressure drops and high flow rates can damage the seats, resulting in decreased valve life.



ITEM	DESCRIPTION	MATERIAL	QTY
1	BODY	ASTM A351 CF8M	1
2	BALL	ASTM A351 CF8M	1
3	RETAINER GASKET	TEFLON	1
4	SEAT	RTFE	2
5	RETAINER	ASTM A351 CF8M	1
6	STOP PIN	SUS 304	1
7	PACKING	TEFLON	1
8	GLAND NUT	SUS 304	1
9	STEM	SUS 304	1
10	1/4 NPT PLUG	SUS 316	2
11	LOCKOUT PIN	SUS 304	1
12	HANDLE	SUS 304	1
13	SET BOLT	SUS 304	3
14	SEAL	EPDM	1



MAINTENANCE

Valve parts are subject to normal wear and should be periodically inspected and replaced as necessary. The type and frequency of repair depends on the service conditions. Due to the nature of the application for the Fig. 105 BD, soft goods replacement should not be necessary. The only area that may occasionally require adjustment to compensate for stem movement and packing fatigue caused by pressure changes is the live loaded stem packing.

If leakage is detected at the stem, the packing can be adjusted by tightening the packing nut (gland nut) in ¼ turn intervals until the leak stops. If the nut cannot be tightened any further and the packing continues to leak, the valve should be replaced.