

Environment 1, Incorporated

P.O. BOX 7085, 114 OAKMONT DRIVE
GREENVILLE, N.C. 27835-7085

PHONE (252) 756-6208
FAX (252) 756-0633

DISTRIBUTION LEAD AND COPPER ANALYSIS

WATER SYSTEM ID#: 04-74-142

COUNTY: PITT

Name of Water System: GREGORY MEADOWS AT BELVOIR

Sample Type: Routine Distribution (Compliance) Non-compliance

Sample Site Type: Tier 1 Tier 2 Tier 3 Other

Location Code: 077 Tap Location: 733 DUSTY LANE-KITCHEN

Street Address:

City:

Check if sample site is owned or controlled by water system.

Check if sample site is a daycare or a K-12 school.

Facility ID No. (Distribution): D01

Sample Point: LCR

Collected By: LEE LATHAM

Mail Results to (water system representative):

GREGORY MEADOWS AT BELVOIR
LEE LATHAM
1459 ROBERSONVILLE RD
WASHINGTON, NC 27889

Collection Date	Collection Time X
07/16/18	11:00 AM

LABORATORY ID#: 37715

SAMPLE UNSATISFACTORY

RESAMPLE REQUESTED

CONTAM CODE	CONTAMINANT	METHOD CODE	REQUIRED REPORTING LIMIT (R.R.L.)	NOT DETECTED ABOVE R.R.L. (X)	QUANTIFIED RESULTS	ALLOWABLE LIMITS
1022	Copper	200.8	0.050 mg/l	X	mg/l	1.300 mg/l
1030	Lead	200.8	0.003 mg/l	X	mg/l	0.015 mg/l

	DATE:	TIME:
ANALYSES BEGUN:	07/16/18	03:30 PM
ANALYSES COMPLETED:	07/19/18	09:58 AM

Laboratory Log #: 8797-071618-077P

Certified By: MAO

COMMENTS:

Environment 1, Incorporated

P.O. BOX 7085, 114 OAKMONT DRIVE
GREENVILLE, N.C. 27835-7085

PHONE (252) 756-6208
FAX (252) 756-0633

DISTRIBUTION LEAD AND COPPER ANALYSIS

WATER SYSTEM ID#: 04-74-142

COUNTY: PITT

Name of Water System: GREGORY MEADOWS AT BELVOIR

Sample Type: Routine Distribution (Compliance) Non-compliance

Sample Site Type: Tier 1 Tier 2 Tier 3 Other

Location Code: 024 Tap Location: 741 WINDY LANE-KITCHEN

Street Address:

City:

Check if sample site is owned or controlled by water system.

Check if sample site is a daycare or a K-12 school.

Facility ID No. (Distribution): D01

Sample Point: LCR

Collected By: LEE LATHAM

Mail Results to (water system representative):

GREGORY MEADOWS AT BELVOIR
LEE LATHAM
1459 ROBERSONVILLE RD
WASHINGTON, NC 27889

Collection Date	Collection Time X
07/16/18	11:38 AM

LABORATORY ID#: 37715

SAMPLE UNSATISFACTORY

RESAMPLE REQUESTED

CONTAM CODE	CONTAMINANT	METHOD CODE	REQUIRED REPORTING LIMIT (R.R.L.)	NOT DETECTED ABOVE R.R.L. (X)	QUANTIFIED RESULTS	ALLOWABLE LIMITS
1022	Copper	200.8	0.050 mg/l	X	mg/l	1.300 mg/l
1030	Lead	200.8	0.003 mg/l	X	mg/l	0.015 mg/l

	DATE:	TIME:
ANALYSES BEGUN:	07/16/18	03:32 PM
ANALYSES COMPLETED:	07/19/18	09:58 AM

Laboratory Log #: 8797-071618-024P

Certified By: MAO

COMMENTS:

Environment 1, Incorporated

P.O. BOX 7085, 114 OAKMONT DRIVE
GREENVILLE, N.C. 27835 7085

PHONE (252) 756-6208
FAX (252) 756-0633

DISTRIBUTION LEAD AND COPPER ANALYSIS

WATER SYSTEM ID#: 04-74-142

COUNTY: PITT

Name of Water System: GREGORY MEADOWS AT BELVOIR

Sample Type: Routine Distribution (Compliance) Non-compliance

Sample Site Type: Tier 1 Tier 2 Tier 3 Other

Location Code: 079 Tap Location: 721 DUSTY LANE-KITCHEN

Street Address:

City:

Check if sample site is owned or controlled by water system.

Check if sample site is a daycare or a K-12 school.

Facility ID No. (Distribution): D01

Sample Point: LCR

Collected By: LEE LATHAM

Mail Results to (water system representative):

GREGORY MEADOWS AT BELVOIR
LEE LATHAM
1459 ROBERSONVILLE RD
WASHINGTON, NC 27889

Collection Date	Collection Time X
07/16/18	11:47 AM

LABORATORY ID#: 37715

SAMPLE UNSATISFACTORY

RESAMPLE REQUESTED

CONTAM CODE	CONTAMINANT	METHOD CODE	REQUIRED REPORTING LIMIT (R.R.L.)	NOT DETECTED ABOVE R.R.L. (X)	QUANTIFIED RESULTS	ALLOWABLE LIMITS
1022	Copper	200.8	0.050 mg/l	X	mg/l	1.300 mg/l
1030	Lead	200.8	0.003 mg/l	X	mg/l	0.015 mg/l

	DATE:	TIME:
ANALYSES BEGUN:	07/16/18	03:33 PM
ANALYSES COMPLETED:	07/19/18	09:58 AM

Laboratory Log #: 8797-071618-079P

Certified By: MAO

COMMENTS:

Environment 1, Incorporated

P.O. BOX 7085, 114 OAKMONT DRIVE
GREENVILLE, N.C. 27835-7085

PHONE (252) 756-6208
FAX (252) 756-0633

DISTRIBUTION LEAD AND COPPER ANALYSIS

WATER SYSTEM ID#: 04-74-142

COUNTY: PITT

Name of Water System: GREGORY MEADOWS AT BELVOIR

Sample Type: Routine Distribution (Compliance) Non-compliance

Sample Site Type: Tier 1 Tier 2 Tier 3 Other

Location Code: 003 Tap Location: 741 ROOSEVELT SPAIN RD-KITCHEN

Street Address:

City:

Check if sample site is owned or controlled by water system.

Check if sample site is a daycare or a K-12 school.

Facility ID No. (Distribution): D01

Sample Point: LCR

Collected By: LEE LATHAM

Mail Results to (water system representative):

GREGORY MEADOWS AT BELVOIR
LEE LATHAM
1459 ROBERSONVILLE RD
WASHINGTON, NC 27889

Collection Date	Collection Time X
07/16/18	11:10 AM

LABORATORY ID#: 37715

SAMPLE UNSATISFACTORY

RESAMPLE REQUESTED

CONTAM CODE	CONTAMINANT	METHOD CODE	REQUIRED REPORTING LIMIT (R.R.L.)	NOT DETECTED ABOVE R.R.L. (X)	QUANTIFIED RESULTS	ALLOWABLE LIMITS
1022	Copper	200.8	0.050 mg/l	X	mg/l	1.300 mg/l
1030	Lead	200.8	0.003 mg/l	X	mg/l	0.015 mg/l

	DATE:	TIME:
ANALYSES BEGUN:	07/16/18	03:35 PM
ANALYSES COMPLETED:	07/19/18	09:58 AM

Laboratory Log #: 8797-071618-003P

Certified By: MAO

COMMENTS:

Environment 1, Incorporated

P.O. BOX 7085, 114 OAKMONT DRIVE
GREENVILLE, N.C. 27835-7085

PHONE (252) 756-6208
FAX (252) 756-0633

DISTRIBUTION LEAD AND COPPER ANALYSIS

WATER SYSTEM ID#: 04-74-142

COUNTY: PITT

Name of Water System: GREGORY MEADOWS AT BELVOIR

Sample Type: Routine Distribution (Compliance) Non-compliance

Sample Site Type: Tier 1 Tier 2 Tier 3 Other

Location Code: 062 Tap Location: 818 DUSTY LANE

Street Address:

City:

Check if sample site is owned or controlled by water system.

Check if sample site is a daycare or a K-12 school.

Facility ID No. (Distribution): D01

Sample Point: LCR

Collected By: LEE LATHAM

Mail Results to (water system representative):

GREGORY MEADOWS AT BELVOIR
LEE LATHAM
1459 ROBERSONVILLE RD
WASHINGTON, NC 27889

Collection Date	Collection Time X
07/16/18	11:55 AM

LABORATORY ID#: 37715

SAMPLE UNSATISFACTORY

RESAMPLE REQUESTED

CONTAM CODE	CONTAMINANT	METHOD CODE	REQUIRED REPORTING LIMIT (R.R.L.)	NOT DETECTED ABOVE R.R.L. (X)	QUANTIFIED RESULTS	ALLOWABLE LIMITS
1022	Copper	200.8	0.050 mg/l	X	mg/l	1.300 mg/l
1030	Lead	200.8	0.003 mg/l	X	mg/l	0.015 mg/l

	DATE:	TIME:
ANALYSES BEGUN:	07/16/18	03:36 PM
ANALYSES COMPLETED:	07/19/18	09:58 AM

Laboratory Log #: 8797-071618-062P

Certified By: MAO

COMMENTS:

Environment 1, Incorporated

P.O. BOX 7085, 114 OAKMONT DRIVE
GREENVILLE, N.C. 27835-7085

PHONE (252) 756-6208
FAX (252) 756-0633

DISTRIBUTION LEAD AND COPPER ANALYSIS

WATER SYSTEM ID#: 04-74-140

COUNTY: PITT

Name of Water System: GREGORY MEADOWS #2

Sample Type: Routine Distribution (Compliance) Non-compliance

Sample Site Type: Tier 1 Tier 2 Tier 3 Other

Location Code: 038 Tap Location: 1431 BILLY LOOP-KITCHEN

Street Address:

City:

Check if sample site is owned or controlled by water system.

Check if sample site is a daycare or a K-12 school.

Facility ID No. (Distribution): D01

Sample Point: LCR

Collected By: LEE LATHAM

Mail Results to (water system representative):

GREGORY MEADOWS #2
LEE LATHAM
1459 ROBERSONVILLE RD
WASHINGTON, NC 27889

Collection Date	Collection Time X
07/16/18	10:40 AM

LABORATORY ID#: 37715

SAMPLE UNSATISFACTORY

RESAMPLE REQUESTED

CONTAM CODE	CONTAMINANT	METHOD CODE	REQUIRED REPORTING LIMIT (R.R.L.)	NOT DETECTED ABOVE R.R.L. (X)	QUANTIFIED RESULTS	ALLOWABLE LIMITS
1022	Copper	200.8	0.050 mg/l	X	mg/l	1.300 mg/l
1030	Lead	200.8	0.003 mg/l	X	mg/l	0.015 mg/l

	DATE:	TIME:
ANALYSES BEGUN:	07/16/18	03:28 PM
ANALYSES COMPLETED:	07/19/18	09:58 AM

Laboratory Log #: 8796-071618-038P

Certified By: MAO

COMMENTS:

P.O. BOX 7085, 114 OAKMONT DRIVE
GREENVILLE, N.C. 27835-7085

PHONE (252) 756-6208
FAX (252) 756-0633

DISTRIBUTION LEAD AND COPPER ANALYSIS

WATER SYSTEM ID#: 04-74-140

COUNTY: PITT

Name of Water System: GREGORY MEADOWS #2

Sample Type: Routine Distribution (Compliance) Non-compliance

Sample Site Type: Tier 1 Tier 2 Tier 3 Other

Location Code: 032 Tap Location: 1457 BILLY LOOP-KITCHEN

Street Address:

City:

Check if sample site is owned or controlled by water system.

Check if sample site is a daycare or a K-12 school.

Facility ID No. (Distribution): D01

Sample Point: LCR

Collected By: LEE LATHAM

Mail Results to (water system representative):

GREGORY MEADOWS #2
LEE LATHAM
1459 ROBERSONVILLE RD
WASHINGTON, NC 27889

Collection Date	Collection Time X
-----------------	-------------------

07/16/18

10:00 AM

LABORATORY ID#: 37715

SAMPLE UNSATISFACTORY

RESAMPLE REQUESTED

CONTAM CODE	CONTAMINANT	METHOD CODE	REQUIRED REPORTING LIMIT (R.R.L.)	NOT DETECTED ABOVE R.R.L. (X)	QUANTIFIED RESULTS	ALLOWABLE LIMITS
1022	Copper	200.8	0.050 mg/l	X	mg/l	1.300 mg/l
1030	Lead	200.8	0.003 mg/l	X	mg/l	0.015 mg/l

	DATE:	TIME:
ANALYSES BEGUN:	07/16/18	03:29 PM
ANALYSES COMPLETED:	07/19/18	09:58 AM

Laboratory Log #: 8796-071618-032P

Certified By: MAO

COMMENTS:

Environment 1, Incorporated

P.O. BOX 7085, 114 OAKMONT DRIVE
GREENVILLE, N.C. 27835-7085

PHONE (252) 756-6208
FAX (252) 756-0633

DISTRIBUTION LEAD AND COPPER ANALYSIS

WATER SYSTEM ID#: 04-74-140 COUNTY: PITT

Name of Water System: GREGORY MEADOWS #2

Sample Type: Routine Distribution (Compliance) Non-compliance

Sample Site Type: Tier 1 Tier 2 Tier 3 Other

Location Code: 049 Tap Location: 1430 BOSS LANE-KITCHEN

Street Address: City:

Check if sample site is owned or controlled by water system.

Check if sample site is a daycare or a K-12 school.

Facility ID No. (Distribution): D01

Sample Point: LCR

Collected By: LEE LATHAM

Mail Results to (water system representative):

GREGORY MEADOWS #2
LEE LATHAM
1459 ROBERSONVILLE RD
WASHINGTON, NC 27889

Collection Date Collection Time X

07/16/18

10:30 AM

LABORATORY ID#: 37715

SAMPLE UNSATISFACTORY

RESAMPLE REQUESTED

CONTAM CODE	CONTAMINANT	METHOD CODE	REQUIRED REPORTING LIMIT (R.R.L.)	NOT DETECTED ABOVE R.R.L. (X)	QUANTIFIED RESULTS	ALLOWABLE LIMITS
1022	Copper	200.8	0.050 mg/l	X	mg/l	1.300 mg/l
1030	Lead	200.8	0.003 mg/l	X	mg/l	0.015 mg/l

	DATE:	TIME:
ANALYSES BEGUN:	07/16/18	03:29 PM
ANALYSES COMPLETED:	07/19/18	09:58 AM

Laboratory Log #: 8796-071618-049P

Certified By: MAO

COMMENTS:

Environment 1, Incorporated

P.O. BOX 7085, 114 OAKMONT DRIVE
GREENVILLE, N.C. 27835-7085

PHONE (252) 756-6208
FAX (252) 756-0633

DISTRIBUTION LEAD AND COPPER ANALYSIS

WATER SYSTEM ID#: 04-74-140

COUNTY: PITT

Name of Water System: GREGORY MEADOWS #2

Sample Type: Routine Distribution (Compliance) Non-compliance

Sample Site Type: Tier 1 Tier 2 Tier 3 Other

Location Code: 006 Tap Location: 1338 BILLY LOOP-KITCHEN

Street Address:

City:

Check if sample site is owned or controlled by water system.

Check if sample site is a daycare or a K-12 school.

Facility ID No. (Distribution): D01

Sample Point: LCR

Collected By: LEE LATHAM

Mail Results to (water system representative):

GREGORY MEADOWS #2
LEE LATHAM
1459 ROBERSONVILLE RD
WASHINGTON, NC 27889

Collection Date	Collection Time X
07/16/18	10:20 AM

LABORATORY ID#: 37715

SAMPLE UNSATISFACTORY

RESAMPLE REQUESTED

CONTAM CODE	CONTAMINANT	METHOD CODE	REQUIRED REPORTING LIMIT (R.R.L.)	NOT DETECTED ABOVE R.R.L. (X)	QUANTIFIED RESULTS	ALLOWABLE LIMITS
1022	Copper	200.8	0.050 mg/l	X	mg/l	1.300 mg/l
1030	Lead	200.8	0.003 mg/l	X	mg/l	0.015 mg/l

	DATE:	TIME:
ANALYSES BEGUN:	07/16/18	03:29 PM
ANALYSES COMPLETED:	07/19/18	09:58 AM

Laboratory Log #: 8796-071618-006P

Certified By: MAO

COMMENTS:

Environment 1, Incorporated

P.O. BOX 7085, 114 OAKMONT DRIVE
GREENVILLE, N.C. 27835-7085

PHONE (252) 756-6208
FAX (252) 756-0633

DISTRIBUTION LEAD AND COPPER ANALYSIS

WATER SYSTEM ID#: 04-74-140

COUNTY: PITT

Name of Water System: GREGORY MEADOWS #2

Sample Type: Routine Distribution (Compliance) Non-compliance

Sample Site Type: Tier 1 Tier 2 Tier 3 Other

Location Code: 023 Tap Location: 1349 BILLY LOOP

Street Address:

City:

Check if sample site is owned or controlled by water system.

Check if sample site is a daycare or a K-12 school.

Facility ID No. (Distribution): D01

Sample Point: LCR

Collected By: LEE LATHAM

Mail Results to (water system representative):

GREGORY MEADOWS #2
LEE LATHAM
1459 ROBERSONVILLE RD
WASHINGTON, NC 27889

Collection Date Collection Time X

07/16/18

10:50 AM

LABORATORY ID#: 37715

SAMPLE UNSATISFACTORY

RESAMPLE REQUESTED

CONTAM CODE	CONTAMINANT	METHOD CODE	REQUIRED REPORTING LIMIT (R.R.L.)	NOT DETECTED ABOVE R.R.L. (X)	QUANTIFIED RESULTS	ALLOWABLE LIMITS
1022	Copper	200.8	0.050 mg/l	X	mg/l	1.300 mg/l
1030	Lead	200.8	0.003 mg/l	X	mg/l	0.015 mg/l

	DATE:	TIME:
ANALYSES BEGUN:	07/16/18	03:30 PM
ANALYSES COMPLETED:	07/19/18	09:58 AM

Laboratory Log #: 8796-071618-023P

Certified By: MAO

COMMENTS: